



**STATE OF CONNECTICUT  
MILITARY DEPARTMENT**

360 Broad Street, Hartford, CT 06105  
Purchasing Department  
Tel: 860-524-4995; Fax: 860-548-3281



**DATE ISSUED: August 18, 2011**

**BID #11MIL217-2401**

**BID ADDENDUM #2**

**DESCRIPTION: Enfield Armory – Boiler replacement  
Norwalk Armory – Hot water system replacement**

**BIDDERS NOTE:**

**Responses to RFI's and site visit:**

**Item 1:** At Enfield, per Yankee gas, the gas pressure to be provided shall be 7"WC downstream of the meter.

**Item 2:** At Enfield, it may be acceptable to use existing openings in the roof, subject to the layout and method of flashing to be approved by the Engineer and the Military.

**Item 3:** At Enfield, the roofing system is a "High Performance Built-Up Roofing System", with an installed completion date of 12/15/2002, and a Thirty (30) year warranty with The Garland Company, Inc. The Contractor shall coordinate in advance, all roof work, with the roof warranty holder in accordance with the roof warranty.

**Item 4:** At Enfield, the Contractors shall assume that the existing boiler contains asbestos containing material (ACM), and carry the cost of removal and disposal within their bids.


**Item 5:** At Enfield and Norwalk, the existing Energy Management System DDC is Johnson Controls. The POC is Chris Schoonerman at (860)731-4775.

**Item 6:** At Norwalk, the Contract shall include the purchase and installation of a new propane tank and all accessories indicated on the documents. This tank is to be used for the water heaters, the existing tank shall remain for use for the generator only. The vendor for propane in the Fairfield County is Parco Gas. The contact person is Eric Derlega at (203)377-7171.



**STATE OF CONNECTICUT  
MILITARY DEPARTMENT**

360 Broad Street, Hartford, CT 06105  
Purchasing Department  
Tel: 860-524-4995; Fax: 860-548-3281



**Item 7:** At Norwalk, the roofing system, at the Lower Front and Rear roof areas, is a "High Performance Built-Up Roofing System", with an installed completion date of 8/8/2003, and a Thirty (30) year warranty with The Garland Company, Inc. The Contractor shall coordinate in advance, all roof work, with the roof warranty holder in accordance with the roof warranty. The Upper roof area is a Urethane roof over a BUR.

**APPROVED**  
**Marie Thompson**  
**Purchasing Supervisor**

This Addendum must be ***Signed & Returned*** with your Bid.

\_\_\_\_\_  
*Authorized Signature of Bidder*

\_\_\_\_\_  
*Company Name*