



TOWN OF GREENWICH

Purchasing Department (203) 622-7881 Fax: (203) 622-7776
Town Hall • 101 Field Point Road • Greenwich, CT 06830

December 21, 2011

ADDENDUM #1

TOWN OF GREENWICH

REQUEST FOR BID #6846 DEADLINE: 12/30/11 AT 3:00 P.M.

EMERGENCY GENERATOR SERVICE


Question #1: Does the yearly price per generator include the cost of labor for repairs or are those to be quoted separately? Does the cost per location on page 11 need to include anything outside of the items listed in Part A?

Answer #1: The bid reply sheet has cost of labor/hour listed separately along with percentage of mark up for parts. Any repair to a generator beyond what is required by the inspection and oil, lube and filter would be billed at this higher rate upon approval by the Town.

Question #2: Specifications pages 6 thru 10 describes checks and tests. It does not mention lubrication, oil or filter changes, who is performing that work?

Answer #2: The contractor shall perform basic lubrication, oil and filter changes as needed when performing the specified inspections, checks and tests.

**ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS OF THIS RFB
REMAIN UNCHANGED.**


James Giannuto Latham, CPPB
Senior Buyer

JGL:tw