



**CITY OF DANBURY**  
155 DEER HILL AVENUE  
DANBURY, CONNECTICUT 06810

CHARLES J. VOLPE, JR  
PURCHASING AGENT

(203) 797-4571 PHONE  
(203) 796-1527 FAX  
c.volpe@ci.danbury.ct.us

January 9, 2012

**ADDENDUM #2**

**To**

**Bid #09-11-12-01 "Partial Window/Door Replacement & Abatement at the Danbury High School"**

This addendum shall be part of the Purchasing documents for the above captioned Bid. This addendum is to be acknowledged by the bidder by signing as provided below and returning with the bidder's proposal.

**SEE ATTACHED:** ADDENDUM NO. 2, Dated January 9, 2012, 1-page plus related attachments

**BID OPENING:** Remains the same – Thursday, January 12, 2012, 10:00 AM

Receipt of the addendum is hereby acknowledged.

Bidder \_\_\_\_\_

Signature \_\_\_\_\_

Title \_\_\_\_\_

Date \_\_\_\_\_

Charles J. Volpe, Jr.  
Purchasing Agent  
City of Danbury

**ADDENDUM NO. 2**

**OWNER:** CITY OF DANBURY  
DEPARTMENT OF PUBLIC WORKS  
155 DEER HILL AVENUE  
DANBURY, CT 06810

**PROJECT NAME:** PARTIAL WINDOW/DOOR REPLACEMENT AND ABATEMENT  
**AT THE:** DANBURY HIGH SCHOOL

This Addendum is hereby included in and made a part of the Contract Documents, dated 12/14/11 whether or not attached thereto.

All requirements of the original project specifications and drawings shall remain in force except as amended by this addendum.

DATE: JANUARY 9, 2012

**THIS ADDENDUM CONSISTS OF ONE (1) PAGE. IN ADDITION SUBMITTED RFI'S BY CONTRACTORS ARE ENCLOSED.**

**THE FOLLOWING ARE MODIFICATIONS, CLARIFICATIONS, DELETIONS OR ADDITIONS TO THE SPECIFICATIONS:**

**SPECIFICATION SECTION: 08801-7, 3.6(A) (1) (a):**

Add the following:

- B. "North" facing windows shall be all glazing facing the athletic field.

**SPECIFICATION SECTION: 08801-7, 3.6 (A) (3) (b) (4):**

Delete the word: "Pyrolitic"

**SPECIFICATION SECTION: 08801-7, 3.6 (B) (3) (b) (4):**

Delete the word: "Pyrolitic"

END OF ADDENDUM NO. 2

The following ATTACHMENTS are being provided for informational purposes:

**Bidder RFI Responses** (In the event of a discrepancy between these responses and the contract documents the contract documents shall prevail unless modified by addendum.)

Bid RFI-16 dated 1/4/12 (1 page)

Bid RFI-17 dated 1/6/12 (1 page)

Bid RFI-18 dated 1/6/12 (1 page)

DANBURY PUBLIC SCHOOLS  
DANBURY HIGH SCHOOL  
PARTIAL WINDOW / DOOR REPLACEMENT AND ABATEMENT

SECTION 00201

RFI FORM

**BID RFI-16**

OWNER'S RFI

CONTRACTOR'S REQUEST FOR INFORMATION NO. 14  
NO: \_\_\_\_\_

NAME OF PROJECT: DANBURY HIGH SCHOOL PARTIAL WINDOW/ DOOR REPLACEMENT  
AND ABATEMENT PROJECT

NAME OF OWNER: CITY OF DANBURY

DATE: 1/4/12

A/E PROJECT NO: 11029.00

FULLER D'ANGELO PC ARCHITECTS AND PLANNERS

45 KNOLLWOOD ROAD

ELMSFORD, NEW YORK 10523

TEL: 914.592.4444 FAX: 914.592.1717

FROM (CO. NAME): CHERRY HILL GLASS

CONTACT NAME: JULIE GOODMAN

SUBJECT: SCOPE

DISCIPLINE/TRADE: WINDOWS & DOORS BID PACKAGE ONE

DWG./SPEC. REFERENCE: A-733 DETAILS 1+3 TYPICAL

QUESTION:

FIELD CONDITION BID PACKAGE 2 DESCRIPTION STATES PREP

DRAWING/SPEC THE OPENINGS. DOES THIS INCLUDE THE

DISCREPANCY WOOD BLOCKING SHOWN ON THE REFERENCED

OWNER CHANGE DETAILS?

CLARIFICATION \_\_\_\_\_

CONTRACTOR'S SUGGESTION (IF APPLICABLE): \_\_\_\_\_

ALL BLOCKING AND PREP WORK ANSWER

ASSOCIATED WITH WINDOWS IS WINDOW

CONTRACTOR RESPONSIBILITY: \_\_\_\_\_


ARCHITECT'S SIGNATURE: J. R. D'Angelo

DATE: 01.06.12

Note: review and any responses to this request for information by the architect/engineer is strictly for design intent only and does not constitute acknowledgement or acceptance of any cost or schedule implications unless specifically presented by the contractor. By submission of this request for information, the contractor assumes all responsibility in the absence of an approved change order or work directive..

END OF SECTION

FULLER AND D'ANGELO, P.C.  
ARCHITECTS AND PLANNERS



DANBURY PUBLIC SCHOOL  
DANBURY HIGH SCHOOL  
PARTIAL WINDOW / DOOR REPLACEMENT AND ABATEMENT

SECTION 00201

RFI FORM

**BID RFI-17**

CONTRACTOR'S REQUEST FOR INFORMATION NO. 2  
NO: \_\_\_\_\_

OWNER'S RFI

NAME OF PROJECT: DANBURY HIGH SCHOOL PARTIAL WINDOW/ DOOR REPLACEMENT  
AND ABATEMENT PROJECT

NAME OF OWNER: CITY OF DANBURY

DATE: 1-6-12


A/E PROJECT NO: 11029.00

FULLER DANGELO PC ARCHITECTS AND PLANNERS

45 KNOLLWOOD ROAD

ELMSFORD, NEW YORK 10523

TEL: 914.592.4444 FAX: 914.592.1717



FROM (CO. NAME): ARCHITECTURAL WINDOW

CONTACT NAME: DAVID LAUG

SUBJECT: GLASS

DISCIPLINE/TRADE: WINDOWS

DWG./SPEC. REFERENCE: 08801-7

QUESTION:

\_\_\_ FIELD CONDITION

DRAWING/SPEC

DISCREPANCY

\_\_\_ OWNER CHANGE

\_\_\_ CLARIFICATION

\_\_\_ CONTRACTOR'S SUGGESTION (IF APPLICABLE):

ANSWER  
DELETE THE WORD "PYROLYTIC"

ARCHITECT'S SIGNATURE: [Signature]

DATE: 01.06.12

Note: review and any responses to this request for information by the architect/engineer is strictly for design intent only and does not constitute acknowledgement or acceptance of any cost or schedule implications unless specifically presented by the contractor. By submission of this request for information, the contractor assumes all responsibility in the absence of an approved change order or work directive.

END OF SECTION

FULLER AND D'ANGELO, P.C.  
ARCHITECTS AND PLANNERS

DANBURY PUBLIC SCHOOL  
DANBURY HIGH SCHOOL  
PARTIAL WINDOW / DOOR REPLACEMENT AND ABATEMENT

SECTION 00201

RFI FORM

**BID RFI-18**  
OWNER'S RFI

CONTRACTOR'S REQUEST FOR INFORMATION NO. 3  
NO: \_\_\_\_\_

NAME OF PROJECT: DANBURY HIGH SCHOOL PARTIAL WINDOW/ DOOR REPLACEMENT  
AND ABATEMENT PROJECT

NAME OF OWNER: CITY OF DANBURY

DATE: 1-6-12

A/E PROJECT NO: 11029.00

FULLER DANGELO PC ARCHITECTS AND PLANNERS

45 KNOLLWOOD ROAD

ELMSFORD, NEW YORK 10523

TEL: 914.592.4444 FAX: 914.592.1717


FROM (CO. NAME): ARCHITECTURAL WINDOW

CONTACT NAME: DAVID LANG

SUBJECT: GLASS

DISCIPLINE/TRADE: WINDOWS

DWG./SPEC. REFERENCE: 08801-7



QUESTION:

- FIELD CONDITION CONFIRM SOLARBW TO ON "NORTH ELEV."
- DRAWING/SPEC IS IT ACTUALLY AT NORTH/EAST
- DISCREPANCY (ELEV. 2, 10 & 11D)?
- OWNER CHANGE \_\_\_\_\_
- CLARIFICATION \_\_\_\_\_
- CONTRACTOR'S SUGGESTION (IF APPLICABLE): \_\_\_\_\_

ANSWER

NORTH ELEVATION SHALL MEAN ALL GLAZING FACING THE ATHLETIC FIELD

ARCHITECT'S SIGNATURE: [Signature]

DATE: 01.06.12

Note: review and any responses to this request for information by the architect/engineer is strictly for design intent only and does not constitute acknowledgement or acceptance of any cost or schedule implications unless specifically presented by the contractor. By submission of this request for information, the contractor assumes all responsibility in the absence of an approved change order or work directive..

END OF SECTION

FULLER AND D'ANGELO, P.C.  
ARCHITECTS AND PLANNERS