

Eastern Connecticut State University
Willimantic, Connecticut 06226-2295

Student Center Café Fireplace Replacement
Project: ECSU 2012-10

Bids Due	2:00P.M.	December 18, 2012
ADDENDUM NUMBER 1	DATE OF ADDENDUM:	December 11, 2012

The following clarifications are applicable to Drawings and Specifications for the project referenced above:

ITEM 1 **DRAWING D-1, DETAIL 6**

Delete note "Cut back exist. base flashing cone.....roofing manufacturer, Carlisle, must be obtained."

Add note: "Verify in field necessity to cut back exist. base flashing cone to accommodate new Town and Country 11" diameter flue pipe. If cut back of exist. base flashing cone is necessary to accommodate new Town and Country 11" dia. flue pipe, then written authorization from the roofing manufacturer, Carlisle, must be obtained prior to cut-back."

ITEM 2 **DRAWING A-1, DETAIL 8**

Delete the following notes:

"Provide flue pipe cap & 14" dia. galv. flue (by fireplace manuf.)"


"Provide 15" dia. galv. flue pipe flashing (by fireplace manuf.)"

"Re-flash EPDM membrane at area of flashing cone cutback..."

Add the following notes:

"Provide new flue pipe cap & 11" dia. galv. flue (by fireplace manuf.)"

"If necessary due to cutback of exist. base flashing cone, re-flash EPDM membrane at area of flashing cone cutback to provide weathertight seal. **Prior written authorization from Carlisle must be obtained. An Authorized Carlisle installer must be used, and a Carlisle rep must inspect the work upon completion. Note: Allied Restoration of East Hartford, CT was the original installer."**



Eastern Connecticut State University
Willimantic, Connecticut 06226-2295

Student Center Café Fireplace Replacement
Project: ECSU 2012-10

Bids Due	2:00P.M.	December 18, 2012
ADDENDUM NUMBER 1	DATE OF ADDENDUM:	December 11, 2012

The following clarifications are applicable to Drawings and Specifications for the project referenced above:

ITEM 1 **DRAWING D-1, DETAIL 6**

Delete note "Cut back exist. base flashing cone.....roofing manufacturer, Carlisle, must be obtained."

Add note: "Verify in field necessity to cut back exist. base flashing cone to accommodate new Town and Country 11" diameter flue pipe. If cut back of exist. base flashing cone is necessary to accommodate new Town and Country 11" dia. flue pipe, then written authorization from the roofing manufacturer, Carlisle, must be obtained prior to cut-back."

ITEM 2 **DRAWING A-1, DETAIL 8**

Delete the following notes:

"Provide flue pipe cap & 14" dia. galv. flue (by fireplace manuf.)"

"Provide 15" dia. galv. flue pipe flashing (by fireplace manuf.)"

"Re-flash EPDM membrane at area of flashing cone cutback..."

Add the following notes:

"Provide new flue pipe cap & 11" dia. galv. flue (by fireplace manuf.)"

"If necessary due to cutback of exist. base flashing cone, re-flash EPDM membrane at area of flashing cone cutback to provide weathertight seal. **Prior written authorization from Carlisle must be obtained. An Authorized Carlisle installer must be used, and a Carlisle rep must inspect the work upon completion. Note: Allied Restoration of East Hartford, CT was the original installer."**

Request for Quotation
Project Number: ECSU 2012-10

Request for Quotation: Student Center Café Fireplace Replacement,

This project consists of:

1. Removal of existing gas fireplace, flue pipe, flashing and roof cap, removal and salvaging for reinstallation of existing zinc panels adjacent to fireplace, removal of existing zinc panel underlayments, and removal of adjacent ceramic tile and underlayments.
2. Furnish and install new gas fireplace, flue pipe, flashing and cap. New gas fireplace to be connected to existing natural gas piping.
3. Reinstallation of existing salvaged zinc panels, installation of new underlayment for zinc panels, installation of new tiles and underlayments.
4. Repair of broken tiles at hearth and fireplace chase.
5. Installation of new stainless steel corner guards at corners of hearth and fireplace chase.
6. Provide all cutting and patching, demolition, modifications, and clean-up as required for a complete and finished product.

Mandatory pre-bid meeting to be held November 29, 2012 at 9:00 a.m. at the facilities conference room, 2nd floor, facilities building, Charter Oak Road, Willimantic, CT. Late arrivals of 10 minutes or more will not be given credit for attendance or allowed to sign in.

Plans and specifications available November 20, 2012 for pick-up at the purchasing dept. Gelsi-Young Hall, 3rd floor, Eastern Road, Willimantic, CT or by calling 465-5148, 8:00 – 4:00 p.m. There is a \$20 non-refundable charge for this bid package. No cash or credit cards will be accepted. Check is to be made payable to ECSU.

Proposal due date and time: December 18, 2012 at 2:00 p.m.

It is the vendors' responsibility to check the DAS website for any addendums. This information can be viewed by accessing; http://www.biznet.ct.gov/SCP_Search/Default.aspx?AccLast=1

Sealed proposals will be received in Gelsi-Young Hall Rm 344, Eastern Road, Eastern Connecticut State University, Willimantic, CT 06226 until 2:00 p.m. on the date shown above.

The awarding authority reserves the right to waive technical defects or to reject any and all bids.

Agency administrative contact: Cindy Hodis, Acquisitions Manager 860-465-5148