

CT DAS Bid 13PSX0172 EXHIBIT A.1

Description of Goods and Services

- I. Fuel Delivery Requirements:** The Contractor's delivery truck shall be capable of delivering, metering and pumping the avgas 100LL fuel from a dedicated fuel type delivery truck into the Danielson Airport aviation fuel tank. The delivery truck's meter shall be sealed in accordance with the regulations established and enforced by the State of Connecticut, Department of Consumer Protection, Division of Weights and Measures or any other originating State's regulations.

The Client Agency reserves the right to cancel and or refuse delivery from the Contractor if the delivery truck has a broken or unsealed meter. Each meter shall be equipped with a ticket printer which will provide an accurate receipt of the amount of avgas 100LL delivered to the Client Agency. The delivery ticket(s) shall be locked in the printer from the start of the delivery until the delivery is completed and recorded.

Access to the Danielson Airport aviation fuel tank is Monday through Friday, 8:00 AM – 4:00 PM.

Product delivery shall be made within twenty-four (24) hours of the delivery request made by the Client Agency. The Contractor shall provide a two (2) hour window delivery period for the day of delivery. Notification of this two (2) hour delivery window period shall be made to either of the following Client Agency contacts:

Mr. Kurt Sendlein at 860-250-4701
Or
Mr. Barry Pallanck at 860-883-6448.

The Contractor is responsible to insure their company representative delivering the avgas 100LL to Danielson Airport provides constant surveillance at the point of product transfer. Should a fuel spill occur, the Contractor shall immediately notify the Client Agency representative on site and immediately notify the State of Connecticut, Department of Energy and Environmental Protection at 860-424-3338.

- II. Fuel Requirements:** The avgas 100LL fuel shall meet the American Standards Testing Methods D910 (ASTM D910) specification. This specification can be obtained by contacting:

American Society for Testing Materials
916 Race Street
Philadelphia, PA 19103
OR: ASTM.org

Certifications of fuel compliance to specifications shall be provided to the Client Agency at time of delivery.

- III. Samples and Testing:** The Client Agency reserves the right to take samples from the delivery truck prior to the product being delivered and metered into the Danielson Airport avgas 100LL fuel tank in order to insure compliance with ASTM D910 for Avgas 100LL. An authorized Client Agency representative will oversee the taking of the sample(s) from the awarded Contractor's delivery truck prior to filling the tank. Sample bottles shall be provided by the Client Agency.

The Client Agency reserves the right to conduct a clear and bright bucket test and to have the fuel sample tested at an independent laboratory. Should the fuel meet or exceed the specification, the Client Agency will assume the cost of the testing.

In the event the fuel sample fails to meet the applicable specification, the delivery shall be refused and the Contractor shall replace the shipment with a new delivery of the fuel at no additional cost to the Client Agency. In addition, the Contractor shall be responsible for the cost of the initial and any reoccurring test(s) of the fuel performed and any and all incurred damages to include, but not be limited to the Client Agency's storing and dispensing equipment.