

REQUEST FOR PROPOSAL 2015-35-SBE CCSU Project 71-H Track and Soccer Field Fencing Addendum #2 Dated November 4, 2014

1- Regarding Drawing S1, Details 2, 3 and 4, Note A, Steel Pole and Protective Padding -

Clarification:

- a. The padding is made of **<u>19oz heavy coated vinyl</u>**, NOT 18oz as indicated on the drawing.
- b. The padding is custom made. Contact Wyndi Sifford, Northeast Customer Service Manager, at ProMats Athletics, 800-617-7125 for information.
- 2- Regarding Drawing D1, Details 2a, 2b, 5, 7 and 8-

Revision to Note regarding footing depth and grout type:

- a. For fence posts located on top of the retaining walls: Core drill 4" diameter, <u>20" deep</u> holes into the CMU walls (NOT 18" as indicated on the drawing).
- b. Fill the core drilled holes with **<u>non-shrink</u>**, high strength grout.

All other terms, conditions and specifications in the RFP remain the same. End of Addendum #2