



Central Connecticut State University

Start with a Dream. Finish with a Future.

Purchasing Department

**REQUEST FOR PROPOSAL 2015-44-SBE
ITBD Canopy
Addendum #1 Dated January 15, 2015**

Contents:

1) Questions received related to this RFP and answers -

- a) Regarding the ITBD Canopy Building: is all the structural steel hot dipped galvanized?

Answer: All structural steel to be hot dipped galvanized.

- b) The required gutters do not show a means of attachment to fascia, or the rain leaders to the building. Do we want to leave this to “ways and means” of contractor?

Answer: The method of attachment will be a means and methods by the contractor.

2) Extension of the bid response due date -

The bid due date has changed from January 20 to **Thursday January 22 2015**, same time and same location.

Note that the “inclement weather” clause from the original RFP still applies – In the event of university closing or early dismissal due to inclement weather, proposals will be due at 3:00 PM on the next business day. Call the University Snow Phone at 860-832-3333 for up to date information on cancellations or early closings.

**All other terms, conditions and specifications in the RFP remain the same.
End of Addendum #1**

