



Central Connecticut State University

Start with a Dream. Finish with a Future.

Purchasing Department

**REQUEST FOR PROPOSAL 2015-44-SBE
ITBD Canopy
Addendum #2 Dated January 20, 2015**

Contents:

1) Last questions received related to this RFP and answers -

- a) Detail 1 on drawing S-2, on far left shows note “new vent pipe”. I believe you can see this pipe on arch photo #P-10. We could use some additional info on exactly what you want done and with what type materials.

ANSWER: This is an existing vent pipe and is to remain untouched.

- b) The snow guard protection system on the new roofs need some advise on manufacture type. Many types and pricing out there.

ANSWER: Snow Guard System, by LM Curb, Longview TX or approved equal.

Note - If bidding a substitute or “equal” bidder MUST include COMPLETE information and specifications, including pictures, on the product being offered. Alternate or substitute bids without required information shall be deemed nonresponsive and will not be considered. All proffered alternates, substitutes or “equals” are subject to evaluation by CCSU. CCSU shall be the sole judge of whether any proposed item will fulfill its requirements for its intended purpose. For further information, see Connecticut State University System Standard Terms and Conditions section II.b.10 (in Purchasing Department Insert).

- c) Also just a small point; but calling this product snow fencing on the prints might net you the wood and wire fencing we see on the ground. CSI format lists them as snow guards section 077253.

ANSWER: To be called out as snow guard.

2) Second extension of the bid response due date -

The bid due date has changed to **Wednesday January 28, 2015**, same time and same location.

Note that the “inclement weather” clause from the original RFP still applies –

In the event of university closing or early dismissal due to inclement weather, proposals will be due at 3:00 PM on the next business day. Call the University Snow Phone at 860-832-3333 for up to date information on cancellations or early closings.

**All other terms, conditions and specifications in the RFP remain the same.
End of Addendum #2**

