UCONN HEALTH

REQUEST FOR QUOTATION
ADDENDUM Q & A
UCHC RFQ-06 Form
Rev. 1/15

Margaret Gilbert
Buyer
860-679-1988
Telephone Number
mgilbert@uchc.edu
E-mail Address
860-284-5873
Fax Number

UNIVERSITY OF CONNECTICUT HEALTH CENTER

Procurement Operations & Contracts
263 Farmington Avenue, MC4036
Farmington, CT 06032-4036

RFQ NUMBER:	QUOTE DUE DATE:	QUOTE DUE TIME:
UCHC4-57399191	February 9, 2015	2:00 PM EST
RFQ TITLE: Sand Filter for Chilled Water System Project 14-601.11		

ADDENDUM NUMBER: 1

DATE ADDENDUM ISSUED: February 3, 2015

FOR: The University of Connecticut Health Center

NOTE: Please see the following responses to supplier requests for additional information. All other terms and conditions, including due date and time. remain unchanged.

This Addendum must be *Signed & Returned* with your bid.

Authorized Signature of Bidder _____ *Company Name* _____

Approved By: _____
[M Gilbert]
Buyer
(Original Signature on Document in Procurement Files)

****SEE ATTACHED Q & A****

UCONN HEALTH

REQUEST FOR QUOTATION
ADDENDUM Q & A
UCHC RFQ-06.1 Form
Rev. 5/14

QUESTION #1:	Is this a prevailing wage project?
UCONN HEALTH RESPONSE:	No.
QUESTION #2:	Are the existing CHWS/R that we are tying into "Epoxy" lined?
UCONN HEALTH RESPONSE:	No, the piping is not epoxy lined.
QUESTION #3:	Is the PEP CL-24/150 the only make of filter allowed?
UCONN HEALTH RESPONSE:	Yes, the UConn Health Facilities shops prefer the PEP filters.

QUESTION #4:	
UCONN HEALTH RESPONSE:	
QUESTION #5:	
UCONN HEALTH RESPONSE:	
QUESTION #6:	
UCONN HEALTH RESPONSE:	