

Margaret Gilbert

*Buyer*

860-679-1988

*Telephone Number*

mgilbert@uchc.edu

*E-mail Address*

860-284-5873

*Fax Number*

## UNIVERSITY OF CONNECTICUT HEALTH CENTER

**Procurement Operations & Contracts**

**263 Farmington Avenue, MC4036**

**Farmington, CT 06032-4036**

ITB NUMBER:	BID DUE DATE:	BID DUE TIME:		ITB SURETY:
UCHC4-70794515	May 2, 2016	2:00 PM	EST	NA
ITB TITLE:		Service Contract - York Chiller		

**ADDENDUM NUMBER:** 1

**DATE ADDENDUM ISSUED:** April 20, 2016

**FOR:** The University of Connecticut Health Center

**NOTE:** 1. Responses to supplier questions received by the due date and time are

follow this cover page.

**This Addendum must be Signed & Returned with your bid.**

\_\_\_\_\_  
*Authorized Signature of Bidder*

\_\_\_\_\_  
*Company Name*

**Approved By:** \_\_\_\_\_

[ Margaret Gilbert ]

Buyer

*(Original Signature on Document in Procurement Files)*

<b>QUESTION #1:</b>	<b>Item 6. Anticipated Service Summary: Oil Analysis: (4 total = 4 per year)</b> The RFP calls for four (4) oil analysis per year, this is typically just done annually as standard with all chiller manufacturers.
<b>UConn HEALTH RESPONSE:</b>	Once per year is all that is required.