

The State of Connecticut
Department of Housing (DOH)
Community Development Block Grant Disaster Recovery Program
(CDBG-DR)

BID PACKAGE

For

CONSTRUCTION OF NEW RESIDENCE

For

GAIL AND JACK TREZ

20 COOPER AVENUE

MILFORD, CONNECTICUT 06460

Lothrop Associates^{LLP} Architects
100 Pearl Street – 14th Floor
Hartford, Connecticut 06103
860-249-7251

Issue Date: June 6, 2016

Application No.5076

LAA Project No. 1524-27



Table of Contents

Section 1:

Advertisement for Bids	2
Information to Bidders	4
Bid Form	8
Irrevocable Letter of Credit (Sample Form)	10
Form of Non-Collusive Affidavit	11
Bidders Certification of Eligibility	12
Certification of General Bidders on CDBG-DR Construction Projects.....	13
Certification of Sub Bidders on CDBG-DR Construction Projects	14
Bid Bond	15
Payment and Performance Bond.....	16
Subcontractor Identification.....	19
Certification of Bidder Regarding Equal Employment Opportunity	20
Certification of Bidders Regarding Section 3 and Segregated Facilities	21
Sample Section 3 Plan	22
Green Building Standards Checklist	25

Section 2:

General Conditions

Section 3:

Scope of Work and Specifications

Section 1

ADVERTISEMENT FOR BIDS

Project # 5076

The State of Connecticut Department of Housing (DOH) is seeking bids through a Invitation for Bids (IFB) process for the rehabilitation, reconstruction and/or mitigation of residential structures damaged by Superstorm Sandy in compliance with all applicable local, federal, and state statutory requirements with special attention paid to requirements for Community Development Block Grants under the United States Department of Housing and Urban Development (“HUD”) Disaster Recovery grant program.

Separated sealed bids for: **Construction of new Residence for Gail and Jack Trez at 20 Cooper Avenue, Milford, Ct. 06460**, will be received by **Lothrop Associates^{LLP} Architects, 100 Pearl Street, 14th Floor, Hartford Ct. 06103**, until **4:00 PM on June 29, 2016**, and then at said office publicly opened and read aloud.

The Information to Bidders, Form of Bid, Form of Contract, Plans, Specifications, and Form of Bid Bond, Performance and Payment Bond, and other contract documents may be examined on the Department of Housing Hurricane Sandy Recover website at www.ct.gov/doh/ and click on the “Hurricane Sandy” link.

DOH reserves the right to waive any informalities or to reject any or all bids.

Each bidder must deposit with his bid, security in the amount, form and subject to the conditions provided in the Information to Bidders.

Attention to bidders is particularly called to the requirements as to conditions of employment to be observed and minimum wages rates to be paid under the contract (if applicable), Section 3, Segregated Facilities, Section 109 and E. O. 11246.

No bidder may withdraw his bid within 30 calendar days after the actual date of the bid opening thereof.

INFORMATION FOR BIDDERS

Receipt and Opening of Bids:

The State of Connecticut Department of Housing (herein called the "DOH"), invites bids on the form attached hereto, all blanks of which must be appropriately filled. Bids will be received by DOH at the office of **Lothrop Associates^{LLP} Architects, 100 Pearl Street, 14th Floor, Hartford, Ct.06103**, until **4 o'clock PM on June 29, 2016** and then at said office publicly opened and read aloud.

The envelopes containing the bids must be sealed, addressed to **Lothrop Associates^{LLP} Architects at 100 Pearl St., 14th floor, Hartford, Ct. 06103** and designated as bid for:

Construction of New Residence for Gail and Jack Trez , 20 Cooper Avenue, Milford,CT. 06460

DOH may consider informal any bid not prepared and submitted in accordance with the provisions hereof and may waive any informalities or reject any and all bids. Any bid may be withdrawn prior to the above scheduled time for the opening of bids or authorized postponement there considered. NO bidder may withdraw a bid within 30 days after the actual date of the opening thereof.

Mandatory Walk Through: All bidders must attend a mandatory walk through of the property designated above. The date and time of the walk through is set for **10:00 AM on June 16, 2016**

Preparation of Bids:

Each bid must be submitted on the prescribed form and accompanied by Certification by Bidder Regarding Equal Employment Opportunity, Form HUD-950.1, and Certification of Bidder Regarding Section 3 and Segregated Facilities. All blank spaces for bid process must be filled in, in ink or typewritten, in both words and figures, and the foregoing Certifications must be fully completed and executed when submitted.

Each bid must be submitted in a sealed envelope bearing on the outside the name of the bidder, his/her address, and the name of the project for which the bid is submitted. If forwarded by mail, the sealed envelope containing the bid must be enclosed in another envelope addressed as specified in the bid form.

Subcontracts: The bidder is specifically advised that any person, for, or other party to whom it is proposed to award a subcontract under this contract:

1. Must be acceptable to the DOH after verification by the State of the current eligibility status; and,
2. Must submit Form HUD-950.2, Certification by Proposed Subcontractor Regarding Equal Employment Opportunity and Certification of Proposed Subcontractor Regarding Section 3 and Segregated Facilities. Approval of the proposed subcontractor award cannot be given by the DOH unless and until the proposed subcontractor has submitted the Certifications and/or other evidence showing that it has fully complied with any reporting requirements to which it is or was subject. Although the bidder is not required to attach such Certifications by proposed subcontractors to his/her bid, the bidder is here advised of this requirement so that appropriate action can be taken to prevent subsequent delay in subcontract awards.

Method of Bidding: DOH invites the following bid(s):

Qualifications of Bidder: The DOH may make such investigations as he/she deems necessary to determine the ability of the bidder to perform the work, and the bidder shall furnish to the DOH all such information and data for this purpose as the DOH may request. The DOH reserves the right to reject any bid if the evidence submitted by, or investigation of, such bidder fails to satisfy the DOH that such bidder is properly qualified to carry out the obligations of the contract and to complete the work contemplated therein. Conditional bids will not be accepted. The State's set Contractor Pre-qualifications are listed in Exhibit G and also are available at the Department of Housing's Hurricane Sandy Recovers website www.ct.gov/doh/ and click on the "Hurricane Sandy" link.

Bid Security: Each bid must be accompanied by an irrevocable letter of credit from the bank, certified check, or bank cashier's check in the amount not less than five percent (5%) of the bid. Bid bonds may be accepted as bid security. Such checks will be returned to all except the three lowest bidders within three days after the opening of bids, and the remaining cash, or checks will be returned promptly after DOH and the accepted bidder have executed the contract, or opening of bids, upon demand or the bidder at any time thereafter, so long as he/she has been notified of the acceptance of his/her bid.

Conditions of Work: Each bidder must inform him/herself fully of the conditions relating to the construction of the project and the employment of labor thereon. Failure to do so will not relieve a successful bidder of his/her obligation to furnish all material and labor necessary to carry out the provision of his/her contract. Insofar as possible the contractor, in carrying out the work, must employ such methods or means as will not cause any interruption of or interference with the work of any other contractor.

Addenda and Interpretations: No interpretation of the meaning of the plans, specifications or other pre-bid documents will be made to any bidder orally.

Every request for such interpretation should be in writing addressed to: **Vincent Lisanti, AIA at 100 Pearl Street, 14th Floor, Hartford, Ct. 06103 (e mail-vlisanti@lothropassociates.com)**, and to be given consideration must be received at least seven days prior to the date fixed for the opening of bids. Any and all such interpretations and any supplemental instruction will be in the form of written addenda to the specifications which, if issued, will be forwarded by electronic mail and posted on DOH's Hurricane Sandy website to all prospective bidders (at the respective email addresses furnished for such purposes), not later than three days prior to the date fixed for the opening of bids. Failure of any bidder to receive any such addendum or interpretation shall not relieve such bidder from any obligation under his/her bid as submitted. All addenda so issued shall become part of the contract documents.

Security for Faithful Performance: Simultaneously with his/her delivery of the executed contract, the Contractor shall furnish a surety bond or bonds as security for faithful performance of this contract and for the payment of all persons performing labor on the project under this contract and furnishing materials in connection with this contract, as specified in the General Conditions included herein. The surety on such bond or bonds shall be a duly authorized surety company satisfactory to the DOH.

Performance and Payment Bonds: A performance and payment bond will be required of the successful bidder (contractor) for 100 percent of the contract price on contracts over \$100,000.

Contract Progress Schedule: Each bid shall be accompanied by a Contract Progress Schedule. Such Schedule shall list the bidder's timetable for completion of the contract.

Power of Attorney: Attorneys-in-fact who sign bid bonds or contract bonds must file with each bond a certified and effectively dated copy of their power of attorney.

Notice of Special Conditions: Attention is particularly called to those parts of the contract documents and specifications which deal with the following:

1. Inspection and testing of materials
2. Insurance requirements
3. Wage rates (if applicable)
4. State allowances

Laws and Regulations: The bidder's attention is directed to the fact that all applicable State laws, municipal ordinances, and the rules and regulations of all authorities having jurisdiction over construction of the project shall apply to the contract throughout, and they will be deemed to be included in the contract the same as though herein written out in full.

Method of Award-Lowest Qualified Bidder: If at the time this contract is to be awarded, the lowest base bid submitted by a responsible bidder does not exceed the amount of funds then estimated by the DOH as available to finance the contract; the contract will be awarded on the base bid only. If such bid exceeds such amount, the DOH may reject all bids or may award the contract on the base bid combined with such deductible alternatives applied in numerical order in which they are listed in the Form of Bids, as produces a net amount which is within the available funds.

If the homeowner wishes to select a prequalified bidding contractor other than the lowest and most responsible bidder, said owner is responsible for paying the difference between the lowest bidder and their chosen bidder from their own financing.

Obligation of Bidder: At the time of the opening of bids, each bidder will be presumed to have inspected the site and to have read and to be thoroughly familiar with the plans and contract documents (including all addenda). The failure or omission of any bidder to examine any form, instrument or document shall in no way relieve any bidder from any obligation in respect to his/her bid.

Safety Standards and Accident Prevention: With respect to all work performed under this contract, the contractor shall:

1. Comply with the safety standards provision of applicable laws, building and construction codes and the "Manual of Accident Prevention in Construction" published by the Associated General Contractors of America, the requirements of the Occupational Safety and Health Act of 1970 (Public Law 91-596), and the requirements of Title 29 of the Code of Federal Regulations, Section 1518 as published in the "Federal Register," Volume 36, No 75, Saturday, April 17, 1971.
2. Exercise every precaution at all times for the prevention of accidents and the protection of persons (including employees) who may be injured on the job site before the employer has made a standing arrangement for removal of injured persons to a hospital or a doctor's care.

BID FORM

The undersigned, being familiarized with the local conditions affecting the cost of the work and with the Drawings, Specifications, Invitation to Bidders, Instructions to Bidders, General Conditions, Bid Form, Form of Contract and Form of Bonds for Project No. **5076** and Addenda No. _____ and _____ thereto, as prepared by **Lothrop Associates^{LLP} Architects**, Harford, Connecticut, and on file in the office of DOH, hereby proposes to furnish all permits, labor, materials, tools, equipment, and related items required for the demolition, abatement and construction including general construction, site improvements, plumbing, heating, electrical, and finish items for said Project No. 5076 located at **The Gail and Jack Trez Residence, 20 Cooper Avenue, in Milford, State of Connecticut**, all in accordance with the Drawings and Specifications, for the sum of:

_____ Dollars (\$))

BREAKDOWN OF COSTS FOR LUMP SUM BASE BID

The following is a Breakdown of Costs by Major Division used by the Bidder in assembling this bid:

GENERAL CONDITIONS, BONDS, INSURANCE, PERMITS	\$ _____
DIVISION 01 GENERAL REQUIREMENTS	\$ _____
DIVISION 03 CAST IN PLACE CONCRETE	\$ _____
DIVISION 05 STRUCTURAL STEEL	\$ _____
DIVISION 06 WOOD AND PLASTICS	\$ _____
DIVISION 07 THERMAL AND MOISTURE PROTECTION	\$ _____
DIVISION 08 OPENINGS (Exclusive Of Allowances)	\$ _____
DIVISION 09 FINISHES	\$ _____
DIVISION 22 PLUMBING (Exclusive Of Allowances)	\$ _____
DIVISION 23 HVAC	\$ _____
DIVISION 26 ELECTRICAL (Exclusive Of Allowances)	\$ _____
DIVISION 31 EARTHWORK	\$ _____
ALLOWANCE #1- MAW	\$3,000.00
ALLOWANCE #2 – PILE INSPECTION	\$5,000.00
ALLOWANCE #3 – TESTS AND INSPECTIONS	\$3,000.00
ALLOWANCE #4 – DOOR HARDWARE (_____ Doors @\$200 ea)	\$ _____
ALLOWANCE #5 – BATHROOM & LAUNDRY ACCESSORIES	\$1,000.00

ALLOWANCE # 6 – RESIDENTIAL CASEWORK	\$15,000.00
ALLOWANCE #7 - PLUMBING FIXTURES (_____ fixtures @\$122. ea.)	\$ _____
ALLOWANCE #8 - LIGHT FIXTURES (_____ Fixtures @ \$150.. ea.)	\$ _____

ALTERNATE PROPOSALS

The undersigned bidder further proposes and agrees that should any or all of the following Alternates be accepted and included in the Contract, the amount of the Base Bid, as heretofore stated, shall be adjusted by the amount stated for each Alternate. All materials and workmanship shall be in strict accordance with the Drawings and Specifications and shall be in-place prices.

ALTERNATE No. 1 (Perform Demolition)

ADD \$ _____

UNIT PRICES

Base bid amount shall include all pile and concrete foundation work. Unit prices are to be used for the purpose specified in Section 010400.

The undersigned bidder proposes and agrees to bid the following unit prices:

Helical Piles-installed complete with grout column: \$ _____ per linear foot
(In accordance with Specifications on the drawings)

Reinforced concrete foundations: \$ _____ per cubic yard
(In accordance with Specification Section 033000)

ALLOWANCES

The undersigned bidder further proposes and agrees to include in the Base Bid, any and all Allowances specified in the Contract.

The undersigned agrees to commence the work on a date to be specified in the contract and to complete such work within **180** consecutive calendar days.

The undersigned agrees that if within the period of thirty (30) calendar days after the opening of bids, or when extended to the next work day immediately following said period, notice of the acceptance of this bid shall be mailed, or delivered to him/her at the business address given below, or at any time thereafter before this bid is withdrawn, the undersigned will within fifteen (15) calendar days thereafter deliver to DOH, where directed, a contract properly executed in such number of counterparts as may be required by said DOH, on the forms annexed, with such changes therein as shall have been made by the DOH, prior to the time named for delivery of this proposal, together with a 100% Performance Bond of a Surety Company, which Surety must be authorized to transact business in the State of Connecticut, and duly qualified therefore, and in the form constituting part of the Specification and a letter indicating those Small/Minority Business Enterprises that will perform work and/or provide materials, equipment or services as part of the contract.

In submitting this bid, it is understood that the right is reserved by the abovementioned DOH to reject any and all bids; and it is agreed that this bid may not be withdrawn for a period of thirty calendar (30) days

from the date of bid opening or until the next work day immediately following said period if such period ends on weekend or a State holiday.

Security in the sum of _____ Dollars (\$ _____)

in the form of _____ is submitted herewith in accordance with the Specifications.

The undersigned bidder agrees to comply with the Section 3 plan included herein and all Federal requirements pertaining to conditions of employment to be observed and minimum wage rates to be paid under the contract, Segregated Facilities, Section 109 and Executive Order 11246.

Attached hereto is an affidavit, in proof that the undersigned has not entered into any collusion with any person in respect to this proposal, or any other proposal, or the submitting of proposals for the above Project. Also attached is a statement of contractor's qualifications, Certification of Bidder Regarding Equal Employment Opportunity, Certification of Bidder Regarding Section 3 and Segregated Facilities.

Date

Firm Name

Address

By: _____

Title: _____

(Bank Letterhead)

BID SECURITY

IRREVOCABLE LETTER OF CREDIT

Dear _____:

We hereby authorize you to draw on us to the aggregate amount of \$ _____
(five percent of the amount of the bid) in the event _____ withdraws
its bid within the bid holding period, or upon being awarded a contract, fails to provide adequate
performance and payment security as required by the Contract documents.

Such drafts must be accompanied by the following document:

A written certification by you that the proceeds of any draft drawn on this Letter of Credit will be
used solely to indemnify the DOH against loss or damage suffered by it resulting from any act or
omission described in the above paragraph.

We warrant to you that all drafts drawn in compliance with the terms of this Letter of Credit will be
unconditionally and duly honored upon delivery of the documentation specified and presented to this
office.

This Letter of Credit is irrevocable and shall be in full force and effect until notification in writing is
received from you that a contract for Project _____ has been awarded and
executed, whereupon this Letter of Credit shall automatically be canceled.

This Letter of Credit shall not be modified or amended except upon the written agreement of this Bank
and the DOH.

Sincerely yours,

President

FORM OF NON-COLLUSIVE AFFIDAVIT

AFFIDAVIT

State of _____)

County of _____)

_____, being first duly sworn, deposes and says:

That he/she is, _____ the party making the foregoing proposal for bid, that such proposal or bid is genuine and not collusive or sham; that said bidder has not colluded, conspired, connived or agreed, directly or indirectly, with any bidder or person, to put in a sham bid or to refrain from bidding, and has not, in any manner, directly or indirectly, sought by agreement or collusion, or communication or conference, with any person, to fix the bid price of affiant or of any other bidder, or to fix any overhead, profit or cost element of said bid price, or of that of any other bidder, or to secure any advantage against DOH or any person interested in the proposed contract, and that all statements in said proposal for bid are true.

Project No. _____

Location _____

Signature

Name and Title

Date

(Signature should be notarized.)

BIDDER'S CERTIFICATION OF ELIGIBILITY

By the submission of this bid, the bidder certifies that to the best of its knowledge and belief, neither it, nor any person or firm which has an interest in the bidder's firm, nor any of the bidder's subcontractors, is ineligible to:

- (1) Be awarded contracts by any agency of the United States Government or HUD; or,
- (2) Participate in HUD programs pursuant to 24 CFR part 24.

(Name of Bidder)

(Address)

BY: _____

Title: _____

NOTE: This certification is a material representation of fact upon which reliance is placed when making award. If it is later determined that the bidder knowingly rendered an erroneous certification, the contract may be terminated for default, and the bidder may be debarred or suspended from participation in HUD programs and other Federal programs.

CERTIFICATION OF GENERAL BIDDERS ON CDBG-DR CONSTRUCTION PROJECTS

I. CERTIFICATION REGARDING HEALTH AND SAFETY

The undersigned hereby certifies that he/she is able to furnish labor that can work in harmony with all other elements of labor employed or to be employed on the work; that all employees to be employed at the worksite will have successfully completed a course in construction safety and health approved by the United States Occupational Safety and Health Administration that is at least ten hours in duration at the time the employee begins work and who shall furnish documentation of successful completion of said course with the first certified payroll report for each employee.

II. CERTIFICATION REGARDING NON-COLLUSION AND DEBARMENT

The undersigned further certifies under the penalties of perjury that this bid is in all respects bona fide, fair and made without collusion or fraud with any other person. As used in this subsection the word “person” shall mean any natural person, joint venture, partnership, corporation or other business or legal entity. The undersigned further certifies that neither he/she nor any firm, corporation, partnership or association in which he/she has a substantial interest is designated as an ineligible contractor by the Comptroller General of the United States pursuant to Section 5.6 (b) of the Regulations of the Secretary of Labor, Part 5 (29 CFR, Part 5), or pursuant to Section 3 (a) of the Davis-Bacon Act, as amended (40 USC 276a). The undersigned further certifies that said undersigned is not presently debarred from doing public construction work in the State of Connecticut.

Date: _____

Name of General Bidder

By _____

Signature

Print name and Title

Business Address

Street Address City and State

OSHA-10 OSHA-10

CERTIFICATION OF SUB- BIDDERS (IF ANY) ON CDBG-DR CONSTRUCTION PROJECTS

I. CERTIFICATION REGARDING HEALTH AND SAFETY

The undersigned hereby certifies that he is able to furnish labor that can work in harmony with all other elements of labor employed or to be employed on the work; that all employees to be employed at the worksite will have successfully completed a course in construction safety and health approved by the United States Occupation Safety and Health Administration that is at least ten hours in duration at the time the employee begins work and who shall furnish documentation of successful completion of said course with the first certified payroll report for each employee; and that he will comply fully with all laws and regulations applicable to awards of subcontracts subject to section 44F.

II. CERTIFICATION REGARDING NON-COLLUSION AND DEBARMENT

The undersigned further certifies under penalties of perjury that this subbid is in all responses bona fide, fair and made without collusion or fraud with any other person. As used in this subsection the “person” shall mean any natural person, joint venture, partnership, corporation or other business or legal entity. The undersigned further certifies that neither he/she nor any firm, corporation, partnership or association in which he/she has a substantial interest is designated as an ineligible contractor by the Comptroller General of the United States pursuant to Section 5.6 (b) of the Regulations of the Secretary of Labor, Part 5 (29 CFR, Part 5), or pursuant to Section 3 (a) of the Davis-Bacon Act, as amended (40 USC 276a). The undersigned further certifies that said undersigned is not presently debarred from doing public construction work in the State of Connecticut.

Date _____

Name of Sub-bidder

By _____

Signature

Print Name and Title

Business Name

Street Address, City and State

BID BOND

KNOW ALL MEN BY THESE PRESENTS, that we, the undersigned, _____ as Principal, and _____ Surety, are hereby held and firmly bound unto _____ as DOH in the penal sum of _____, for the payment of which, well and truly be made, we hereby jointly and severally bind ourselves, our heirs, executors, administrators, successors and assigns. Signed this _____ day of _____, 2016.

THE CONDITION OF THIS OBLIGATION IS SUCH, that whereas the Principal has submitted to _____ a certain Bid, attached hereto and hereby made a part hereof to enter into a contract in writing, for the _____

NOW, THEREFORE,

1. If said Bid shall be rejected, or in the alternate,
2. If said Bid shall be accepted and the Principal shall execute and deliver a contract in the Form of Contract attached hereto (properly completed in accordance with the Bid) and shall furnish a bond for this faithful performance of said contract, and for the payment of all person performing labor or furnishing materials in connection therewith, and shall in all other respects perform the agreement created by the acceptance of said Bid,

Then this obligation shall be void, otherwise the same shall remain in force and effect; it being expressly understood and agreed that the liability of the Surety for any or all claims hereunder shall, in no event, exceed the penal amount of this obligation as herein stated.

The Surety, for value received, hereby stipulates and agrees that the obligations of said Surety and its bond shall be in no way impaired or affected by any extension of the time which the DOH may accept such Bid; and said Surety does hereby waive notice of any such extension.

IN WITNESS WHEREOF, the Principal and Surety have hereunto set their hands and seals, and such of them as are corporations have caused their corporate seals to be hereto affixed and these presents to be signed by their proper officers, the day and year first set forth above.

Principal (L.S)

Surety

SEAL

By: _____

PERFORMANCE AND PAYMENT BOND

KNOW ALL MEN BY THESE PRESENTS: THAT we,

_____, as

PRINCIPAL, and _____, as SURETY,

are held firmly bound unto _____

_____ hereinafter called the DOH, in the penal

sum of _____

_____ (\$ _____), for the payment

of which sum we bind ourselves, our heirs, executors, administrators, and successors, jointly and severally.

WHEREAS, Principal has entered into a certain Contract with DOH, dated _____, a copy of which is hereto attached and made a part hereof.

NOW, THEREFORE, the condition of this obligation is such that if the Principal shall in all respects fully perform the Contract and all duly authorized modifications thereof, during its original term and any extensions thereof that may be granted and during any guaranty period for which the Contract provides, and if the Principal shall fully satisfy all claims arising out of the prosecution of the work under the Contract and shall fully indemnify DOH for all expenses which it may incur by reason of such claims, including its attorney's fees and court costs, and if the Principal shall make full payment to all persons supplying labor, services, materials, or equipment in the prosecution of the work under the Contract, in default of which such persons shall have a direct right of action hereupon; and if the Principal shall pay or cause to be paid all sales and use taxes payable as a result of the performance of the Contract as well as payment of gasoline and special motor fuel taxes in the performance of the Contract and all motor vehicle fees required for commercial motor vehicles used in connection with the performance of the Contract, then this obligation shall be void; otherwise, it shall remain in full force and effect. No modification of the Contract or extension of the term thereof, nor any forbearance on the part of DOH shall in any way release the Principal or the Surety from liability hereunder. Notice to the Surety of any such modification, extension, or forbearance is hereby waived.

IN WITNESS WHEREOF, the aforesaid Principal and Surety have executed this instrument and affixed their seals hereto, this _____ day of _____.

Principal

Surety

Name and Title

Name and Title

(Signatures must be notarized.)

(Power-of-Attorney for person signing for Surety Company must be attached to bond.)

The rate of premium on this bond is \$ _____ per thousand.

The total amount of premium charge is \$ _____.

(The above is to be filled in by Surety Company.)

CERTIFICATE AS TO CORPORATE PRINCIPAL

I, _____, certify that I am the

_____ Secretary of the corporation

named as Principal in the foregoing bond; that _____, who

signed the bond on behalf of the Principal, was then _____ of said

corporation; that I know his/her signature thereto is genuine; and that said bond was fully signed, sealed,

and attested for and in behalf of said corporation by authority of its governing body.

SUBCONTRACTOR IDENTIFICATION

(Provide additional forms for more subcontractors, as needed prior to execution.)

This form is a part of your bid package and must be submitted along with the itemized and formal bid forms at the time of the bid opening. Failure to submit a completed document could result in the disqualification of your bid.

Name of Subcontractor: _____

Address: _____

Trade: _____

Hourly Wage: \$ _____ Full Contract Price: \$ _____

Federal Tax# or SSN #: _____

Male Owned Business _____ Female Owned Business _____

Is he/she of Hispanic or Latino ethnicity? Yes _____ No _____

Race: (Please check one)

- | | |
|---|---|
| <input type="checkbox"/> White | <input type="checkbox"/> American Indian/Alaskan Native |
| <input type="checkbox"/> Black/African American | <input type="checkbox"/> Hasidic Jew |
| <input type="checkbox"/> Asian/Pacific American | |

Name of Subcontractor: _____

Address: _____

Trade: _____

Hourly Wage: \$ _____ Full Contract Price: \$ _____

Federal Tax# or SSN #: _____

Male Owned Business _____ Female Owned Business _____

Is he/she of Hispanic or Latino ethnicity? Yes _____ No _____

Race: (Please check one)

- | | |
|---|---|
| <input type="checkbox"/> White | <input type="checkbox"/> American Indian/Alaskan Native |
| <input type="checkbox"/> Black/African American | <input type="checkbox"/> Hasidic Jew |
| <input type="checkbox"/> Asian/Pacific American | |

Name of Subcontractor: _____

Address: _____

Trade: _____

Hourly Wage: \$ _____ Full Contract Price: \$ _____

Federal Tax# or SSN #: _____

Male Owned Business _____ Female Owned Business _____

Is he/she of Hispanic or Latino ethnicity? Yes _____ No _____

Race: (Please check one)

- | | |
|---|---|
| <input type="checkbox"/> White | <input type="checkbox"/> American Indian/Alaskan Native |
| <input type="checkbox"/> Black/African American | <input type="checkbox"/> Hasidic Jew |
| <input type="checkbox"/> Asian/Pacific American | |

Contractor's Signature

Date

U.S. DEPARTMENT OF HOUSING AND URBAN DEVELOPMENT
CERTIFICATION OF BIDDER REGARDING EQUAL EMPLOYMENT
OPPORTUNITY

INSTRUCTIONS

This certification is required pursuant to Executive Order 11246 (30 F R 12319-25). The implementing rules and regulations provide that any bidder or prospective contractor, or any of their proposed subcontractors shall state as an initial part of the bid or negotiations of the contract whether it has participated in any previous contract or subcontract subject to the equal opportunity clause; and, if so, whether it has filed all compliance reports due under applicable instructions.

Where the certification indicates that the bidder has not filed a compliance report due under applicable instructions, such bidder shall be required to submit a compliance report within seven calendar days after bid opening. No contract shall be awarded unless such report is submitted.

CERTIFICATION OF BIDDER

Name and address of Bidder (include zip code)

-
1. Bidder has participated in a previous contract or subcontract subject to the Equal Opportunity Clause.
 YES NO
 2. Compliance reports were required to be filed in connection with such contract or subcontract.
 YES NO
 3. Bidder has filed all compliance reports due under applicable instructions, including SF.100.
 YES NO NOT REQUIRED
 4. Have you ever seen or are you being considered for sanction due to violation of Executive Order 11246, as amended?
 YES NO

NAME AND TITLE OF SIGNER (Please type.)

SIGNATURE

DATE

CERTIFICATION OF BIDDERS REGARDING SECTION 3 AND SEGREGATED FACILITIES

Project Name:

Project No:

Name of Prime Contractor:

The undersigned hereby certifies that:

1. Section 3 provisions are included in the Contract
2. A written Section 3 plan was prepared and submitted as part of the bid proceedings (if bid equals or exceeds \$100,000.00)
3. No segregated facilities will be maintained.

Name and Title of Signer (Print or Type)

Signature

Date

CONTRACTOR

Section 3 Plan Format

_____ agrees to implement the following specific affirmative action steps directed at increasing the utilization of lower income residents and business within the

_____.

- A. To ascertain from the DOH the exact boundaries of the Section 3 covered project area and where advantageous, seek the assistance of local officials in preparing and implementing the affirmative action plans.
- B. To attempt to recruit from within the city the necessary number of lower income residents through: local advertising media, signs placed at the proposed site for the project, and community organizations and public or private institutions operating within or serving the project area such as Service Employment and Redevelopment (SER), Opportunities Industrialization Center (OIC), Urban League, Concentrated Employment Program, Hometown Plan, or the U. S. Employment Service.
- C. To maintain a list of all lower income residents who have applied either on their own or on referral from any source, and to employ such persons, if otherwise eligible and if a vacancy exists.
- D. To insert this Section 3 plan in all bid documents, and to require all bidders on subcontracts to submit a Section 3 Affirmative Action Plan including utilization goals and the specific steps planned to accomplish these goals.
- E. To insure that contracts which are typically let on a negotiated rather than a bid basis in areas other than Section 3 covered project areas, are also let on a negotiated basis, wherever feasible, when let in a Section 3 covered project area.
- F. To formally contact unions, subcontractors and trade associations to secure their cooperation for this program.
- G. To insure that all appropriated project area business concerns are notified or pending subcontractural opportunities
- H. To maintain records, including copies of correspondence, memoranda, etc., that document all above affirmative action steps have been taken.
- I. To appoint or recruit an executive official of the company or agency as Equal Opportunity Officer to coordinate the implementation of the Section 3 plan.
- J. To list on Table A, information related to subcontracts to be awarded.
- K. To list on Table B, all projected workforce needs for all phases of this project by occupation, trade, skill level and number of positions.

As officers and representatives of _____

We, the undersigned, have read and fully agree to this Affirmative Action Plan, and become a party to the full implementation of this program.

Signature

Title

Date

Loans, grants, contracts and subsidies for less than \$100,000.00 will be exempt.

Table B

Estimated Project Workforce Breakdown

<i>Column 1</i>	<i>Column 2</i>	<i>Column 3</i>	<i>Column 4</i>	<i>Column 5</i>
Job Category	Total Estimated Population	No. Positions Currently Occupied by Permanent Employees	No. Positions Not Currently Occupied	No. Positions to be filled with LIPAR*
Officers/Supervisors				
Professionals				
Technicians				
Housing Sales/Rental Management				
Office Clerical				
Service Workers				
Others				
TRADE:				
Journeyman				
Helpers				
Apprentices				
Maximum No. of Trainees				
Others				
TRADE:				
Journeyman				
Helpers				
Apprentices				
Maximum No. of Trainees				
Others				
TRADE:				
Journeyman				
Helpers				
Apprentices				
Maximum No. of Trainees				
Others				
Total				

**Lower Income Project Area Residents. Individuals residing within the project area whose family income does not exceed 80% of the area median income in the SMSA.*

Company

Green Building Standards Checklist

HUD CPD Green Building Retrofit Checklist

The CPD Green Retrofit Checklist promotes energy efficiency and green building practices for residential retrofit projects. Grantees must follow the checklist in its entirety and apply all measures within the Checklist to the extent applicable to the particular building type being retrofitted. The phrase “when replacing” in the Checklist refers to the mandatory replacement with specified green improvements, products, and fixtures only when replacing those systems during the normal course of the retrofit.

WATER AND ENERGY CONSERVATION MEASURES

- Water-Conserving Fixtures**
Install or retrofit water conserving fixtures in any unit and common facility, use the following specifications: Toilets-- 1.28 gpf; Urinals-- 0.5 gpf; Showerheads-- 2.0 gpm; Kitchen faucets-- 2.0 gpm; and Bathroom faucets-- 1.5gpm. [gpf = gallons per flush; gpm = gallons per minute]
- ENERGY STAR Appliances**
Install ENERGY STAR-labeled clothes washers, dishwashers, and refrigerators, if these appliance categories are provided in units or common areas.
- Air Sealing: Building Envelope**
Seal all accessible gaps and penetrations in the building envelope. If applicable, use low VOC caulk or foam.
- Insulation: Attic** (if applicable to building type)
For attics with closed floor cavities directly above the conditioned space, blow in insulation per manufacturer's specifications to a minimum density of 3.5 Lbs. per cubic foot (CF). For attics with open floor cavities directly above the conditioned space, install insulation to meet or exceed IECC levels.
- Insulation: Flooring** (if applicable to building type)
Install \geq R-19 insulation in contact with the subfloor in buildings with floor systems over vented crawl spaces. Install a 6-mil vapor barrier in contact with 100% of the floor of the crawl space (the ground), overlapping seams and piers at least 6 inches.
- Duct Sealing** (if applicable to building type)
In buildings with ducted forced-air heating and cooling systems, seal all penetrations of the air distribution system to reduce leakage in order to meet or exceed ENERGY STAR for Homes' duct leakage standard.
- Air Barrier System**
Ensure continuous unbroken air barrier surrounding all conditioned space and dwelling units. Align insulation completely and continuously with the air barrier.
- Radiant Barriers: Roofing**
When replacing or making a substantial repair to the roof, use radiant barrier sheathing or other radiant barrier material; if economically feasible, also use cool roofing materials.
- Windows**

When replacing windows, install geographically appropriate ENERGY STAR rated windows.



Sizing of Heating and Cooling Equipment

When replacing, size heating and cooling equipment in accordance with the Air Conditioning Contractors of America (ACCA) Manuals, Parts J and S, or 2012 ASHRAE Handbook--HVAC Systems and Equipment or most recent edition.



Domestic Hot Water Systems

When replacing domestic water heating system(s), ensure the system(s) meet or exceed the efficiency requirements of ENERGY STAR for Homes' Reference Design. Insulate pipes by at least R-4.



Efficient Lighting: Interior Units

Follow the guidance appropriate for the project type: install the ENERGY STAR Advanced Lighting Package (ALP); **OR** follow the ENERGY STAR MFHR program guidelines, which require that 80% of installed lighting fixtures within units must be ENERGY STAR-qualified or have ENERGY STAR-qualified lamps installed; **OR** when replacing, new fixtures and ceiling fans must meet or exceed ENERGY STAR efficiency levels.



Efficient Lighting: Common Areas and Emergency Lighting (if applicable to building type)

Follow the guidance appropriate for the project type: use ENERGY STAR-labeled fixtures or any equivalent high-performance lighting fixtures and bulbs in all common areas; **OR** when replacing, new common space and emergency lighting fixtures must meet or exceed ENERGY STAR efficiency levels. For emergency lighting, if installing new or replacing, all exist signs shall meet or exceed LED efficiency levels and conform to local building codes.



Efficient Lighting: Exterior

Follow the guidance appropriate for the project type: install ENERGY STAR-qualified fixtures or LEDs with a minimum efficacy of 45 lumens/watt; **OR** follow the ENERGY STAR MFHR program guidelines, which require that 80% of outdoor lighting fixtures must be ENERGY STAR-qualified or have ENERGY STAR-qualified lamps installed; **OR** when replacing, install ENERGY STAR compact fluorescents or LEDs with a minimum efficacy of 45 lumens/watt.

INDOOR AIR QUALITY



Air Ventilation: Single Family and Multifamily (three stories or fewer)

Install an in-unit ventilation system capable of providing adequate fresh air per ASHRAE 62.2 requirements.



Air Ventilation: Multifamily (four stories or more)

Install apartment ventilation systems that satisfy ASHRAE 62.2 for all dwelling units and common area ventilation systems that satisfy ASHRAE 62.1 requirements. If economically feasible, consider heat/energy recovery for 100% of corridor air supply.



Composite Wood Products that Emit Low/No Formaldehyde

Composite wood products must be certified compliant with California 93120. If using a composite wood product that does not comply with California 93120, all exposed edges and sides must be sealed with low-VOC sealants.

- Environmentally Preferable Flooring**
When replacing flooring, use environmentally preferable flooring, including the FloorScore certification. Any carpet products used must meet the Carpet and Rug Institute's Green Label or Green Label Plus certification for carpet, pad, and carpet adhesives.
- Low/No VOC Paints and Primers**
All interior paints and primers must be less than or equal to the following VOC levels: Flats--50 g/L; Non-flats--50 g/L; Floor--100 g/L. [g/L = grams per liter; levels are based on a combination of the Master Painters Institute (MPI) and GreenSeal standards.]
- Low/No VOC Adhesives and Sealants**
All adhesives must comply with Rule 1168 of the South Coast Air Quality Management District. All caulks and sealants must comply with regulation 8, rule 51, of the Bay Area Air Quality Management District.
- Clothes Dryer Exhaust**
Vent clothes dryers directly to the outdoors using rigid-type duct work.
- Mold Inspection and Remediation**
Inspect the interior and exterior of the building for evidence of moisture problems. Document the extent and location of the problems, and implement the proposed repairs according to the Moisture section of the EPA Healthy Indoor Environment Protocols for Home Energy Upgrades.
- Combustion Equipment**
When installing new space and water-heating equipment, specify power-vented or direct vent combustion equipment.
- Mold Prevention: Water Heaters**
Provide adequate drainage for water heaters that includes drains or catch pans with drains piped to the exterior of the dwelling.
- Mold Prevention: Surfaces**
When replacing or repairing bathrooms, kitchens, and laundry rooms, use materials that have durable, cleanable surfaces.
- Mold Prevention: Tub and Shower Enclosures**
When replacing or repairing tub and/or shower enclosures, use non-paper-faced backing materials such as cement board, fiber cement board, or equivalent in bathrooms.
- Integrated Pest Management**
Seal all wall, floor, and joint penetrations with low-VOC caulking or other appropriate sealing methods to prevent pest entry. [If applicable, provide training to multifamily buildings staff.]
- Lead-Safe Work Practices**
For properties built before 1978, if the project will involve disturbing painted surfaces or cleaning up lead contaminated dust or soil, use certified renovation or lead abatement contractors and workers using lead-safe work practices and clearance examinations consistent with the more stringent of EPA's Renovation, Repair, and Painting Rule and HUD's Lead Safe Housing Rule.
- Radon Testing and Mitigation** (if applicable based on building location)

For buildings in EPA Radon Zone 1 or 2, test for radon using the current edition of American Association of Radon Scientists and Technologists (AARST)'s Protocols for Radon Measurement in Homes Standard for Single-Family Housing or Duplexes, or AARST's Protocol for Conducting Radon and Radon Decay Product Measurements in Multifamily Buildings. To install radon mitigation systems in buildings with radon level of 4 pCi/L or more, use ASTM E 2121 for single-family housing or duplexes, or AARST's Radon Mitigation Standards for Multifamily Buildings. For new construction, use AARST's Reducing Radon in New Construction of 1 & 2 Family Dwellings and Townhouses, or ASTM E 1465.

Section 2: General Conditions for Construction Contracts

Based on HUD form 5370

Applicability. This form is applicable to any construction/development contract greater than \$100,000.

This form includes those clauses required by OMB's common rule on grantee procurement, implemented at HUD in 24 CFR 85.36, and those requirements set forth in Section 3 of the Housing and Urban Development Act of 1968 and its amendment by the Housing and Community Development Act of 1992, implemented by HUD at 24 CFR Part 135.

		Table of Contents			
Clause		Page	Clause		Page
1.	Definitions	2		Administrative Requirements	
2.	Contractor's Responsibility for Work	2	24.	Contract Period	9
3.	Architect's Duties, Responsibilities and Authority	3	25.	Order of Precedence	9
4.	Other Contracts	3	26.	Payments	9
	Construction Requirements		27.	Contract Modifications	1
5.	Preconstruction Conference and Notice to	3	28.	Changes	10
6.	Site Investigation and Conditions Affecting the	3	29.	Suspension of Work	1
7.	Differing Site Conditions	3	30.	Disputes	11
8.	Specifications and Drawings for Construction	4	31.	Default	11
9.	Material and Workmanship	4	32.	Liquidated Damages	12
10.	Permits and Codes	5	33.	Termination of Convenience	1
11.	Health, Safety, and Accident Prevention	5	34.	Assignment of Contract	1
12.	Temporary Buildings and Transportation	6	35.	Insurance	13
13.	Availability and Use of Utility Services	6	36.	Subcontracts	12
14.	Protection of Existing Vegetation, Structures, Equipment, Utilities, and Improvements	6	37.	Subcontracting with Small and Minority	1
15.	Temporary Buildings and Transportation	6	38.	Equal Employment Opportunity	13
16.	Clean Air and Water	7	39.	Employment, Training, and Contracting Opportunities for Low-Income Persons,	4
17.	Energy Efficiency	7	40.	Interest of Members of Congress	1
18.	Green Building Standards	7	41.	Interest of Members, Officers, or Employees	4
19.	Inspection and Acceptance of Construction	7	42.	Limitations on Payments Made to Influence	1
20.	Use and Possession Prior to Completion	8	44.	Royalties and Patents	15
21.	Warranty of Title	8	44.	Examination and Retention of Contractor's	1
22.	Warranty of Construction	8	45.	Labor Standards-Davis-Bacon and Related	15
23.	Prohibition Against Liens	8	46.	Non-Federal Prevailing Wage Rates	1
.			47.	Procurement of Recovered Materials	18

1. Definitions

- (a) "Architect" means the person or other entity engaged by DOH to perform architectural, engineering, design, and other services related to the work as provided for in the contract. When DOH uses an engineer to act in this capacity, the terms "architect" and "engineer" shall be synonymous. The Architect shall serve as a technical representative of the Contracting Officer. The Architect's authority is as set forth elsewhere in this contract.
- (b) "Contract" means the contract entered into between DOH and the Contractor. It includes the forms of Bid, the Bid Bond, the Performance and Payment Bond or Bonds or other assurance of completion, the Certifications, Representations, and Other Statements of Bidders (form HUD-5370), these General Conditions of the Contract for Construction (form HUD-5370), the applicable wage rate determinations from the U.S. Department of Labor (when applicable), any special conditions included elsewhere in the contract, the specifications, and drawings. It includes all formal changes to any of those documents by addendum, change order, or other modification.
- (c) "Contracting Officer" means the person delegated the authority by DOH to enter into, administer, and/or terminate this contract and designated as such in writing to the Contractor. The term includes any successor Contracting Officer and any duly authorized representative of the Contracting Officer also designated in writing. The Contracting Officer shall be deemed the authorized agent of DOH in all dealings with the Contractor.
- (d) "Contractor" means the person or other entity entering into the contract with DOH to perform all of the work required under the contract.
- (e) "Drawings" means the drawings enumerated in the schedule of drawings contained in the Specifications and as described in the contract clause entitled Specifications and Drawings for Construction herein.
- (f) "DOH" means the State Department of Housing including the Commissioner, or any other person designated to act on its behalf.
- (g) "HUD" means the United States of America acting through the Department of Housing and

Urban Development including the Secretary, or any other person designated to act on its behalf. HUD has agreed, subject to the provisions of an Annual Contributions Contract (ACC), to provide financial assistance to DOH, which includes assistance in financing the work to be performed under this contract. As defined elsewhere in these General Conditions or the contract documents, the determination of HUD may be required to authorize changes in the work or for release of funds to DOH for payment to the Contractor. Notwithstanding HUD's role, nothing in this contract shall be construed to create any contractual relationship between the Contractor and HUD.

- (h) "Grantee" means the State of Connecticut Department of Housing (DOH).
- (i) "Homeowner" means the owner(s) of the real property for which project is taking place and is a party to the contract.
- (j) "Project" means the entire project, whether construction or rehabilitation, the work for which is provided for in whole or in part under this contract.
- (k) "Specifications" means the written description of the technical requirements for construction and includes the criteria and tests for determining whether the requirements are met.
- (l) "Work" means materials, workmanship, and manufacture and fabrication of components.

2. Contractor's Responsibility for Work

- (a) The Contractor shall furnish all necessary labor, materials, tools, equipment, and transportation necessary for performance of the work. The Contractor shall also furnish all necessary water, heat, light, and power not made available to the Contractor by the Homeowner pursuant to the clause entitled Access to the Premises Section 5.3 of Homeowner Rehabilitation Agreement herein.
- (b) The Contractor shall perform on the site, and with its own organization, work equivalent to at least 15 percent of the total amount of work to be performed under the order. This percentage may be reduced by a supplemental agreement to this order if, during performing the work, the Contractor requests a reduction and the Contracting Officer determines that the reduction would be to the advantage of DOH.

- (c) At all times during performance of this contract and until the work is completed and accepted, the Contractor shall directly superintend the work or assign and have on the work site a competent superintendent who is satisfactory to the Contracting Officer and has authority to act for the Contractor.
- (d) The Contractor shall be responsible for all damages to persons or property that occur as a result of the Contractor's fault or negligence, and shall take proper safety and health precautions to protect the work, the workers, the public, and the property of others. The Contractor shall hold and save DOH, its officers and agents, free and harmless from liability of any nature occasioned by the Contractor's performance. The Contractor shall also be responsible for all materials delivered and work performed until completion and acceptance of the entire work, except for any completed unit of work which may have been accepted under the contract.
- (e) The Contractor shall lay out the work from base lines and bench marks indicated on the drawings and be responsible for all lines, levels, and measurements of all work executed under the contract. The Contractor shall verify the figures before laying out the work and will be held responsible for any error resulting from its failure to do so.
- (f) The Contractor shall confine all operations (including storage of materials) on Homeowner premises to areas authorized or approved by the Contracting Officer.
- (g) The Contractor shall at all times keep the work area, including storage areas, free from accumulations of waste materials. After completing the work and before final inspection, the Contractor shall (1) remove from the premises all scaffolding, equipment, tools, and materials (including rejected materials) that are not the property of the Homeowner and all rubbish caused by its work; (2) leave the work area in a clean, neat, and orderly condition satisfactory to the Contracting Officer; (3) perform all specified tests; and, (4) deliver the installation in complete and operating condition.
- (h) The Contractor's responsibility will terminate when all work has been completed, the final inspection made, and the work accepted by the Contracting Officer. The Contractor will then be released from further obligation except as

required by the warranties specified elsewhere in the contract.

3. Architect's Duties, Responsibilities, and Authority

- (a) The Architect for this contract, and any successor, shall be designated in writing by the Contracting Officer.
- (b) The Architect shall serve as the Contracting Officer's technical representative with respect to architectural, engineering, and design matters related to the work performed under the contract. The Architect may provide direction on contract performance. Such direction shall be within the scope of the contract and may not be of a nature which: (1) institutes additional work outside the scope of the contract; (2) constitutes a change as defined in the Changes clause herein; (3) causes an increase or decrease in the cost of the contract; (4) alters the Construction Progress Schedule; or (5) changes any of the other express terms or conditions of the contract.
- (c) The Architect's duties and responsibilities may include but shall not be limited to:
 - (1) Making periodic visits to the work site, and on the basis of his/her on-site inspections, issuing written reports to DOH which shall include all observed deficiencies. The Architect shall file a copy of the report with the Contractor's designated representative at the site;
 - (2) Making modifications in drawings and technical specifications and assisting the Contracting Officer in the preparation of change orders and other contract modifications for issuance by the Contracting Officer;
 - (3) Reviewing and making recommendations with respect to - (i) the Contractor's construction progress schedules; (ii) the Contractor's shop and detailed drawings; (iii) the machinery, mechanical and other equipment and materials or other articles proposed for use by the Contractor; and, (iv) the Contractor's price breakdown and progress payment estimates; and,
 - (4) Assisting in inspections, signing Certificates of Completion, and making recommendations with respect to acceptance of work completed under the contract.

4. Other Contracts

DOH may undertake or award other contracts for additional work at or near the site of the work under this contract. The Contractor shall fully

cooperate with the other contractors and with DOH employees and shall carefully adapt scheduling and performing the work under this contract to accommodate the additional work, heeding any direction that may be provided by the Contracting Officer. The Contractor shall not commit or permit any act that will interfere with the performance of work by any other contractor or by DOH employees

Construction Requirements

5. Pre-construction Conference and Notice to Proceed

- (a) Upon scheduling of the contract execution, and prior to the commencement of work, the Contractor shall attend a preconstruction conference with representatives of DOH, its Architect, and other interested parties convened by DOH. The conference will serve to acquaint the participants with the general plan of the construction operation and all other requirements of the contract. DOH or its Architect will provide the Contractor with the date, time, and place of the conference.
- (b) The contractor shall begin work upon receipt of a written Notice to Proceed from the Contracting Officer or designee. The Contractor shall not begin work prior to receiving such notice. Such notice shall not be prior to the homeowners three (3) day Notice of Cancellation period.

6. Site Investigation and Conditions Affecting the Work

- (a) The Contractor acknowledges that it has taken steps reasonably necessary to ascertain the nature and location of the work, and that it has investigated and satisfied itself as to the general and local conditions which can affect the work or its cost, including but not limited to, (1) conditions bearing upon transportation, disposal, handling, and storage of materials; (2) the availability of labor, water, electric power, and roads; (3) uncertainties of weather, river stages, tides, or similar physical conditions at the site; (4) the conformation and conditions of the ground; and (5) the character of equipment and facilities needed preliminary to and during work performance. The Contractor also acknowledges that it has satisfied itself as to the character, quality, and quantity of surface and subsurface materials or obstacles to be

encountered insofar as this information is reasonably ascertainable from an inspection of the site, including all exploratory work done by DOH, as well as from the drawings and specifications made a part of this contract. Any failure of the Contractor to take the actions described and acknowledged in this paragraph will not relieve the Contractor from responsibility for estimating properly the difficulty and cost of successfully performing the work, or for proceeding to successfully perform the work without additional expense to DOH.

- (b) DOH assumes no responsibility for any conclusions or interpretations made by the Contractor based on the information made available by DOH. Nor does DOH assume responsibility for any understanding reached or representation made concerning conditions which can affect the work by any of its officers or agents before the execution of this contract, unless that understanding or representation is expressly stated in the contract.

7. Differing Site Conditions

- (a) The Contractor shall promptly, and before the conditions are disturbed, give a written notice to the Contracting Officer of (1) subsurface or latent physical conditions at the site which differ materially from those indicated in this contract, or (2) unknown physical conditions at the site(s), of an unusual nature, which differ materially from those ordinarily encountered and generally recognized as inhering in work of the character provided for in the contract.
- (b) The Contracting Officer shall investigate the site conditions promptly after receiving the notice. Work shall not proceed at the affected site, except at the Contractor's risk, until the Contracting Officer has provided written instructions to the Contractor. If the conditions do materially so differ and cause an increase or decrease in the Contractor's cost of, or the time required for, performing any part of the work under this contract, whether or not changed as a result of the conditions, the Contractor shall file a claim in writing to DOH within ten days after receipt of such instructions and, in any event, before proceeding with the work. An equitable adjustment in the contract price, the delivery schedule, or both shall be made under this clause and the contract modified in writing accordingly.
- (c) No request by the Contractor for an equitable adjustment to the contract under this clause shall be allowed, unless the Contractor has given the

written notice required; provided, that the time prescribed in (a) above for giving written notice may be extended by the Contracting Officer.

- (d) No request by the Contractor for an equitable adjustment to the contract for differing site conditions shall be allowed if made after final payment under this contract.

8. Specifications and Drawings for Construction

- (a) The Contractor shall keep on the work site a copy of the drawings and specifications and shall at all times give the Contracting Officer access thereto. Anything mentioned in the specifications and not shown on the drawings, or shown on the drawings and not mentioned in the specifications, shall be of like effect as if shown or mentioned in both. In case of difference between drawings and specifications, the specifications shall govern. In case of discrepancy in the figures, in the drawings, or in the specifications, the matter shall be promptly submitted to the Contracting Officer, who shall promptly make a determination in writing. Any adjustment by the Contractor without such a determination shall be at its own risk and expense. The Contracting Officer shall furnish from time to time such detailed drawings and other information as considered necessary, unless otherwise provided.
- (b) Wherever in the specifications or upon the drawings the words “directed”, “required”, “ordered”, “designated”, “prescribed”, or words of like import are used, it shall be understood that the “direction”, “requirement”, “order”, “designation”, or “prescription”, of the Contracting Officer is intended and similarly the words “approved”, “acceptable”, “satisfactory”, or words of like import shall mean “approved by”, or “acceptable to”, or “satisfactory to” the Contracting Officer, unless otherwise expressly stated.
- (c) Where “as shown”, “as indicated”, “as detailed”, or words of similar import are used, it shall be understood that the reference is made to the drawings accompanying this contract unless stated otherwise. The word “provided” as used herein shall be understood to mean “provide complete in place” that is “furnished and installed”.
- (d) “Shop drawings” means drawings, submitted to DOH by the Contractor, subcontractor, or any

lower tier subcontractor, showing in detail (1) the proposed fabrication and assembly of structural elements and (2) the installation (i.e., form, fit, and attachment details) of materials of equipment. It includes drawings, diagrams, layouts, schematics, descriptive literature, illustrations, schedules, performance and test data, and similar materials furnished by the Contractor to explain in detail specific portions of the work required by the contract. DOH may duplicate, use, and disclose in any manner and for any purpose shop drawings delivered under this contract.

- (e) If this contract requires shop drawings, the Contractor shall coordinate all such drawings, and review them for accuracy, completeness, and compliance with other contract requirements and shall indicate its approval thereon as evidence of such coordination and review. Shop drawings submitted to the Contracting Officer without evidence of the Contractor's approval may be returned for resubmission. The Contracting Officer will indicate an approval or disapproval of the shop drawings and if not approved as submitted shall indicate DOH's reasons therefore. Any work done before such approval shall be at the Contractor's risk. Approval by the Contracting Officer shall not relieve the Contractor from responsibility for any errors or omissions in such drawings, nor from responsibility for complying with the requirements of this contract, except with respect to variations described and approved in accordance with (f) below.
- (f) If shop drawings show variations from the contract requirements, the Contractor shall describe such variations in writing, separate from the drawings, at the time of submission. If the Architect approves any such variation and the Contracting Officer concurs, the Contracting Officer shall issue an appropriate modification to the contract, except that, if the variation is minor or does not involve a change in price or in time of performance, a modification need not be issued.
- (g) It shall be the responsibility of the Contractor to make timely requests of DOH for such large scale and full size drawings, color schemes, and other additional information, not already in his possession, which shall be required in the planning and production of the work. Such requests may be submitted as the need arises, but each such request shall be filed in ample time to permit appropriate action to be taken by all parties involved so as to avoid delay.
- (h) The Contractor shall submit to the Contracting Officer for approval four copies (unless otherwise indicated) of all shop drawings as called for under the various headings of these specifications. Three sets (unless otherwise indicated) of all shop drawings, will be retained by DOH and one set will be returned to the Contractor. As required by the Contracting Officer, the Contractor, upon completing the work under this contract, shall furnish a

complete set of all shop drawings as finally approved. These drawings shall show all changes and revisions made up to the time the work is completed and accepted.

- (i) This clause shall be included in all subcontracts at any tier. It shall be the responsibility of the Contractor to ensure that all shop drawings prepared by subcontractors are submitted to the Contracting Officer.

9. Material and Workmanship

- (a) All equipment, material, and articles furnished under this contract shall be new and of the most suitable grade for the purpose intended, unless otherwise specifically provided in this contract. References in the contract to equipment, material, articles, or patented processes by trade name, make, or catalog number, shall be regarded as establishing a standard of quality and shall not be construed as limiting competition. The Contractor may, at its option, use any equipment, material, article, or process that, in the judgment of, and as approved by the Contracting Officer, is equal to that named in the specifications, unless otherwise specifically provided in this contract.
- (b) Approval of equipment and materials.
 - (1) The Contractor shall obtain the Contracting Officer's approval of the machinery and mechanical and other equipment to be incorporated into the work. When requesting approval, the Contractor shall furnish to the Contracting Officer the name of the manufacturer, the model number, and other information concerning the performance, capacity, nature, and rating of the machinery and mechanical and other equipment. When required by this contract or by the Contracting Officer, the Contractor shall also obtain the Contracting Officer's approval of the material or articles which the Contractor contemplates incorporating into the work. When requesting approval, the Contractor shall provide full information concerning the material or articles. Machinery, equipment, material, and articles that do not have the required approval shall be installed or used at the risk of subsequent rejection.
 - (2) When required by the specifications or the Contracting Officer, the Contractor shall submit appropriately marked samples (and

certificates related to them) for approval at the Contractor's expense, with all shipping charges prepaid. The Contractor shall label, or otherwise properly mark on the container, the material or product represented, its place of origin, the name of the producer, the Contractor's name, and the identification of the construction project for which the material or product is intended to be used.

- (3) Certificates shall be submitted in triplicate, describing each sample submitted for approval and certifying that the material, equipment or accessory complies with contract requirements. The certificates shall include the name and brand of the product, name of manufacturer, and the location where produced.
 - (4) Approval of a sample shall not constitute a waiver of DOH right to demand full compliance with contract requirements. Materials, equipment and accessories may be rejected for cause even though samples have been approved.
 - (5) Wherever materials are required to comply with recognized standards or specifications, such specifications shall be accepted as establishing the technical qualities and testing methods, but shall not govern the number of tests required to be made nor modify other contract requirements. The Contracting Officer may require laboratory test reports on items submitted for approval or may approve materials on the basis of data submitted in certificates with samples. Check tests will be made on materials delivered for use only as frequently as the Contracting Officer determines necessary to insure compliance of materials with the specifications. The Contractor will assume all costs of retesting materials which fail to meet contract requirements and/or testing materials offered in substitution for those found deficient.
 - (6) After approval, samples will be kept in the Project office until completion of work. They may be built into the work after a substantial quantity of the materials they represent has been built in and accepted.
- (c) Requirements concerning lead-based paint. The Contractor shall comply with the requirements concerning lead-based paint contained in the Lead-Based Paint Poisoning Prevention Act

(42 U.S.C. 4821-4846) as implemented by 24 CFR Part 35, HUD's Lead Safe Housing Rule and EPA's Repair Renovation, and Painting Rule at 40 CFR.80 Subpart E.

10. Permits and Codes

The Contractor shall give all notices and comply with all applicable laws, ordinances, codes, rules and regulations. Notwithstanding the requirement of the Contractor to comply with the drawings and specifications in the contract, all work installed shall comply with all applicable codes and regulations as amended by any waivers. Before installing the work, the Contractor shall examine the drawings and the specifications for compliance with applicable codes and regulations bearing on the work and shall immediately report any discrepancy it may discover to the Contracting Officer. Where the requirements of the drawings and specifications fail to comply with the applicable code or regulation, the Contracting Officer shall modify the contract by change order pursuant to the clause entitled Changes herein to conform to the code or regulation.

- (a) The Contractor shall secure and pay for all permits, fees, and licenses necessary for the proper execution and completion of the work. Where DOH can arrange for the issuance of all or part of these permits, fees and licenses, without cost to the Contractor, the contract amount shall be reduced accordingly.

11. Health, Safety, and Accident Prevention

- (a) In performing this contract, the Contractor shall:
 - (1) Ensure that no laborer or mechanic shall be required to work in surroundings or under working conditions which are unsanitary, hazardous, or dangerous to his/her health and/or safety as determined under construction safety and health standards promulgated by the Secretary of Labor by regulation;
 - (2) Protect the lives, health, and safety of other persons;
 - (3) Prevent damage to property, materials, supplies, and equipment; and,
 - (4) Avoid work interruptions.
- (b) For these purposes, the Contractor shall:
 - (1) Comply with regulations and standards issued by the Secretary of Labor at 29 CFR Part 1926. Failure to comply may result in imposition of

sanctions pursuant to the Contract Work Hours and Safety Standards Act (Public Law 91-54, 83 Stat. 96), 40 U.S.C. 3701 et seq.; and

- (2) Include the terms of this clause in every subcontract so that such terms will be binding on each subcontractor.
- (c) The Contractor shall maintain an accurate record of exposure data on all accidents incident to work performed under this contract resulting in death, traumatic injury, occupational disease, or damage to property, materials, supplies, or equipment, and shall report this data in the manner prescribed by 29 CFR Part 1904.

- (d) The Contracting Officer shall notify the Contractor of any noncompliance with these requirements and of the corrective action required. This notice, when delivered to the Contractor or the Contractor's representative at the site of the work, shall be deemed sufficient notice of the noncompliance and corrective action required. After receiving the notice, the Contractor shall immediately take corrective action. If the Contractor fails or refuses to take corrective action promptly, the Contracting Officer may issue an order stopping all or part of the work until satisfactory corrective action has been taken. The Contractor shall not base any claim or request for equitable adjustment for additional time or money on any stop order issued under these circumstances.
- (e) The Contractor shall be responsible for its subcontractors' compliance with the provisions of this clause. The Contractor shall take such action with respect to any subcontract as DOH, the Secretary of Housing and Urban Development, or the Secretary of Labor shall direct as a means of enforcing such provisions.

12. Temporary Heating

The Contractor shall provide and pay for temporary heating, covering, and enclosures necessary to properly protect all work and materials against damage by dampness and cold, to dry out the work, and to facilitate the completion of the work. Any permanent heating equipment used shall be turned over to the Homeowner in the condition and at the time required by the specifications.

13. Availability and Use of Utility Services

- (a) The Homeowner shall make all reasonably required amounts of utilities available to the Contractor from existing outlets and supplies, as specified in the contract. The Contractor shall carefully conserve any utilities furnished without charge.
- (b) The Contractor, at its expense and in a manner satisfactory to the Contracting Officer, shall install and maintain all necessary temporary connections and distribution lines. Before final acceptance of the work by DOH, the Contractor

shall remove all the temporary connections, distribution lines, meters, and associated paraphernalia.

14. Protection of Existing Vegetation, Structures, Equipment, Utilities, and Improvements

- (a) The Contractor shall preserve and protect all structures, equipment, and vegetation (such as trees, shrubs, and grass) on or adjacent to the work site, which are not to be removed under this contract, and which do not unreasonably interfere with the work required under this contract.
- (b) The Contractor shall only remove trees when specifically authorized to do so, and shall avoid damaging vegetation that will remain in place. If any limbs or branches of trees are broken during performance of this contract, or by the careless operation of equipment, or by workmen, the Contractor shall trim those limbs or branches with a clean cut and paint the cut with a tree-pruning compound as directed by the Contracting Officer.
- (c) The Contractor shall protect from damage all existing improvements and utilities (1) at or near the work site and (2) on adjacent property of a third party, the locations of which are made known to or should be known by the Contractor. Prior to disturbing the ground at the construction site, the Contractor shall ensure that all underground utility lines are clearly marked.
- (d) The Contractor shall shore up, brace, underpin, secure, and protect as necessary all foundations and other parts of existing structures adjacent to, adjoining, and in the vicinity of the site, which may be affected by the excavations or other operations connected with the construction of the project.
- (e) Any equipment temporarily removed as a result of work under this contract shall be protected, cleaned, and replaced in the same condition as at the time of award of this contract.
- (f) New work which connects to existing work shall correspond in all respects with that to which it connects and/or be similar to existing work unless otherwise required by the specifications.
- (g) No structural members shall be altered or in any

way weakened without the written authorization of the Contracting Officer, unless such work is clearly specified in the plans or specifications.

- (h) If the removal of the existing work exposes discolored or unfinished surfaces, or work out of alignment, such surfaces shall be refinished, or the material replaced as necessary to make the continuous work uniform and harmonious. This, however, shall not be construed to require the refinishing or reconstruction of dissimilar finishes previously exposed, or finished surfaces in good condition, but in different planes or on different levels when brought together by the removal of intervening work, unless such refinishing or reconstruction is specified in the plans or specifications.
- (i) The Contractor shall give all required notices to any adjoining or adjacent property owner or other party before the commencement of any work.
- (j) The Contractor shall indemnify and save harmless DOH from any damages on account of settlement or the loss of lateral support of adjoining property, any damages from changes in topography affecting drainage, and from all loss or expense and all damages for which DOH may become liable in consequence of such injury or damage to adjoining and adjacent structures and their premises.
- (k) The Contractor shall repair any damage to vegetation, structures, equipment, utilities, or improvements, including those that are the property of a third party, resulting from failure to comply with the requirements of this contract or failure to exercise reasonable care in performing the work. If the Contractor fails or refuses to repair the damage promptly, the Contracting Officer may have the necessary work performed and charge the cost to the Contractor.

15. Temporary Buildings and Transportation of Materials

- (a) Temporary buildings (e.g., storage sheds, shops, offices, sanitary facilities) and utilities may be erected by the Contractor only with the approval of the Contracting Officer and shall be built with labor and materials furnished by the Contractor without expense to DOH. The temporary buildings and utilities shall remain the property of the Contractor and shall be removed by the Contractor at its expense upon completion of the work. With the written consent of the Contracting

Officer, the buildings and utilities may be abandoned and need not be removed.

- (b) The Contractor shall, as directed by the Contracting Officer, use only established roadways, or use temporary roadways constructed by the Contractor when and as authorized by the Contracting Officer. When materials are transported in prosecuting the work, vehicles shall not be loaded beyond the loading capacity recommended by the manufacturer of the vehicle or prescribed by any federal, state, or local law or regulation. When it is necessary to cross curbs or sidewalks, the Contractor shall protect them from damage. The Contractor shall repair or pay for the repair of any damaged curbs, sidewalks, or roads.

16. Clean Air and Water

The contractor shall comply with the Clean Air Act, as amended, 42 USC 7401 et seq., the Federal Water Pollution Control Water Act, as amended, 33 U.S.C. 1251 et seq., and standards issued pursuant thereto in the facilities in which this contract is to be performed.

17. Energy Efficiency

The Contractor shall comply with mandatory standards and policies relating to energy efficiency which are contained in the energy conservation plan issued in compliance with the Energy Policy and Conservation Act (Pub.L. 94-163) for the State in which the work under the contract is performed.

18. Green Building Standards

DOH will require that all replacement of residential properties, including reconstruction and new construction of substantially damaged properties meet the Enterprise Green Communities Standard.

For those buildings that are non-substantially damaged, DOH will require that they be rehabilitated following the HUD CPD Green Buildings Retrofit Checklist. The requirement for rehabilitation is that to the extent possible strive to meet the checklist standard where there are Energy Star, Water Sense and Federal Management Program-designed products available.

DOH strongly encourages the use of green infrastructure techniques to mitigate against storm water run-off and flooding and incorporate EPA's Green Infrastructure resources to the extent feasible.

19. Inspection and Acceptance of Construction

- (a) Definitions. As used in this clause -
 - (1) "Acceptance" means the act of an authorized representative of DOH by which DOH approves of the work performed under this contract. Acceptance may be partial or complete.

"Inspection" means examining and testing the work performed under the contract (including, when appropriate, raw materials, equipment, components, and intermediate assemblies) to determine whether it conforms to contract requirements.

- (1) "Testing" means that element of inspection that determines the properties or elements, including functional operation of materials, equipment, or their components, by the application of established scientific principles and procedures.
- (b) The Contractor shall maintain an adequate inspection system and perform such inspections as will ensure that the work performed under the contract conforms to contract requirements. All work is subject to DOH inspection and test at all places and at all reasonable times before acceptance to ensure strict compliance with the terms of the contract.
- (c) DOH inspections and tests are for the sole benefit of DOH and do not: (1) relieve the Contractor of responsibility for providing adequate quality control measures; (2) relieve the Contractor of responsibility for loss or damage of the material before acceptance; (3) constitute or imply acceptance; or, (4) affect the continuing rights of DOH after acceptance of the completed work under paragraph (j) below.
- (d) The presence or absence of DOH inspector does not relieve the Contractor from any contract requirement, nor is the inspector authorized to change any term or condition of the specifications without the Contracting Officer's written authorization. All instructions and approvals with respect to the work shall be given to the Contractor by the Contracting Officer.

- (e) The Contractor shall promptly furnish, without additional charge, all facilities, labor, and material reasonably needed for performing such safe and convenient inspections and tests as may be required by the Contracting Officer. DOH may charge to the Contractor any additional cost of inspection or test when work is not ready at the time specified by the Contractor for inspection or test, or when prior rejection makes reinspection or retest necessary. DOH shall perform all inspections and tests in a manner that will not unnecessarily delay the work. Special, full size, and performance tests shall be performed as described in the contract.
- (f) DOH may conduct routine inspections of the construction site on a daily basis.
- (g) The Contractor shall, without charge, replace or correct work found by DOH not to conform to contract requirements, unless DOH decides that it is in its interest to accept the work with an appropriate adjustment in contract price. The Contractor shall promptly segregate and remove rejected material from the premises.
- (h) If the Contractor does not promptly replace or correct rejected work, DOH may (1) by contract or otherwise, replace or correct the work and charge the cost to the Contractor, or (2) terminate for default the Contractor's right to proceed.
- (i) If any work requiring inspection is covered up without approval of DOH, it must, if requested by the Contracting Officer, be uncovered at the expense of the Contractor. If at any time before final acceptance of the entire work, DOH considers it necessary or advisable, to examine work already completed by removing or tearing it out, the Contractor, shall on request, promptly furnish all necessary facilities, labor, and material. If such work is found to be defective or nonconforming in any material respect due to the fault of the Contractor or its

subcontractors, the Contractor shall defray all the expenses of the examination and of satisfactory reconstruction. If, however, such work is found to meet the requirements of the contract, the Contracting Officer shall make an equitable adjustment to cover the cost of the examination and reconstruction, including, if completion of the work was thereby delayed, an extension of time.

- (j) The Contractor shall notify the Contracting Officer, in writing, as to the date when in its opinion all or a designated portion of the work will be substantially completed and ready for inspection. If the Architect determines that the state of preparedness is as represented, DOH will promptly arrange for the inspection. Unless otherwise specified in the contract, DOH shall accept, as soon as practicable after completion and inspection, all work required by the contract or that portion of the work the Contracting Officer determines and designates can be accepted separately. Acceptance shall be final and conclusive except for latent defects, fraud, gross mistakes amounting to fraud, or DOH's right under any warranty or guarantee.

20. Use and Possession Prior to Completion

- (a) If applicable, the Homeowner may have the right to take possession of or use any completed or partially completed part of the work. Before taking possession of or using any work, the Contracting Officer shall furnish the Contractor a list of items of work remaining to be performed or corrected on those portions of the work that the Homeowner intends to take possession of or use. However, failure of the Contracting Officer to list any item of work shall not relieve the Contractor of responsibility for complying with the terms of the contract. The Homeowner's possession or use shall not be deemed an acceptance of any work under the contract.
- (b) While the Homeowner has such possession or use, the Contractor shall be relieved of the responsibility for (1) the loss of or damage to the work resulting from the Homeowner's possession or use, notwithstanding the terms of the clause entitled Permits and Codes herein; (2) all maintenance costs on the areas occupied; and, (3) furnishing heat, light, power, and water used in the areas occupied without proper remuneration therefore. If prior possession or use by the Homeowner delays the progress of the work or causes additional expense to the Contractor, an equitable adjustment shall be made in the contract price or the time of completion, and the contract shall be modified in writing accordingly.

21. Warranty of Title

The Contractor warrants good title to all materials, supplies, and equipment incorporated in the work and agrees to deliver the premises together with all improvements thereon free from any claims, liens or charges, and agrees further that neither it nor any other person, firm or corporation shall have any right to a lien upon the premises or anything appurtenant thereto.

22. Warranty of Construction

- (a) In addition to any other warranties in this contract, the Contractor warrants, except as provided in paragraph (j) of this clause, that work performed under this contract conforms to the contract requirements and is free of any defect in equipment, material, or workmanship performed by the Contractor or any subcontractor or supplier at any tier. This warranty shall continue for a period of **one year** from the date of final acceptance of the work. If the Homeowner takes possession of any part of the work before final acceptance, this warranty shall continue for a period of (one year unless otherwise indicated) from the date that the Homeowner takes possession.
- (b) The Contractor shall remedy, at the Contractor's expense, any failure to conform, or any defect. In addition, the Contractor shall remedy, at the Contractor's expense, any damage to Homeowner-owned or controlled real or personal property when the damage is the result of—
- (1) The Contractor's failure to conform to contract requirements; or
 - (2) Any defects of equipment, material, workmanship or design furnished by the Contractor.
- (c) The Contractor shall restore any work damaged in fulfilling the terms and conditions of this clause. The Contractor's warranty with respect to work repaired or replaced will run for (one year unless otherwise indicated) from the date of repair or replacement.
- (d) The Contracting Officer shall notify the Contractor, in writing, within a reasonable

Administrative Requirements

23. Contract Period

time after the discovery of any failure, defect or damage.

- (e) If the Contractor fails to remedy any failure, defect, or damage within a reasonable time after receipt of notice, DOH shall have the right to replace, repair or otherwise remedy the failure, defect, or damage at the Contractor's expense.
- (f) With respect to all warranties, express or implied, from subcontractors, manufacturers, or suppliers for work performed and materials furnished under this contract, the Contractor shall:
- (1) Obtain all warranties that would be given in normal commercial practice;
 - (2) Require all warranties to be executed in writing, for the benefit of the homeowner; and,
 - (3) Enforce all warranties for the benefit of the homeowner.
- (g) In the event the Contractor's warranty under paragraph(a) of this clause has expired, the homeowner may bring suit at its own expense to enforce a subcontractor's, manufacturer's or supplier's warranty.
- (h) Unless a defect is caused by the negligence of the Contractor or subcontractor or supplier at any tier, the Contractor shall not be liable for the repair of any defect of material or design furnished by the homeowner nor for the repair of any damage that results from any defect in DOH furnished material or design.
- (i) Notwithstanding any provisions herein to the contrary, the establishment of the time periods in paragraphs (a) and (c) above relate only to the specific obligation of the Contractor to correct the work, and have no relationship to the time within which its obligation to comply with the contract may be sought to be enforced, nor to the time within which proceedings may be commenced to establish the Contractor's liability with respect to its obligation other than specifically to correct the work.
- (j) This warranty shall not limit DOH's/Homeowner's rights under the Inspection and Acceptance of Construction clause of this contract with respect to latent defects, gross mistakes or fraud.

The Contractor shall complete all work required under this contract within **180** calendar days of the effective date of the contract, or within the time schedule established in the notice to proceed issued by the Contracting Officer.

24. Order of Provisions

In the event of a conflict between these General Conditions and the Specifications, the General Conditions shall prevail. In the event of a conflict between the contract and any applicable state or local law or regulation, the state or local law or regulation shall prevail; provided that such state or local law or regulation does not conflict with, or is less restrictive than applicable federal law, regulation, or Executive Order. In the event of such a conflict, applicable federal law, regulation, and Executive Order shall prevail.

25. Payments

- (a) DOH/Homeowner shall pay the Contractor the price as provided in this contract.
- (b) DOH shall make progress payments approximately every 30 days as the work proceeds, on estimates of work accomplished which meets the standards of quality established under the contract, as approved by the Contracting Officer. DOH may, subject to written determination and approval of the Contracting Officer, make more frequent payments to contractors which are qualified small businesses.
- (c) Before the first progress payment under this contract, the Contractor shall furnish, in such detail as requested by the Contracting Officer, a breakdown of the total contract price showing the amount included therein for each principal category of the work, which shall substantiate the payment amount requested in order to provide a basis for determining progress payments. The breakdown shall be approved by the Contracting Officer and must be acceptable to DOH. The values and quantities employed in making up this breakdown are for determining the amount of progress payments and shall not be construed as a basis for additions to or deductions from the contract price. The Contractor shall prorate its overhead and profit over the construction period of the contract.
- (d) The Contractor shall submit, on AIA forms provided by DOH, periodic estimates showing the value of the work performed during each period based upon the approved breakdown of the contract price. Such estimates shall be

submitted not later than **14** days in advance of the date set for payment and are subject to correction and revision as required. The estimates must be approved by the Contracting Officer with the concurrence of the Architect prior to payment. If the contract covers more than one project, the Contractor shall furnish a separate progress payment estimate for each.

- (e) Along with each request for progress payments and the required estimates, the Contractor shall furnish lien waivers and labor releases as good and sufficient evidence that the premises are free from all liens, damages, and anything chargeable to said contractor.
- (f) Except as otherwise provided in State law, DOH shall retain five (5) percent of the amount of progress payments until completion and acceptance of all work under the contract; except, that if upon completion of 50 percent of the work, the Contracting Officer, after consulting with the Architect, determines that the Contractor's performance and progress are satisfactory, DOH may make the remaining payments in full for the work subsequently completed. If the Contracting Officer subsequently determines that the Contractor's performance and progress are unsatisfactory, DOH shall reinstate the five (5) percent retainage until such time as the Contracting Officer determines that performance and progress are satisfactory. Retainage will be released 90 days after project completion.
- (g) The Contracting Officer may authorize material delivered on the site and preparatory work done to be taken into consideration when computing progress payments. Material delivered to the Contractor at locations other than the site may also be taken into consideration if the Contractor furnishes satisfactory evidence that (1) it has acquired title to such material; (2) the material is properly stored in a bonded warehouse, storage yard, or similar suitable place as may be approved by the Contracting Officer; (3) the material is insured to cover its full value; and (4) the material will be used to perform this contract. Before any progress payment which includes delivered material is made, the Contractor shall furnish such documentation as the Contracting Officer may require to assure the protection of DOH's/Homeowner's interest in such materials. The Contractor shall remain responsible for such

stored material notwithstanding the transfer of title to the Homeowner.

- (h) All material and work covered by progress payments made shall, at the time of payment become the sole property of the Homeowner, but this shall not be construed as (1) relieving the Contractor from the sole responsibility for all material and work upon which payments have been made or the restoration of any damaged work; or, (2) waiving the right of DOH/Homeowner to require the fulfillment of all of the terms of the contract. In the event the work of the Contractor has been damaged by other contractors or persons other than employees of DOH in the course of their employment, the Contractor shall restore such damaged work without cost to DOH/Homeowner and to seek redress for its damage only from those who directly caused it.
- (i) DOH shall make the final payment due the Contractor under this contract after (1) completion and final acceptance of all work; and (2) presentation of release of all claims against DOH/Homeowner arising by virtue of this contract, other than claims, in stated amounts, that the Contractor has specifically excepted from the operation of the release. Each such exception shall embrace no more than one claim, the basis and scope of which shall be clearly defined. The amounts for such excepted claims shall not be included in the request for final payment. A release may also be required of the assignee if the Contractor's claim to amounts payable under this contract has been assigned.
- (j) Prior to making any payment, the Contracting Officer may require the Contractor to furnish receipts or other evidence of payment from all persons performing work and supplying material to the Contractor, if the Contracting Officer determines such evidence is necessary to substantiate claimed costs.
- (k) DOH shall not; (1) determine or adjust any claims for payment or disputes arising there under between the Contractor and its subcontractors or material suppliers; or, (2) withhold any moneys for the protection of the subcontractors or material suppliers. The failure or refusal of DOH to withhold moneys from the Contractor shall in nowise impair the obligations of any surety or sureties under any bonds furnished under this contract.

26. Contract Modifications

- (a) Only the Contracting Officer has authority to modify any term or condition of this contract. Any contract modification shall be authorized in writing.
- (b) The Contracting Officer may modify the contract unilaterally (1) pursuant to a specific authorization stated in a contract clause (e.g., Changes); or (2) for administrative matters which do not change the rights or responsibilities of the parties (e.g., change in DOH/homeowner's address). All other contract modifications shall be in the form of supplemental agreements signed by the Contractor and the Contracting Officer.
- (c) When a proposed modification requires the approval of DOH prior to its issuance (e.g., a change order that exceeds DOH's approved threshold), such modification shall not be effective until the required approval is received by DOH.

27. Changes

- (a) The Contracting Officer may, at any time, without notice to the sureties, by written order designated or indicated to be a change order, make changes in the work within the general scope of the contract including changes:
 - (1) In the specifications (including drawings and designs);
 - (2) In the method or manner of performance of the work;
 - (3) Directing the acceleration in the performance of the work.
- (b) Any other written order or oral order (which, as used in this paragraph (b), includes direction, instruction, interpretation, or determination) from the Contracting Officer that causes a change shall be treated as a change order under this clause; provided, that the Contractor gives the Contracting Officer written notice stating (1) the date, circumstances and source of the order and (2) that the Contractor regards the order as a change order.
- (c) Except as provided in this clause, no order,

statement or conduct of the Contracting Officer shall be treated as a change under this clause or entitle the Contractor to an equitable adjustment.

- (d) If any change under this clause causes an increase or decrease in the Contractor's cost of, or the time required for the performance of any part of the work under this contract, whether or not changed by any such order, the Contracting Officer shall make an equitable adjustment and modify the contract in writing. However, except for a adjustment based on defective specifications, no proposal for any change under paragraph (b) above shall be allowed for any costs incurred more than 20 days (5 days for oral orders) before the Contractor gives written notice as required. In the case of defective specifications for which DOH is responsible, the equitable adjustment shall include any increased cost reasonably incurred by the Contractor in attempting to comply with the defective specifications.
- (e) The Contractor must assert its right to an adjustment under this clause within 30 days after (1) receipt of a written change order under paragraph (a) of this clause, or (2) the furnishing of a written notice under paragraph(b) of this clause, by submitting a written statement describing the general nature and the amount of the proposal. If the facts justify it, the Contracting Officer may extend the period for submission. The proposal may be included in the notice required under paragraph (b) above. No proposal by the Contractor for an equitable adjustment shall be allowed if asserted after final payment under this contract.
- (f) The Contractor's written proposal for equitable adjustment shall be submitted in the form of a lump sum proposal supported with an itemized breakdown of all increases and decreases in the contract in at least the following details:
- (1) Direct Costs. Materials (list individual items, the quantity and unit cost of each, and the aggregate cost); Transportation and delivery costs associated with materials; Labor breakdowns by hours or unit costs (identified with specific work to be performed); Construction equipment exclusively necessary for the change; Costs of preparation and/ or revision to shop drawings resulting from the change; Worker's

Compensation and Public Liability Insurance; Employment taxes under FICA and FUTA; and, Bond Costs when size of change warrants revision.

- (2) Indirect Costs. Indirect costs may include overhead, general and administrative expenses, and fringe benefits not normally treated as direct costs.
- (3) Profit. The amount of profit shall be negotiated and may vary according to the nature, extent, and complexity of the work required by the change.

The allowability of the direct and indirect costs shall be determined in accordance with the Contract Cost Principles and Procedures for Commercial Firms in Part 31 of the Federal Acquisition Regulation (48 CFR 1-31), as implemented by HUD Handbook 2210.18, in effect on the date of this contract. The Contractor shall not be allowed a profit on the profit received by any subcontractor. Equitable adjustments for deleted work shall include a credit for profit and may include a credit for indirect costs. On proposals covering both increases and decreases in the amount of the contract, the application of indirect costs and profit shall be on the net- change in direct costs for the Contractor or subcontractor performing the work

- (g) The Contractor shall include in the proposal its request for time extension (if any), and shall include sufficient information and dates to demonstrate whether and to what extent the change will delay the completion of the contract in its entirety.
- (h) The Contracting Officer shall act on proposals within 30 days after their receipt, or notify the Contractor of the date when such action will be taken.
- (i) Failure to reach an agreement on any proposal shall be a dispute under the clause entitled Disputes herein. Nothing in this clause, however, shall excuse the Contractor from proceeding with the contract as changed.
- (j) Except in an emergency endangering life or property, no change shall be made by the Contractor without a prior order from the Contracting Officer.

28. Suspension of Work

- (a) The Contracting Officer may order the Contractor in writing to suspend, delay, or interrupt all or any part of the work of this contract for the period of

time that the Contracting Officer determines appropriate for the convenience of DOH/Homeowner.

If the performance of all or any part of the work is, for an unreasonable period of time, suspended, delayed, or interrupted (1) by an act of the Contracting Officer in the administration of this contract, or (2) by the Contracting Officer's failure to act within the time specified (or within a reasonable time if not specified) in this contract an adjustment may be made for any increase in the cost of performance of the contract (excluding profit) necessarily caused by such unreasonable suspension, delay, or interruption and the contract modified in writing accordingly. However, no adjustment shall be made under this clause for any suspension, delay, or interruption to the extent that performance would have been so suspended, delayed, or interrupted by any other cause, including the fault or negligence of the Contractor or for which any equitable adjustment is provided for or excluded under any other provision of this contract.

(b) A claim under this clause shall not be allowed without prior written approval of the Contracting Officer.

29. Disputes

(a) "Claim," as used in this clause, means a written demand or written assertion by one of the contracting parties seeking, as a matter of right, the payment of money in a sum certain, the adjustment or interpretation of contract terms, or other relief arising under or relating to the contract. A claim arising under the contract, unlike a claim relating to the contract, is a claim that can be resolved under a contract clause that provides for the relief sought by the claimant. A voucher, invoice, or other routine request for payment that is not in dispute when submitted is not a claim. The submission may be converted to a claim by complying with the requirements of this clause, if it is disputed either as to liability or amount or is not acted upon in a reasonable time.

(b) Except for disputes arising under the clauses entitled Labor Standards - Davis Bacon and Related Acts, herein, all disputes arising under or relating to this contract, including any

claims for damages for the alleged breach thereof which are not disposed of by agreement, shall be resolved under this clause.

- (c) All claims by the Contractor shall be made in writing and submitted to the Contracting Officer for a written decision.
- (d) A claim by the Homeowner against the Contractor shall be subject to a written decision by the Contracting Officer.
- (e) The Contracting Officer shall, within 60 (unless otherwise indicated) days after receipt of the request, decide the claim or notify the Contractor of the date by which the decision will be made.
- (f) The Contracting Officer's decision shall be final unless the Contractor (1) appeals in writing to a higher level in DOH in accordance with DOH's policy and procedures, (2) refers the appeal to an independent mediator or arbitrator, or (3) files suit in a court of competent jurisdiction. Such appeal must be made within (30 unless otherwise indicated) days after receipt of the Contracting Officer's decision.
- (g) The Contractor shall proceed diligently with performance of this contract, pending final resolution of any request for relief, claim, appeal, or action arising under or relating to the contract, and comply with any decision of the Contracting Officer.

30. Default

- (a) If the Contractor refuses or fails to prosecute the work, or any separable part thereof, with the diligence that will insure its completion within the time specified in this contract, or any extension thereof, or fails to complete said work within this time, the Contracting Officer may, by written notice to the Contractor, terminate the right to proceed with the work (or separable part of the work) that has been delayed. In this event, DOH may take over the work and complete it, by contract or otherwise, and may take possession of and use any materials, equipment, and plant on the work site necessary for completing the work. The Contractor and its sureties shall be liable for any damage to DOH/Homeowner resulting from the Contractor's refusal or failure to complete the work within the specified time, whether or not the Contractor's right to proceed with the work is terminated. This liability includes any increased

costs incurred by DOH/Homeowner in completing the work.

- (b) The Contractor's right to proceed shall not be terminated or the Contractor charged with damages under this clause if—
- (1) The delay in completing the work arises from unforeseeable causes beyond the control and without the fault or negligence of the Contractor. Examples of such causes include (i) acts of God, or of the public enemy, (ii) acts of DOH or other governmental entity in either its sovereign or contractual capacity, (iii) acts of another contractor in the performance of a contract with DOH, (iv) fires, (v) floods, (vi) epidemics, (vii) quarantine restrictions, (viii) strikes, (ix) freight embargoes, (x) unusually severe weather, or (xi) delays of subcontractors or suppliers at any tier arising from unforeseeable causes beyond the control and without the fault or negligence of both the Contractor and the subcontractors or suppliers; and
 - (2) The Contractor, within days (5 days unless otherwise indicated) from the beginning of such delay (unless extended by the Contracting Officer) notifies the Contracting Officer in writing of the causes of delay. The Contracting Officer shall ascertain the facts and the extent of the delay. If, in the judgment of the Contracting Officer, the findings of fact warrant such action, time for completing the work shall be extended by written modification to the contract. The findings of the Contracting Officer shall be reduced to a written decision which shall be subject to the provisions of the Disputes clause of this contract.

- (b) If, after termination of the Contractor's right to proceed, it is determined that the Contractor was not in default, or that the delay was excusable, the rights and obligations of the parties will be the same as if the termination had been for convenience of DOH.

31. Liquidated Damages

- (a) If the Contractor fails to complete the work within the time specified in the contract, or any extension, as specified in the clause entitled Default of this contract, the Contractor may pay to DOH as liquidated damages, the sum of \$100.00 for each day of delay. If different completion dates are specified in the contract for separate parts or stages of the work, the amount of liquidated damages shall be assessed on those parts or stages which are delayed. To the extent that the Contractor's delay or nonperformance is excused under another clause in this contract, liquidated damages shall not be due DOH. The Contractor remains liable for damages caused other than by delay.
- (b) If DOH terminates the Contractor's right to proceed, the resulting damage will consist of liquidated damages until such reasonable time as may be required for final completion of the work together with any increased costs occasioned DOH in completing the work.
- (c) If DOH does not terminate the Contractor's right to proceed, the resulting damage will consist of liquidated damages until the work is completed or accepted.

32. Termination for Convenience

- (a) The Contracting Officer may terminate this contract in whole, or in part, whenever the Contracting Officer determines that such termination is in the best interest of DOH/Homeowner. Any such termination shall be effected by delivery to the Contractor of a Notice of Termination specifying the extent to which the performance of the work under the contract is terminated, and the date upon which such termination becomes effective.
- (b) If the performance of the work is terminated, either in whole or in part, DOH/Homeowner shall be liable to the Contractor for reasonable and proper costs resulting from such termination upon the receipt by DOH of a properly presented claim setting out in detail: (1) the total cost of the work

performed to date of termination less the total amount of contract payments made to the Contractor; (2) the cost (including reasonable profit) of settling and paying claims under subcontracts and material orders for work performed and materials and supplies delivered to the site, payment for which has not been made by DOH to the Contractor or by the Contractor to the subcontractor or supplier; (3) the cost of preserving and protecting the work already performed until DOH or assignee takes possession thereof or assumes responsibility therefore; (4) the actual or estimated cost of legal and accounting services reasonably necessary to prepare and present the termination claim to DOH/Homeowner; and (5) an amount constituting a reasonable profit on the value of the work performed by the Contractor.

- (c) The Contracting Officer will act on the Contractor's claim within days (60 days unless otherwise indicated) of receipt of the Contractor's claim.
- (d) Any disputes with regard to this clause are expressly made subject to the provisions of the Disputes clause of this contract.

33. Assignment of Contract

The Contractor shall not assign or transfer any interest in this contract; except that claims for monies due or to become due from DOH/Homeowner under the contract may be assigned to a bank, trust company, or other financial institution. Such assignments of claims shall only be made with the written concurrence of the Contracting Officer. If the Contractor is a partnership, this contract shall inure to the benefit of the surviving or remaining member(s) of such partnership as approved by the Contracting Officer.

34. Insurance

- (a) Before commencing work, the Contractor and each subcontractor shall furnish DOH with certificates of insurance listing DOH and the Homeowner as additionally insured A.T.I.M.A. showing the following insurance is in force and will insure all operations under the Contract:

- (1) Workers' Compensation, in accordance with state or Territorial Workers' Compensation laws.
 - (2) Commercial General Liability with a combined single limit for bodily injury and property damage of not less than \$1,000,000 per occurrence to protect the Contractor and each subcontractor against claims for bodily injury or death and damage to the property of others. This shall cover the use of all equipment, hoists, and vehicles on the site(s) not covered by Automobile Liability under (3) below. If the Contractor has a "claims- made" policy, then the following additional requirements apply: the policy must provide a "retroactive date" which must be on or before the execution date of the Contract; and the extended reporting period may not be less than five years following the completion date of the Contract.
 - (3) Automobile Liability on owned and non-owned motor vehicles used on the site(s) or in connection therewith for a combined single limit for bodily injury and property damage of not less than \$1,000,000 per occurrence.
 - (4) Cargo Insurance in the amount of \$250,000 is required when the project involves raising the structure above the Base Flood Elevation.
- (b) Before commencing work, the Contractor shall furnish DOH with a certificate of insurance evidencing that Builder's Risk (fire and extended coverage) Insurance on all work in place and/or materials stored at the building site(s), including foundations and building equipment, is in force. The Builder's Risk Insurance shall be for the benefit of the Contractor, the Homeowner and DOH as their interests may appear and each shall be named in the policy or policies as an insured. The Contractor in installing equipment supplied by DOH shall carry insurance on such equipment from the time the Contractor takes possession thereof until the Contract work is accepted by DOH. The Builder's Risk Insurance need not be carried on excavations, piers, footings, or foundations until such time as work on the superstructure is started. It need not be carried on landscape work. Policies shall furnish coverage at all times for the full cash value of all completed construction, as well as materials in place and/or stored at the site(s), whether or not partial payment has been made by DOH. The Contractor may terminate this insurance on buildings as of

the date taken over for occupancy by the Homeowner. The Contractor is not required to carry Builder's Risk Insurance for modernization work which does not involve structural alterations or additions and where the Homeowner's existing fire and extended coverage policy can be endorsed to include such work.

- (c) All insurance shall be carried with companies which are financially responsible and admitted to do business in the State in which the project is located with a minimum Best rating of A-. If any such insurance is due to expire during the construction period, the Contractor (including subcontractors, as applicable) shall not permit the coverage to lapse and shall furnish evidence of coverage to the Contracting Officer. All certificates of insurance, as evidence of coverage, shall provide that no coverage may be canceled or non-renewed by the insurance company until at least 30 days prior written notice has been given to the Contracting Officer.

35. Subcontracts

- (a) Definitions. As used in this contract -
 - (1) "Subcontract" means any contract, purchase order, or other purchase agreement, including modifications and change orders to the foregoing, entered into by a subcontractor to furnish supplies, materials, equipment, and services for the performance of the prime contract or a subcontract.
 - (2) "Subcontractor" means any supplier, vendor, or firm that furnishes supplies, materials, equipment, or services to or for the Contractor or another subcontractor.
- (b) The Contractor shall not enter into any subcontract with any subcontractor who has been temporarily denied participation in a HUD program or who has been suspended or debarred from participating in contracting programs by any agency of the United States Government or of the state in which the work under this contract is to be performed.
- (c) The Contractor shall be as fully responsible for the acts or omissions of its subcontractors, and of persons either directly or indirectly employed by them as for the acts or omissions of persons directly employed by the Contractor.

- (d) The Contractor shall insert appropriate clauses in all subcontracts to bind subcontractors to the terms and conditions of this contract insofar as they are applicable to the work of subcontractors.
- (e) Nothing contained in this contract shall create any contractual relationship between any subcontractor and DOH or between the subcontractor and HUD.

36. Subcontracting with Small and Minority Firms, Women’s Business Enterprise, and Labor Surplus Area Firms

The Contractor shall take the following steps to ensure that, whenever possible, subcontracts are awarded to small business firms, minority firms, women’s business enterprises, and labor surplus area firms:

- (a) Placing qualified small and minority businesses and women’s business enterprises on solicitation lists;
- (b) Ensuring that small and minority businesses and women’s business enterprises are solicited whenever they are potential sources;
- (c) Dividing total requirements, when economically feasible, into smaller tasks or quantities to permit maximum participation by small and minority businesses and women’s business enterprises;
- (d) Establishing delivery schedules, where the requirements of the contract permit, which encourage participation by small and minority businesses and women’s business enterprises; and
- (e) Using the services and assistance of the U.S. Small Business Administration, the Minority Business Development Agency of the U.S. Department of Commerce, and State and local governmental small business agencies.

37. Equal Employment Opportunity

During the performance of this contract, the Contractor agrees as follows:

- (a) The Contractor shall not discriminate against any employee or applicant for employment because of race, color, religion, sex, national origin, or

handicap.

- (b) The Contractor shall take affirmative action to ensure that applicants are employed, and that employees are treated during employment without regard to their race, color, religion, sex, national origin, or handicap. Such action shall include, but not be limited to, (1) employment, (2) upgrading, (3) demotion, (4) transfer, (5) recruitment or recruitment advertising, (6) layoff or termination, (7) rates of pay or other forms of compensation, and (8) selection for training, including apprenticeship.
- (c) The Contractor shall post in conspicuous places available to employees and applicants for employment the notices to be provided by the Contracting Officer that explain this clause.
- (d) The Contractor shall, in all solicitations or advertisements for employees placed by or on behalf of the Contractor, state that all qualified applicants will receive consideration for employment without regard to race, color, religion, sex, national origin, or handicap.
- (e) The Contractor shall send, to each labor union or representative of workers with which it has a collective bargaining agreement or other contract or understanding, the notice to be provided by the Contracting Officer advising the labor union or workers’ representative of the Contractor’s commitments under this clause, and post copies of the notice in conspicuous places available to employees and applicants for employment.
- (f) The Contractor shall comply with Executive Order 11246, as amended, and the rules, regulations, and orders of the Secretary of Labor.
- (g) The Contractor shall furnish all information and reports required by Executive Order 11246, as amended, Section 503 of the Rehabilitation Act of 1973, as amended, and by rules, regulations, and orders of the Secretary of Labor, or pursuant thereto. The Contractor shall permit access to its books, records, and accounts by the Secretary of Labor for purposes of investigation to ascertain compliance with such rules, regulations, and orders.
- (h) In the event of a determination that the Contractor is not in compliance with this clause or any rule, regulation, or order of the Secretary of Labor, this contract may be canceled, terminated, or suspended in whole or in part, and the Contractor may be declared ineligible for further Government contracts, or Federally assisted construction contracts under the procedures authorized in Executive Order 11246, as amended. In addition,

sanctions may be imposed and remedies invoked against the Contractor as provided in Executive Order 11246, as amended, the rules, regulations, and orders of the Secretary of Labor, or as otherwise provided by law.

- (i) The Contractor shall include the terms and conditions of this clause in every subcontract or purchase order unless exempted by the rules, regulations, or orders of the Secretary of Labor issued under Executive Order 11246, as amended, so that these terms and conditions will be binding upon each subcontractor or vendor. The Contractor shall take such action with respect to any subcontract or purchase order as the Secretary of Housing and Urban Development or the Secretary of Labor may direct as a means of enforcing such provisions, including sanctions for noncompliance; provided that if the Contractor becomes involved in, or is threatened with, litigation with a subcontractor or vendor as a result of such direction, the Contractor may request the United States to enter into the litigation to protect the interests of the United States.
- (j) Compliance with the requirements of this clause shall be to the maximum extent consistent with, but not in derogation of, compliance with section 7(b) of the Indian Self-Determination and Education Assistance Act and the Indian Preference clause of this contract.

38. Employment, Training, and Contracting Opportunities for Low-Income Persons, Section 3 of the Housing and Urban Development Act of 1968.

- (a) The work to be performed under this contract is subject to the requirements of Section 3 of the Housing and Urban Development Act of 1968, as amended, 12 U.S.C. 1701u (Section 3). The purpose of Section 3 is to ensure that employment and other economic opportunities generated by HUD assistance or HUD-assisted projects covered by Section 3, shall, to the greatest extent feasible, be directed to low- and very low-income persons, particularly persons who are recipients of HUD assistance for housing.
- (b) The parties to this contract agree to comply with HUD's regulations in 24 CFR Part 135, which implement Section 3. As evidenced by their execution of this contract, the parties to this contract certify that they are under no contractual or other impediment that would prevent them from complying with the Part 135 regulations.

- (c) The contractor agrees to send to each labor organization or representative of workers with which the contractor has a collective bargaining agreement or other understanding, if any, a notice advising the labor organization or workers' representative of the contractor's commitments under this Section 3 clause, and will post copies of the notice in conspicuous places at the work site where both employees and applicants for training and employment positions can see the notice. The notice shall describe the Section 3 preference, shall set forth minimum number and job titles subject to hire, availability of apprenticeship and training positions, the qualifications for each; and the name and location of the person(s) taking applications for each of the positions; and the anticipated date the work shall begin.
- (d) The contractor agrees to include this Section 3 clause in every subcontract subject to compliance with regulations in 24 CFR Part 135, and agrees to take appropriate action, as provided in an applicable provision of the subcontract or in this Section 3 clause, upon a finding that the subcontractor is in violation of the regulations in 24 CFR Part 135. The contractor will not subcontract with any subcontractor where the contractor has notice or knowledge that the subcontractor has been found in violation of the regulations in 24 CFR Part 135.
- (e) The contractor will certify that any vacant employment positions, including training positions, that are filled (1) after the contractor is selected but before the contract is executed, and (2) with persons other than those to whom the regulations of 24 CFR Part 135 require employment opportunities to be directed, were not filled to circumvent the contractor's obligations under 24 CFR Part 135.
- (f) Noncompliance with HUD's regulations in 24 CFR Part 135 may result in sanctions, termination of this contract for default, and debarment or suspension from future HUD assisted contracts.
- (g) With respect to work performed in connection with Section 3 covered Indian housing assistance, section 7(b) of the Indian Self-Determination and Education Assistance Act (25 U.S.C. 450e) also applies to the work to be performed under this contract. Section 7(b) requires that to the greatest extent feasible (i) preference and opportunities for training and employment shall be given to Indians, and (ii) preference in the award of

contracts and subcontracts shall be given to Indian organizations and Indian-owned Economic Enterprises. Parties to this contract that are subject to the provisions of Section 3 and Section 7(b) agree to comply with Section 3 to the maximum extent feasible, but not in derogation of compliance with section 7(b).

39. Interest of Members of Congress

No member of or delegate to the Congress of the United States of America shall be admitted to any share or part of this contract or to any benefit that may arise therefrom.

40. Interest of Members, Officers, or Employees and Former Members, Officers, or Employees

No member, officer, or employee of DOH, no member of the governing body of the locality in which the project is situated, no member of the governing body of the locality in which DOH was activated, and no other public official of such locality or localities who exercises any functions or responsibilities with respect to the project, shall, during his or her tenure, or for one year thereafter, have any interest, direct or indirect, in this contract or the proceeds thereof.

41. Limitations on Payments made to Influence Certain Federal Financial Transactions

- (a) The Contractor agrees to comply with Section 1352 of Title 31, United States Code which prohibits the use of Federal appropriated funds to pay any person for influencing or attempting to influence an officer or employee of any agency, a Member of Congress, and officer or employee of Congress, or an employee of a Member of Congress in connection with any of the following covered Federal actions: the awarding of any Federal contract; the making of any Federal grant; the making of any Federal loan; the entering into of any cooperative agreement; or the modification of any Federal contract, grant, loan, or cooperative agreement.
- (b) The Contractor further agrees to comply with the requirement of the Act to furnish a disclosure (OMB Standard Form LLL, Disclosure of Lobbying Activities) if any funds other than Federal appropriated funds (including profit or fee received under a covered Federal transaction) have been paid, or will be paid, to any person for influencing or attempting to influence an officer or employee of

any agency, a Member of Congress, an officer or employee of Congress, or an employee of a Member of Congress in connection with a Federal contract, grant, loan, or cooperative agreement.

42. Royalties and Patents

The Contractor shall pay all royalties and license fees. It shall defend all suits or claims for infringement of any patent rights and shall save DOH/Homeowner harmless from loss on account thereof; except that DOH shall be responsible for all such loss when a particular design, process or the product of a particular manufacturer or manufacturers is specified and the Contractor has no reason to believe that the specified design, process, or product is an infringement. If, however, the Contractor has reason to believe that any design, process or product specified is an infringement of a patent, the Contractor shall promptly notify the Contracting Officer. Failure to give such notice shall make the Contractor responsible for resultant loss.

43. Examination and Retention of Contractor's Records

- (a) DOH, HUD, or Comptroller General of the United States, or any of their duly authorized representatives shall, until 3 years after final payment under this contract, have access to and the right to examine any of the Contractor's directly pertinent books, documents, papers, or other records involving transactions related to this contract for the purpose of making audit, examination, excerpts, and transcriptions.
- (b) The Contractor agrees to include in first-tier subcontracts under this contract a clause substantially the same as paragraph (a) above. "Subcontract," as used in this clause, excludes purchase orders not exceeding \$10,000.
- (c) The periods of access and examination in paragraphs (a) and (b) above for records relating to (1) appeals under the Disputes clause of this contract, (2) litigation or settlement of claims arising from the performance of this contract, or (3) costs and expenses of this contract to which DOH, HUD, or Comptroller General or any of their duly authorized representatives has taken exception shall continue until disposition of such appeals, litigation, claims, or exceptions.

44. Labor Standards - Davis-Bacon and Related Acts

Except for housing rehabilitation/reconstruction projects designed to contain fewer than eight (8) units, if the total amount of this contract exceeds

\$2,000, the Federal labor standards set forth in the clause below shall apply to the development or construction work to be performed under the contract.

(a) Minimum Wages.

(1) All laborers and mechanics employed under this contract in the development or construction of the project(s) involved will be paid unconditionally and not less often than once a week, and without subsequent deduction or rebate on any account (except such payroll deductions as are permitted by regulations issued by the Secretary of Labor under the Copeland Act (29 CFR Part 3)), the full amount of wages and bona fide fringe benefits (or cash equivalents thereof) due at time of payment computed at rates not less than those contained in the wage determination of the Secretary of Labor which is attached hereto and made a part hereof (if applicable), regardless of any contractual relationship which may be alleged to exist between the Contractor and such laborers and mechanics. Contributions made or costs reasonably anticipated for bona fide fringe benefits under Section 1(b)(2) of the Davis-Bacon Act on behalf of laborers or mechanics are considered wages paid to such laborers or mechanics, subject to the provisions of 29 CFR 5.5(a)(1)(iv); also, regular contributions made or costs incurred for more than a weekly period (but not less often than quarterly) under plans, funds, or programs which cover the regular weekly period, are deemed to be constructively made or incurred during such weekly period. If applicable, such laborers and mechanics shall be paid the appropriate wage rate and fringe benefits in the wage determination for the classification of work actually performed, without regard to skill, except as provided in 29 CFR 5.5(a)(4). Laborers or mechanics performing work in more than one classification may be compensated at the rate specified for each classification for the time actually worked therein; provided, that the employer's payroll records accurately set forth the time spent in each classification in which work is performed. The wage determination (including any additional classification and wage rates conformed under 29 CFR 5.5(a)(1)(ii) and the Davis-Bacon poster (WH-1321) shall be posted at all times by the Contractor and its subcontractors at the site of the work in a prominent and accessible place where it can be easily seen by the workers (if applicable).

(2) (i) Any class of laborers or mechanics, including

helpers, which is not listed in the wage determination and which is to be employed under the contract shall be classified in conformance with the wage determination. HUD shall approve an additional classification and wage rate and fringe benefits therefor only when all the following criteria have been met: (A) The work to be performed by the classification requested is not performed by a classification in the wage determination; and (B) The classification is utilized in the area by the construction industry; and (C) The proposed wage rate, including any bona fide fringe benefits, bears a reasonable relationship to the wage rates contained in the wage determination.

(ii) If the Contractor and the laborers and mechanics to be employed in the classification (if known), or their representatives, and HUD or its designee agree on the classification and wage rate (including the amount designated for fringe benefits where appropriate), a report of the action taken shall be sent by HUD or its designee to the Administrator of the Wage and Hour Division, Employee Standards Administration, U.S. Department of Labor, Washington, DC 20210. The Administrator, or an authorized representative, will approve, modify, or disapprove every additional classification action within 30 days of receipt and so advise HUD or its designee or will notify HUD or its designee within the 30-day period that additional time is necessary.

(iii) In the event the Contractor, the laborers or mechanics to be employed in the classification or their representatives, and HUD or its designee do not agree on the proposed classification and wage rate (including the amount designated for fringe benefits, where appropriate), HUD or its designee shall refer the questions, including the views of all interested parties and the recommendation of HUD or its designee, to the Administrator of the Wage and Hour Division for determination. The Administrator, or an authorized representative, will issue a determination within 30 days of receipt and so advise HUD or its designee or will notify HUD or its designee within the 30-day period that additional time is necessary.

(iv) The wage rate (including fringe benefits

where appropriate) determined pursuant to subparagraphs (a)(2)(ii) or (iii) of this clause shall be paid to all workers performing work in the classification under this contract from the first day on which work is performed in classification.

(3) Whenever the minimum wage rate prescribed in the contract for a class of laborers or mechanics includes a fringe benefit which is not expressed as an hourly rate, the Contractor shall either pay the benefit as stated in the wage determination or shall pay another bona fide fringe benefit or an hourly cash equivalent thereof.

(4) If the Contractor does not make payments to a trustee or other third person, the Contractor may consider as part of the wages of any laborer or mechanic the amount of any costs reasonably anticipated in providing bona fide fringe benefits under a plan or program; provided, that the Secretary of Labor has found, upon the written request of the Contractor, that the applicable standards of the Davis-Bacon Act have been met. The Secretary of Labor may require the Contractor to set aside in a separate account assets for the meeting of obligations under the plan or program.

(b) Withholding of funds. HUD or its designee shall, upon its own action or upon written request of an authorized representative of the Department of Labor, withhold or cause to be withheld from the Contractor under this contract or any other Federal contract with the same prime Contractor, or any other Federally-assisted contract subject to Davis-Bacon prevailing wage requirements, which is held by the same prime Contractor, so much of the accrued payments or advances as may be considered necessary to pay laborers and mechanics, including apprentices, trainees, and helpers, employed by the Contractor or any subcontractor the full amount of wages required by the contract. In the event of failure to pay any laborer or mechanic, including any apprentice, trainee, or helper, employed or working in the construction or development of the project, all or part of the wages required by the contract, HUD or its designee may, after written notice to the Contractor, take such action as may be necessary to cause the suspension of any further payment, advance, or guarantee of funds until such violations have ceased. HUD

or its designee may, after written notice to the Contractor, disburse such amounts withheld for and on account of the Contractor or subcontractor to the respective employees to whom they are due.

(c) Payrolls and basic records.

(1) Payrolls and basic records relating thereto shall be maintained by the Contractor during the course of the work and preserved for a period of three years thereafter for all laborers and mechanics working in the construction or development of the project. Such records shall contain the name, address, and social security number of each such worker, his or her correct classification, hourly rates of wages paid (including rates of contributions or costs anticipated for bona fide fringe benefits or cash equivalents thereof of the types described in section 1(b)(2)(B) of the Davis-Bacon Act), daily and weekly number of hours worked, deductions made, and actual wages paid. Whenever the Secretary of Labor has found, under 29 CFR 5.5(a)(1)(iv), that the wages of any laborer or mechanic include the amount of costs reasonably anticipated in providing benefits under a plan or program described in section 1(b)(2)(B) of the Davis-Bacon Act, the Contractor shall maintain records which show that the commitment to provide such benefits is enforceable, that the plan or program is financially responsible, and that the plan or program has been communicated in writing to the laborers or mechanics affected, and records which show the costs anticipated or the actual cost incurred in providing such benefits. Contractors employing apprentices or trainees under approved programs shall maintain written evidence of the registration of apprenticeship programs and certification of trainee programs, the registration of the apprentices and trainees, and the ratios and wage rates prescribed in the applicable programs.

(2) (i) The Contractor shall submit weekly for each week in which any contract work is performed a copy of all payrolls to the Contracting Officer for transmission to HUD

or its designee. The payrolls submitted shall set out accurately and completely all of the information required to be maintained under subparagraph (c)(1) of this clause. This information may be submitted in any form desired. Optional Form WH-347 (Federal Stock Number 029-005-00014-1) is available for this purpose and may be purchased from the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. The Contractor is responsible for the submission of copies of payrolls by all subcontractors. (Approved by the Office of Management and Budget under OMB Control Number 1214-0149.)

- (ii) Each payroll submitted shall be accompanied by a "Statement of Compliance," signed by the Contractor or subcontractor or his or her agent who pays or supervises the payment of the persons employed under the contract and shall certify the following:
 - (A) That the payroll for the payroll period contains the information required to be maintained under paragraph (c) (1) of this clause and that such information is correct and complete;
 - (B) That each laborer or mechanic (including each helper, apprentice, and trainee) employed on the contract during the payroll period has been paid the full weekly wages earned, without rebate, either directly or indirectly, and that no deductions have been made either directly or indirectly from the full wages earned, other than permissible deductions as set forth in 29 CFR Part 3; and
 - (C) That each laborer or mechanic has been paid not less than the applicable wage rates and fringe benefits or cash equivalents for the classification of work performed, as specified in the applicable wage determination incorporated into the contract.
- (iii) The weekly submission of a properly executed certification set forth on the reverse side of Optional Form WH-347 shall satisfy the requirements for submission of the "Statement of Compliance" required by subparagraph (c)(2)(ii) of this clause.
- (iv) The falsification of any of the above certifications may subject the Contractor or subcontractor to civil or criminal prosecution under Section 1001 of Title 18 and Section

3729 of Title 31 of the United States Code.

- (3) The Contractor or subcontractor shall make the records required under subparagraph (c)(1) available for inspection, copying, or transcription by authorized representatives of HUD or its designee, the Contracting Officer, or the Department of Labor and shall permit such representatives to interview employees during working hours on the job. If the Contractor or subcontractor fails to submit the required records or to make them available, HUD or its designee may, after written notice to the Contractor, take such action as may be necessary to cause the suspension of any further payment, advance, or guarantee of funds. Furthermore, failure to submit the required records upon request or to make such records available may be grounds for debarment action pursuant to 29 CFR 5.12.
- (d) (1) Apprentices. Apprentices will be permitted to work at less than the predetermined rate for the work they performed when they are employed pursuant to and individually registered in a bona fide apprenticeship program registered with the U.S. Department of Labor, Employment and Training Administration, Office of Apprenticeship and Training, Employer and Labor Services (OATELS), or with a State Apprenticeship Agency recognized by OATELS, or if a person is employed in his or her first 90 days of probationary employment as an apprentice in such an apprenticeship program, who is not individually registered in the program, but who has been certified by OATELS or a State Apprenticeship Agency (where appropriate) to be eligible for probationary employment as an apprentice. The allowable ratio of apprentices to journeymen on the job site in any craft classification shall not be greater than the ratio permitted to the Contractor as to the entire work force under the registered program. Any worker listed on a payroll at an apprentice wage rate, who is not registered or otherwise employed as stated in this paragraph, shall be paid not less than the applicable wage rate on the

wage determination for the classification of work actually performed. In addition, any apprentice performing work on the job site in excess of the ratio permitted under the registered program shall be paid not less than the applicable wage rate on the wage determination for the work actually performed. Where a contractor is performing construction on a project in a locality other than that in which its program is registered, the ratios and wage rates (expressed in percentages of the journeyman's hourly rate) specified in the Contractor's or subcontractor's registered program shall be observed. Every apprentice must be paid at not less than the rate specified in the registered program for the apprentice's level of progress, expressed as a percentage of the journeyman hourly rate specified in the applicable wage determination. Apprentices shall be paid fringe benefits in accordance with the provisions of the apprenticeship program. If the apprenticeship program does not specify fringe benefits, apprentices must be paid the full amount of fringe benefits listed on the wage determination for the applicable classification. If the Administrator of the Wage and Hour Division determines that a different practice prevails for the applicable apprentice classification, fringes shall be paid in accordance with that determination. In the event OATELS, or a State Apprenticeship Agency recognized by OATELS, withdraws approval of an apprenticeship program, the Contractor will no longer be permitted to utilize apprentices at less than the applicable predetermined rate for the work performed until an acceptable program is approved.

- (2) Trainees. Except as provided in 29 CFR 5.16, trainees will not be permitted to work at less than the predetermined rate for the work performed unless they are employed pursuant to and individually registered in a program which has received prior approval, evidenced by formal certification by the U.S. Department of Labor, Employment and Training Administration. The ratio of trainees to journeymen on the job site shall not be greater than permitted under the plan approved by the Employment and Training Administration.

Every trainee must be paid at not less than the rate specified in the approved program for the trainee's level of progress, expressed as a percentage of the journeyman hourly rate specified in the applicable wage determination. Trainees shall be paid fringe benefits in accordance with the provisions of the trainee program. If the trainee program does not mention fringe benefits, trainees shall be paid the full amount of fringe benefits listed in the wage determination unless the Administrator of the Wage and Hour Division determines that there is an apprenticeship program associated with the corresponding journeyman wage rate in the wage determination which provides for less than full fringe benefits for apprentices. Any employee listed on the payroll at a trainee rate who is not registered and participating in a training plan approved by the Employment and Training Administration shall be paid not less than the applicable wage rate in the wage determination for the classification of work actually performed. In addition, any trainee performing work on the job site in excess of the ratio permitted under the registered program shall be paid not less than the applicable wage rate in the wage determination for the work actually performed. In the event the Employment and Training Administration withdraws approval of a training program, the Contractor will no longer be permitted to utilize trainees at less than the applicable predetermined rate for the work performed until an acceptable program is approved.

- (3) Equal employment opportunity. The utilization of apprentices, trainees, and journeymen under this clause shall be in conformity with the equal employment opportunity requirements of Executive Order 11246, as amended, and 29 CFR Part 30.
- (e) Compliance with Copeland Act requirements. The Contractor shall comply with the requirements of 29 CFR Part 3, which are hereby incorporated by reference in this contract.
- (f) Contract termination; debarment. A breach of this contract clause may be grounds for termination of the contract and for debarment as a Contractor and a subcontractor as provided in 29 CFR 5.12.
- (g) Compliance with Davis-Bacon and related Act requirements. All rulings and interpretations of the Davis-Bacon and related Acts contained in 29 CFR Parts 1, 3, and 5 are herein incorporated by

reference in this contract.

- (h) Disputes concerning labor standards. Disputes arising out of the labor standards provisions of this clause shall not be subject to the general disputes clause of this contract. Such disputes shall be resolved in accordance with the procedures of the Department of Labor set forth in 29 CFR Parts 5, 6, and 7. Disputes within the meaning of this clause include disputes between the Contractor (or any of its subcontractors) and DOH, HUD, the U.S.

Department of Labor, or the employees or their representatives.

- (i) Certification of eligibility.

- (1) By entering into this contract, the Contractor certifies that neither it (nor he or she) nor any person or firm who has an interest in the Contractor's firm is a person or firm ineligible to be awarded contracts by the United States Government by virtue of section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1).

- (2) No part of this contract shall be subcontracted to any person or firm ineligible for award of a United States Government contract by virtue of section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1).

- (3) The penalty for making false statements is prescribed in the U. S. Criminal Code, 18 U.S.C. 1001.

- (j) Contract Work Hours and Safety Standards Act.

As used in this paragraph, the terms "laborers" and "mechanics" include watchmen and guards.

- (1) Overtime requirements. No contractor or subcontractor contracting for any part of the contract work which may require or involve the employment of laborers or mechanics, including watchmen and guards, shall require or permit any such laborer or mechanic in any workweek in which the individual is employed on such work to work in excess of 40 hours in such workweek unless such laborer or mechanic receives compensation at a rate not less than one and one-half times the basic rate of pay for all hours worked in excess of 40 hours in such workweek.

- (2) Violation; liability for unpaid wages; liquidated damages. In the event of any violation of the provisions set forth in subparagraph (j)(1) of this clause, the Contractor and any subcontractor responsible therefor shall be liable for the unpaid wages. In addition, such Contractor and subcontractor

shall be liable to the United States (in the case of work done under contract for the District of Columbia or a territory, to such District or to such territory), for liquidated damages. Such liquidated damages shall be computed with respect to each individual laborer or mechanic (including watchmen and guards) employed in violation of the provisions set forth in subparagraph (j)(1) of this clause, in the sum of \$10 for each calendar day on which such individual was required or permitted to work in excess of the standard workweek of 40 hours without payment of the overtime wages required by provisions set forth in subparagraph (j)(1) of this clause.

- (3) Withholding for unpaid wages and liquidated damages. HUD or its designee shall upon its own action or upon written request of an authorized representative of the Department of Labor withhold or cause to be withheld, from any moneys payable on account of work performed by the Contractor or subcontractor under any such contract or any Federal contract with the same prime Contractor, or any other Federally-assisted contract subject to the Contract Work Hours and Safety Standards Act, which is held by the same prime Contractor, such sums as may be determined to be necessary to satisfy any liabilities of such Contractor or subcontractor for unpaid wages and liquidated damages as provided in the provisions set forth in subparagraph (j)(2) of this clause.

- (k) Subcontracts. The Contractor or subcontractor shall insert in any subcontracts all the provisions contained in this clause, and such other clauses as HUD or its designee may by appropriate instructions require, and also a clause requiring the subcontractors to include these provisions in any lower tier subcontracts. The prime Contractor shall be responsible for the compliance by any subcontractor or lower tier subcontractor with all these provisions

45. . Non-Federal Prevailing Wage Rates

- (a) Any prevailing wage rate (including basic hourly rate and any fringe benefits), determined under State or tribal law to be prevailing, with respect to any employee in any trade or position employed under the contract, is inapplicable to the contract and shall not be enforced against the Contractor or any subcontractor, with respect to employees engaged under the contract whenever such non-

Federal prevailing wage rate exceeds:

- (1) The applicable wage rate determined by the Secretary of Labor pursuant to the Davis-Bacon Act (40 U.S.C. 3141 et seq.) to be prevailing in the locality with respect to such trade;
- (b) An applicable apprentice wage rate based thereon specified in an apprenticeship program registered with the U.S. Department of Labor (DOL) or a DOL- recognized State Apprenticeship Agency; or
- (c) An applicable trainee wage rate based thereon specified in a DOL-certified trainee program.

46. Procurement of Recovered Materials.

- (a) In accordance with Section 6002 of the Solid Waste Disposal Act, as amended by the Resource Conservation and Recovery Act, the Contractor shall procure items designated in guidelines of the Environmental Protection Agency (EPA) at 40 CFR Part 247 that contains the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition. The contractor shall procure items designated in the EPA guidelines that contain the highest percentage of recovered materials practicable unless the Contractor determines that such items: (1) are not reasonably available in a reasonable period of time; (2) fail to meet reasonable performance standards, which shall be determined on the basis of the guidelines of the National Institute of Standards and Technology, if applicable to the item; or (3) are only available at an unreasonable price.
- (b) Paragraph (a) of this clause shall apply to items purchased under this contract where: (1) the Contractor purchases in excess of \$10,000 of the item under this contract; or (2) during the preceding Federal fiscal year, the Contractor: (i) purchased any amount of the items for use under a contract that was funded with Federal appropriations and was within a Federal agency or a State agency of a political subdivision of a State; and (ii) purchased a total of in excess of \$10,000 of the item both under and outside that contract.

Section 3:

Scope of Work and Specifications

Refer to pages following.

SECTION 3

000100 - TABLE OF CONTENTS

INTRODUCTORY INFORMATION

SECTIONS		PAGES
000100	Table of Contents	000100-1 thru 4
000200	List of Drawings	000200-1

TECHNICAL SPECIFICATIONS

DIVISION 01 – GENERAL REQUIREMENTS

SECTIONS

010100	Summary	010100-1 thru 3
010200	Allowances	010200-1 thru 2
010300	Alternates	010300-1
010400	Unit Prices	010400-1
010450	Cutting and Patching	010450-1 thru 3
011530	Change Order Procedures	011530-1 thru 4
012000	Project Meetings	010200-1 thru 3
013000	Submittals	013000-1 thru 5
013700	Schedule of Values	013700-1
014200	Reference Standards and Definitions	014200-1 thru 3
015000	Temporary Facilities	015000-1 thru 4
016000	Materials, Workmanship and Equipment	016000-1 thru 4
016301	Product Substitutions	016301-1 thru 3
017300	Execution	017300-1 thru 5
017419	Construction Waste Management and Disposal	017419-1 thru 6
017700	Closeout Procedures	017700-1 thru 6
017839	Project Record Documents	017839-1 thru 3

DIVISION 02 – EXISTING CONDITIONS

SECTIONS

028300	Lead Paint Awareness	028300-1 thru 12
--------	----------------------	------------------

DIVISION 03 – CONCRETE

SECTIONS

033000 Cast –in-Place Concrete 033000-1 thru 9

DIVISION 05 – METALS

SECTIONS

051200 Structural Steel Framing 051200-1 thru 5

DIVISION 06 – WOOD AND PLASTICS

SECTIONS

061000 Rough Carpentry 061000-1 thru 8
061600 Sheathing 061600-1 thru 4
062013 Exterior Finish Carpentry 062013-1 thru 3
064300 Interior Wood Stairs and Railings 064300-1 thru 4
064600 Interior Wood Trim and Frames 064600-1 thru 4

DIVISION 07 – THERMAL AND MOISTURE PROTECTION

SECTIONS

072100 Thermal Insulation 072100-1 thru 4
072500 Weather Barriers 072500-1 thru 2
073113 Asphalt Shingles 073113-1 thru 5
074633 Vinyl Siding and Soffits 074633-1 thru 4
077100 Roof Specialties 077100-1 thru 6
079200 Joint Sealants 079200-1 thru 6

DIVISION 08 – OPENINGS

SECTIONS

081113 Hollow Metal Doors and Frames 081113-1 thru 6
081417 Wood and Fiberglass Doors 081417-1 thru 3
085200 Vinyl Clad Wood Windows 085200-1 thru 5
087100 Door Hardware 087100-1 thru 6
089516 Wall Vents 089516-1

DIVISION 09 – FINISHES

SECTIONS

092900	Gypsum Board	092900-1 thru 5
093013	Tiling	093013-1 thru 6
096400	Wood Flooring	096400-1 thru 3
099123	Interior Painting	099123-1 thru 4

DIVISION 10 – SPECIALTIES

SECTIONS

102800	Bathroom and Laundry Accessories	102800-1
--------	----------------------------------	----------

DIVISION 12 – FURNISHINGS

SECTIONS

123530	Residential Casework	123530-1
--------	----------------------	----------

DIVISION 22 – PLUMBING

SECTIONS

222326	Plumbing-HVAC-Electrical General Requirements	222326-1 thru 2
224000	Plumbing Performance Specification	224000-1 thru 3
224100	Residential Plumbing Fixtures	224100-1 thru 4

DIVISION 23 – HEATING VENTILATING AND AIR CONDITIONING

SECTIONS

230000	HVAC Performance Specification	230000-1 thru 2
--------	--------------------------------	-----------------

DIVISION 26 – ELECTRICAL

SECTIONS

260000 Electrical Performance Specification
265100 Light Fixtures

260000-1 thru 3
265100-1 thru 2

DIVISION 31 – EARTHWORK

SECTIONS

311000 Site Clearing
312000 Earth Moving
312319 Dewatering

311000-1 thru 4
312000-1 thru 3
312319-1 thru 2

END OF SECTION 000100

SECTION 000200 LIST OF DRAWINGS

The List of Drawings which are dated June 6, 2016 indicated below contain, in addition to the work outlined in the Specifications Sections of the Project Manual, information required to perform the work of the contract.

LIST OF DRAWINGS:

ARCHITECTURAL

- G-001 Cover Sheet
- G-002 Site Plans and Zoning Data
- A-101 Lower Level, First and Second Floor Plans
- A-102 Attic Floor Plan and Exterior Elevations
- A-103 Building Sections, Door Schedule and Details

STRUCTURAL

- S-101 Foundation, First and Second Floor Framing Plans
- S-102 Attic and Roof Framing Plan, Structural Wall Section
- S-103 Shear Wall Plan and Typical Details
- S-104 Details and Sections
- S-105 Structural Notes and Soil Boring Logs

END OF SECTION 000200

SECTION 010100 – SUMMARY

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Project information.
 2. Work covered by Contract Documents.
 3. Work under separate contracts.
 4. Access to site.
 5. Coordination with occupants.
 6. Work restrictions.
 7. Specification and drawing conventions.
 8. Miscellaneous provisions.

1.2 PROJECT INFORMATION

- A. Project Identification: **DOH Application No. 5076. LAA Project No. 1524-27**
1. Project Location:20 Cooper Avenue, Milford, CT, United States
Project sponsor: State of Connecticut Department of CDBG-Community Block Grant Program
- B. Architect: Lothrop Associates LLP, 100 Pearl Street, Hartford CT 06103

1.3 WORK COVERED BY CONTRACT DOCUMENTS

- A. The Work of Project is defined by the Contract Documents and consists of the following:
1. Limited sitework, new utility connections, new foundations, construct new 2 story residence, all related plumbing, mechanical and electrical work.
- B. The Work to be performed by the Owner generally consists of the following:
1. Hazardous Material abatement of existing residence and legal removal of all hazardous materials from site.
 2. Demolition of existing residence and removal from site of all demolition debris.
 3. Future construction of exterior deck and stair.
 4. Future interior construction not indicated in the Contract Documents.
- C. Type of Contract.
1. Project will be constructed under a single prime contract.

1.4 ACCESS TO SITE

- A. General: Contractor shall have full use of Project site except as noted below, for construction operations during construction period. Contractor's use of Project site is limited only by Owner's right to perform work or to retain other contractors on portions of Project.
- B. Condition of Existing Site: Maintain portions of existing site affected by construction operations in good condition throughout construction period. Repair damage caused by construction operations.

1.5 COORDINATION WITH OCCUPANTS

- A. Owner Occupancy: Owner will not occupy site during the construction period.

1.6 WORK RESTRICTIONS

- A. Work Restrictions, General: Comply with restrictions on construction operations.
 - 1. Comply with limitations on use of public streets and with other requirements of authorities having jurisdiction.
- B. On-Site Work Hours: Limit work in the existing building to normal business working hours of 8:00 a.m. to 5:00 p.m., Monday through Friday, unless otherwise indicated.
- C. Noise, Vibration, and Odors: Minimize operations that may result in high levels of noise and vibration, odors, or other disruptions.

1.7 SPECIFICATION AND DRAWING CONVENTIONS

- A. Specification Content: The Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:
 - 1. Imperative mood and streamlined language are generally used in the Specifications. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.
 - 2. Specification requirements are to be performed by Contractor unless specifically stated otherwise.
- B. Division 01 General Requirements: Requirements of Sections in Division 01 apply to the Work of all Sections in the Section 3 Specifications.
- C. Section 2 General Conditions: Requirements of Section 2 General Conditions shall apply to the Work of all Sections in the Section 3 Specifications.

- D. Drawing Coordination: Requirements for materials and products identified on Drawings are described in detail in the Specifications. One or more of the following are used on Drawings to identify materials and products:
1. Terminology: Materials and products are identified by the typical generic terms used in the individual Specifications Sections.
 2. Abbreviations: Materials and products are identified by abbreviations published as part of the U.S. National CAD Standard and scheduled on Drawings.
 3. Keynoting: Materials and products are identified by reference keynotes referencing Specification Section numbers found in this Project Manual.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 010100

SECTION 010200 ALLOWANCES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for allowances.
- B. Itemized records and receipts for allowance items shall be presented to the Architect and DOH for audit. Unused funds shall be credited to the Ct. Department of Housing (DOH).

1.2 ALLOWANCES

- A. Per Conditions of the Contract, the following Allowances shall be included in the Contract Sum, unless modified by the signed Agreement.
 - 1. MAW (Miscellaneous Additional Work)- Include a cash allowance of \$3,000.00 in the Base Bid for Miscellaneous Additional Work as directed by the Architect.
 - 2. Pile Inspection: Include a cash allowance of \$5,000.00 in the Base Bid for pile inspections as directed by the Architect.
 - 3. Tests and Inspections: Include a cash allowance of \$3,000.00 in the Base Bid for concrete and reinforcing tests and inspections as directed by the Architect.
 - 4. Division 8–Openings- Section 087100 “Door Hardware”: Include an allowance sum of \$200 per door in the Base Bid to provide door hardware. The Allowance Amount shall include installation.
 - 5. Division 10–Specialties- Section 102800 “Toilet, Bath and Laundry Accessories" include an allowance sum of \$1000 in the Base Bid to provide toilet, bath and laundry accessories. The Allowance Amount shall include installation
 - 6. Division 12–Furnishings- Section 123530 “Residential Casework”: Include an allowance sum of \$15,000 in the Base Bid to provide kitchen cabinets, bathroom vanities and countertops. The Allowance Amount shall include installation.

7. Division 22–Plumbing- Section 224100 "Residential Plumbing": Include an allowance sum of \$1200 per fixture in the Base Bid to provide plumbing fixtures faucets and trim. For estimating purposes a “fixture “ shall include faucets, finish trim and all required finished fittings. The Allowance Amount shall include installation, Plumbing roughing shall be included in the base bid.
8. Division 26–Electrical- Section 265100 "Light Fixtures": Include an allowance sum of \$150 per fixture in the Base Bid to provide lighting fixtures. Installation and electrical roughing shall be included in the base bid.

END OF SECTION 010200

SECTION 010300 ALTERNATES

PART 1 - GENERAL

1.1 SUMMARY

- . This Section includes administrative and procedural requirements for Alternates.

1.2 DEFINITIONS

- . Definition: An Alternate is an amount proposed by bidders and stated on the Bid Form for certain work defined in the Bidding Requirements that may be added to or deducted from the Base Bid amount if the Owner decides to accept a corresponding change in either the amount of construction to be completed, or in the products, materials, equipment, systems, or installation methods described in the Contract Documents.
 1. The cost or credit for each alternate is the net addition to or deduction from the Contract Sum to incorporate the Alternate into the Work. No other adjustments are made to the Contract Sum.

1.3 PROCEDURES

- . Coordination: Modify or adjust affected adjacent Work as necessary to completely and fully integrate that Work into the Project.
 1. Include as part of each alternate, miscellaneous devices, accessory objects, and similar items incidental to or required for a complete installation whether or not mentioned as part of the Alternate.
- B. Execute accepted alternates under the same conditions as other Work of this Contract.

1.5 SCHEDULE OF ALTERNATES

Where indicated on the Bid Form, state the amount to be added to or deducted from the Base Bid Proposal for:

- A. **ADD ALTERNATE NO. 1 HOUSE DEMOLITION**
State the amount to be added to the base bid amount to perform the entire existing residence demolition, utility disconnects, hazardous material abatement site clearing and debris removal.
Base bid shall not include house demolition, utility disconnects, hazardous material abatement, site clearing and debris removal. This work shall be performed by the Owner.

END OF SECTION 010300

SECTION 010400 - UNIT PRICES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for unit prices.

1.2 DEFINITIONS

- A. Unit price is an amount incorporated in the Agreement, applicable during the duration of the Work as a price per unit of measurement for materials, equipment, or services, or a portion of the Work, added to or deducted from the Contract Sum by appropriate modification, if the scope of Work or estimated quantities of Work required by the Contract Documents are increased or decreased.

1.3 PROCEDURES

- A. Unit prices include all necessary material, plus cost for delivery, installation, insurance, applicable taxes, overhead, and profit.
- B. Owner reserves the right to reject Contractor's measurement of work-in-place that involves use of established unit prices and to have this work measured, at Owner's expense, by an independent surveyor acceptable to Contractor.
- C. List of Unit Prices: A schedule of unit prices is included in the bid form specified elsewhere. Specification Sections referenced in the schedule contain requirements for materials described under each unit price.
- D. Quantity Allowance: Coordinate unit price with allowance adjustment requirements in Section 012100 "Allowances."

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 SCHEDULE OF UNIT PRICES

- A. Refer to unit price schedule on the bid form, specified elsewhere.

END OF SECTION 010400

SECTION 010450 - CUTTING AND PATCHING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General Conditions apply to this Section.
- B. Refer to other Sections of these Specifications, for specific requirements and limitations applicable to cutting and patching individual parts of the Work.

1.2 DESCRIPTION OF WORK

- A. All cutting required for the installation of building systems, such as for Electrical work and other trades, shall be performed by the parties requiring same for the installation of their work, unless otherwise specifically indicated or noted to be performed otherwise.
- B. The Construction Contract includes all patching of building materials and surfaces affected by the cutting and removals for all trades and subcontracts, except for special patching which must be performed by mechanical and electrical trades, such as patching of ductwork, piping and other mechanical and electrical systems.

1.3 CUTTING OF FINISH MATERIALS

- A. When it is necessary to have finish materials cut, drawings shall be submitted by the Contractor showing the proposed changes and indicating the finished conditions. The cutting shall not be done until the Architect has approved the drawings.
- B. Structural Work: Do not cut and patch structural elements in a manner that would reduce the load-carrying capacity or load deflection ratio. Obtain approval of the cutting and patching proposal before cutting and patching structural elements.
- C. Visual Requirements: Do not cut and patch construction exposed on the exterior or in occupied spaces, in a manner that would reduce the building's aesthetic qualities, or result in visual evidence of cutting and patching. Remove and replace Work cut and patched in a visually unsatisfactory manner.
- D. Materials: Use materials identical to existing materials.
- E. Inspection: Before cutting, examine surfaces to be cut and patched and conditions under which cutting and patching is to be performed. Take corrective action before proceeding, if unsafe or unsatisfactory conditions are encountered.
- F. Temporary Support: Provide temporary support of Work to be cut.

- G. Protection: Protect construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions that might be exposed during cutting and patching operations.
- H. Avoid interference with use of adjoining areas or interruption of free passage to adjoining areas.

1.4 PERFORMANCE

- A. Employ skilled workmen to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time and complete without delay.
- B. Cut existing construction to provide for the installation of other components or the performance of other construction activities and the subsequent fitting and patching required to restore surfaces to their original condition.
- C. Cutting: Cut using methods least likely to damage elements to be retained or adjoining construction. Where possible review procedures with the original installer; comply with the original installer's recommendations.
- D. Where cutting is required use hand or small power tools designed for sawing or grinding, not hammering and chopping. Cut holes and slots to size required with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use. To avoid marring existing finished surfaces, cut or drill from the exposed or finished side into concealed surfaces.
- E. Cut through concrete and masonry using a cutting machine such as a carborundum saw or diamond core drill.
- F. Comply with requirements of applicable sections of Division 31 where cutting and patching requires excavating and backfilling.

1.5 PATCHING

- A. Patch with durable seams that are as invisible as possible. Comply with specified tolerances.
- B. Where feasible, inspect and test patched areas to demonstrate integrity of the installation.
- C. Restore exposed finishes of patched areas and extend finish into retained adjoining construction in a manner that will eliminate evidence of patching and refinishing.
- D. Where patching occurs in a smooth painted surface, extend final paint coat over entire unbroken plane containing the patch, after the patched area has received primer and second coat.

- E. Cleaning: Thoroughly clean areas and spaces where cutting and patching is performed or used as access. Remove paint, mortar, oils, putty and similar items. Thoroughly clean piping, conduit and similar features before painting or finishing is applied.

PART 2 - PRODUCTS Not Applicable

PART 3 - EXECUTION Not Applicable

END OF SECTION 010450

SECTION 011530 - CHANGE ORDER PROCEDURES

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Changes in the Work, in the Contract Sum, in the Contract Time of Completion, or any combination thereof, as described in written Change Orders signed by the Owner, Architect and Contractor and issued after execution of the Contract, in accordance with the provisions of this Section.
- B. Related Work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, and Sections in Division 01 of these Specifications.

1.2 QUALITY ASSURANCE

- A. Include within the Contractor's quality assurance program such measures as are needed to assure familiarity of the Contractor's staff and employees with these procedures for processing Change Order data.
- B. Change Order Form: AIA Document G-701 shall be used for all change orders.

1.3 SUBMITTALS

- A. Make submittals directly to the Architect at the address shown on the Project Directory in the Project Manual.
- B. Submit the number of copies called for under the various items listed in the Section.

1.4 PRODUCT HANDLING

- A. Maintain a "Register of Bulletins and Change Orders" at the job site, accurately reflecting current status of all pertinent data.
- B. Make the Register available to the Architect for review at his request.

1.5 PROCESSING CHANGES INITIATED BY THE OWNER

- A. Should the Owner contemplate making a change in the Work or a change in the Contract Time of Completion, the Architect will issue a Directive to the Contractor.
 - 1. Directives shall be dated and numbered in sequence.
 - 2. Directives shall describe the contemplated changes, and carry one of the following instructions to the Contractor:

- a. Make the described change in the Work at no change in the Contract Sum and no change in the Contract Time of Completion.
 - b. Make the described change in the Work, credit or cost for which will be approved by the Owner and/or Architect.
 - c. Promptly advise the Architect as to credit or cost proposed for the described change. This is not an authorization to proceed with the change.
- B. If the Contractor has been directed by the Architect to make the described change in the Work at no change in the Contract Sum and no change in the Contract Time of Completion, but the Contractor wishes to make a claim for one or both of such change, the Contractor shall proceed with the change and shall notify the Architect.
- C. If the Contractor has been directed by the Architect to make the described change subject to later determination of cost or credit, the Contractor shall:
1. Take such measures as needed to make the change.
 2. Consult with the Architect and reach agreement on the most appropriate method for determining credit or cost for the change.
- D. If the Contractor has been directed by the Architect to promptly advise him as to credit or cost proposed for the described change, the Contractor shall:
1. Analyze the described change and its impact on costs and time
 2. Secure the required information and forward it to the Architect for review.
 3. Meet with the Architect as required to explain costs and when appropriate, determine other acceptable ways to achieve the desired objective.
 4. Alert pertinent personnel and subcontractors as to the impending change and, to the maximum extent possible, avoid such work as would increase the Owner's cost for making the change, advising the Architect in writing when such avoidance no longer is practicable.

1.6 PROCESSING CHANGES INITIATED BY THE CONTRACTOR

- A. Should the Contractor require further information or explanation to interpret Contract Documents as to Architect's intent, he shall request such clarification. The Contractor's failure to do so, and subsequent work performed and rejected as a result of his misinterpretation of the Contract Documents will not be cause for a change in the Contract Sum.
- B. Should the Contractor discover a discrepancy among the Contract Documents, a concealed condition or other cause for suggesting a change in the Work, a change in the Contract Sum, or a change in the Contract Time of Completion, he shall notify the Architect as required by pertinent provisions of the Contract Documents.
- C. Upon agreement by the Architect that there is reasonable cause to consider the Contractor's proposed change, the Architect will issue a Directive in accordance with the provisions described in Article 1.05 above.

1.7 PROCESSING DIRECTIVE

- A. Make written reply to the Architect in response to each Directive.
 - 1. State proposed change in the Contract Sum, if any.
 - 2. State proposed change in the Contract Time of Completion if any.
 - 3. Clearly describe other changes in the Work required by the proposed change, or desirable therewith, if any.
 - 4. Include full backup data such as subcontractor's letter or proposal or similar information.
 - 5. Submit this response in single copy.
- B. When cost or credit for the change has been agreed upon the Owner and the Contractor, the Architect will issue a "Change Order" to the Contractor.

1.8 PROCESSING CHANGE ORDERS

- A. Change Orders shall be dated and numbered in sequence, and prepared on the forms specified.
- B. Each Change Order shall describe the change or changes, refer to the Directive or Directives involved, and shall be signed by the Owner and the Architect.
- C. The Architect will issue four copies of each Change Order to the Contractor.
 - 1. The Contractor shall sign all four copies and return three copies to the Architect.
 - 2. The Architect will retain one signed copy and forward two signed copies to the Owner.
- D. Should the Contractor disagree with the stipulated change in Contract Sum or change in Contract Time of Completion, or both:
 - 1. The Contractor promptly shall return three copies of the Change Order, unsigned by him, to the Architect with a letter signed by the Contractor and stating the reason or reasons for the Contractor's disagreement.
 - 2. The Contractor's disagreement with the Change Order shall not in any way relieve the Contractor of his responsibility to proceed with the change as ordered and to seek settlement of the dispute under applicable provisions of the Contract Documents.

1.9 CONTRACTOR'S OVERHEAD AND PROFIT ON CHANGE ORDERS

- A. Work performed by the General Contractor: 15% Overhead and Profit.
- B. Work performed by a Subcontractor of the General Contractor: 7 ½% Overhead and Profit for the General Contractor.

The above rates shall apply to all Change Orders with dollar values of \$25,000.00 or less. Rates for Change Orders with dollar values in excess of \$25,000.00 shall be capped at 12%.

PART 2- PRODUCTS - Not Used

PART 3- EXECUTION - Not Used

END OF SECTION 011530

SECTION 012000 - PROJECT MEETINGS

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: To enable orderly review during progress of the Work, and to provide for systematic discussions of issues, the Architect will conduct project meetings throughout the construction period.

1.2 AUTHORITY

- A. For those persons designated by the Contractor to attend and participate in project meetings, provide required authority committing the Contractor to solutions agreed upon in the project meetings

1.3 AGENDA

- A. Agenda items: To the maximum extent practicable, advise the Architect at least 24 hours in advance of project meetings regarding items to be added to the agenda.

B. MEETING REPORT

- 1. The Architect will prepare written reports of each project meeting, and will furnish three copies to the Contractor and State of Connecticut Department of Housing.
- 2. Recipients of copies may make and distribute copies as necessary.

1.4 MEETING SCHEDULE

- A. Except as noted below for Preconstruction Meeting, project meetings shall be held monthly.
- B. Coordinate as necessary to establish mutually acceptable schedule for meetings.

1.5 MEETING LOCATION

- A. Unless otherwise required or mutually agreed by all parties, meetings shall be held at the job site.

1.6 PRECONSTRUCTION MEETING

- A. Preconstruction Meeting shall be scheduled within ten (10) working days after the Owner has issued the Notice to Proceed.
 - 1. Provide attendance by authorized representatives of the Contractor and major subcontractors.
 - 2. The Architect will advise other interested parties, including the Owner, State of Connecticut Department of Housing., and request their attendance.

B. Minimum Agenda: Data will be distributed and discussed on at least the following items:

1. Organizational arrangement of Contractor's forces and personnel, and those of subcontractors, materials suppliers, and Architect.
2. Channels and procedures for communications.
3. Construction schedule, including sequence of critical work.
4. Contract documents, including distribution of required copies of original Documents and revisions.
5. Processing of Shop Drawings and other data submitted to the Architect for review.
6. Processing of Bulletins, Field Decisions, and Change Orders.
7. Rules and regulations governing performance of the Work.
8. Procedures for security, quality control, housekeeping, and related matters.

1.7 PROJECT MEETINGS

A. Attendance:

1. To the maximum extent possible, assign the same person or persons to represent the Contractor at project meetings throughout progress of the Work.
2. Subcontractors, material suppliers, and others may be invited to attend those project meetings when their interests are involved.

B. Minimum Agenda:

1. Review, revise as necessary, and approve minutes of previous meetings.
2. Review progress of the Work since last meeting, including status of submittals for approval.
3. Identify problems, which impede planned progress.
4. Develop corrective measures and procedures to regain planned schedule.
5. Complete other current business.

C. Revisions to Minutes:

1. Unless published minutes are challenged in writing prior to the next regularly scheduled progress meeting, they will be accepted as properly stating the activities and decisions of the meeting.

1.8 PROJECT CORRESPONDENCE

A. All correspondence concerning the project, which is being submitted to the Owner or Architect, shall clearly be identified meeting the following requirements:

1. Clients Name
2. CIP Year
3. Project Site Name
4. Architects Project Title

5. Architects Project # _____
6. DOH Application # _____

B. All correspondence not conforming to the above requirements will be discarded.

PART 2- PRODUCTS - Not Applicable

PART 3- EXECUTION - Not Applicable.

END OF SECTION 012000

SECTION 013000 SUBMITTALS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section specifies requirements for handling Submittals. Refer to related provisions of the General and Supplementary Conditions.
- B. General Procedures: Coordinate submittal preparation with performance of construction activities, and with purchasing or fabrication, delivery, and other submittals and related activities. Transmit in advance of performance of related activities to avoid delays.
 - 1. Coordinate transmittal of different submittals for related elements so processing will not be delayed by the need to review concurrently for coordination. The Architect reserves the right to withhold action on a submittal requiring coordination until related submittals are received.
 - 2. Processing: Allow two weeks for initial review. Allow more time if processing must be delayed for coordination with other submittals. The Architect will advise the Contractor when a submittal must be delayed for coordination. Allow two weeks for reprocessing each submittal.
 - a. No extension of time will be authorized because of failure to transmit submittals sufficiently in advance of the Work to permit processing.
 - 3. Submittal Preparation: Place a label or title block on each submittal for identification. Provide a 4" x 10" space on the label or beside the title block on Shop Drawings to record Contractor's review and approval markings and action taken. Include the following information on the label for processing and recording action taken.
 - a. Project name.
 - b. Date.
 - c. Name and address of Architect.
 - d. Name and address of Contractor.
 - e. Name and address of subcontractor.
 - f. Name and address of supplier.
 - g. Name of manufacturer.
 - h. Submission number.
- C. Contractor's Review: The Contractor will examine the submission and indicate the results of his review with a stamp with his approval representing that he has checked and verified the submission with the requirements of the work and the Contract Documents on the submission made to the Architect. He will retain one copy of all submissions for his review, and will forward the remaining copies of each shop drawing and catalog cuts, manufacturer's specifications, etc., to the Architect for review, with a copy of the trans-

mittal to the Owner's representative. Submittals which do not bear the Contractor's review stamp will be returned with no action taken.

Submittal Transmittal: Package submittals appropriately for transmittal and handling.

Transmit with a transmittal form. Submittals received from other than the Contractor will be returned without action. Record requests for data and deviations from Contract

Documents. Include Contractor's certification that information complies with Contract Documents.

- D. Contractor's Construction Schedule: Submit a fully developed, bar-chart type construction schedule, within 20 days of the date established for Commencement of the Work. Provide a separate bar for each construction activity and a vertical line to identify the first working day of each week. Use the breakdown of units of Work as indicated in the "Schedule of Values".
1. Prepare the schedule on reproducible media, of sufficient width to show data for the entire construction period.
 2. Secure commitments for performing critical construction operations from parties involved. Coordinate each activity with other activities and show in proper sequence; include minor elements involved in the construction sequence. Indicate sequences necessary for completion of related portions.
 3. Coordinate the Construction Schedule with the Schedule of Values, list of subcontracts, Submittal Schedule, progress reports, payment requests and other schedules.
 4. Indicate completion in advance of the date established for Substantial Completion. Indicate Substantial Completion on the Schedule to allow time for the Architect's procedures necessary for certification of Substantial Completion.
- E. Phasing and Area Separations: If applicable, provide a separate time bar to identify each construction phase or area for each major part of the Work. Indicate where each element must be sequenced with other activities.
- F. Submittal Schedule: Submit the Submittal Schedule within 10 days of the Construction Schedule. Coordinate the Schedule with the list of subcontracts, Schedule of Values and list of products as well as the Construction Schedule.
1. Prepare the Schedule in chronological order; include submittals required during the first 90 days of construction. Provide the following information:
 - a. Scheduled date for the first submittal.
 - b. Related Section number.
 - c. Name of subcontractor.
 - d. Description of the construction element covered.
 - e. Scheduled date of the Architect's final release.
- G. Distribution of Schedules: Distribute copies of the Construction and Submittal Schedules to the Architect, Owner, subcontractors, and other parties required to comply with scheduled dates. Post copies in the temporary field office. When revisions are made, distribute to the same parties and post in the same locations.

1. Updating: Revise and issue each Schedule after each meeting or activity, where revisions have been made.
- H. Shop Drawings: Submit new information, drawn to accurate scale. Indicate deviations from Contract Documents. Do not reproduce Contract Documents or copy standard information as the basis of Shop Drawings. Fax copies are unacceptable as shop drawings. Include the following information:
1. Dimensions.
 2. Identification of products, materials and finishes included.
 3. Notation of coordination requirements.
 4. Notation of dimensions established by field measurement.
 5. Sheet Size: Except for templates, patterns and similar full-size Drawings, submit Shop Drawings on sheets at least 8-1/2" x 11" but no larger than 30" x 42".
 6. Submittal: Submit six correctable copies for review; five copies will be returned.
 7. Do not use Shop Drawings without a final stamp indicating action taken in connection with construction.
- I. Product Data: Collect Product Data into a single submittal for each element or system. Mark each copy to show applicable choices and options. Where Product Data includes information on several products, some of which are not required, mark copies to indicate the applicable information. Fax copies are unacceptable.
1. Include the following information:
 - a. Manufacturer's printed recommendations.
 - b. Compliance with recognized trade association standards.
 - c. Compliance with recognized testing agency standards.
 - d. Application of testing agency labels and seals.
 - e. Notation of dimensions verified by field measurement.
 - f. Notation of coordination requirements.
- J. Submittals:
1. Submit one copy in PDF format to the Architect, and one copy of the transmittal to the Owner. The Architect will return one PDF file to the Contractor, and a copy to the Owner, marked with action taken and corrections or modifications required unless instructed otherwise by the Owner's representative.
 2. Distribution: Furnish copies of final submittal to the Owner, installers, and others required for performance of construction activities. Show distribution on transmittal forms. Do not proceed with installation until an applicable copy of Product Data is in the installer's possession.
 3. Do not permit use of unmarked copies of Product Data in connection with construction.
 4. Fax copies are unacceptable.

- K. Samples: Submit 4 full-size Samples to the Architect, cured and finished as specified and identical to the product proposed. Mount, display, or package Samples to facilitate review. Prepare Samples to match the Architect's Sample.
1. Include the following information tagged on one face, with the other face reserved for Architect's action stamp.
 - a. Project name.
 - b. Date.
 - c. Architect's name.
 - d. Contractor's name.
 - e. Generic description.
 - f. Source.
 - g. Product name or name of manufacturer.
 - h. Compliance with recognized standards.
 - i. Availability and delivery time.
 2. Submit Samples for review of kind, color, pattern, and texture, for a final check of these characteristics, and a comparison of these characteristics between the final submittal and the component as delivered and installed. Where variations are inherent in the product, submit multiple units that show limits of the variations.
 3. Preliminary submittals: Where Samples are for selection of characteristics from a range of choices, submit a full set of choices for the product. Preliminary submittals will be reviewed and returned indicating selection and other action.
 4. Submittals: Except for Samples illustrating assembly details, workmanship, fabrication techniques, connections, operation and similar characteristics, submit 4 sets; two will be returned marked with the action taken. Maintain one Sample set at the Project site, for quality comparisons.
 - a. Unless noncompliance with Contract Document provisions is observed, the submittal may serve as the final submittal.
 - b. Sample sets may be used to obtain final acceptance of the construction associated with each set.
 5. Distribution: Prepare additional sets for Owner, subcontractors, manufacturers, fabricators, installers, and others as required for performance. Show distribution on transmittal forms.
- L. Architect's Action: Except for submittals for record, information or similar purposes, where action and return is required, the Architect will review each submittal, mark to indicate action taken, and return.
1. The Architect will indicate the results of his review of the Contractor's shop drawings/catalog cuts by marking them as follows:

NO EXCEPTIONS TAKEN: Submittal may be released for fabrication, erection, construction and incorporation in the work without further checking, approval or submission of shop drawings, catalog cuts, etc.

MAKE CORRECTIONS NOTED: Submittal may be released for fabrication, erection, construction and incorporation in the work subject to notes, corrections shown thereon which have been made by the Architect or his Consultants.

AMEND AND RESUBMIT: Shop drawings, catalog cuts, etc., so marked must be corrected or changed, and copies sent to the Architect for record purposes, in the number and forms required by him.

REJECTED-SEE REMARKS: The items shown in the submittal are rejected for fabrication and their incorporation into the work is not permitted. Submittals so marked will be returned to the Contractor for corrections and/or the addition of more details, and resubmission will be required.

2. The Architect's review and action taken of a separate item shall not indicate he has reviewed and acted upon the assembly in which the item functions. The Architect's review and action does not relieve the Contractor from responsibility for errors or omissions in the Shop Drawings.
 3. In the event of returns for correction and re-submissions, all alterations, changes and additions of new information beyond the scope of the Architect's corrective notations, shall be suitably marked on the shop drawing or drawings and noted in the accompanying transmittal or resubmission.
 4. Record Submittals: See other sections for requirements, if any, to submit complete set of shop drawings, product data and samples of in-place work for Owner's records.
- M. Electronic Submittals: Shop drawings may be submitted in electronic format, subject to all requirements of this section. Procedures for electronic submittals shall be established with the Owner and Architect prior to commencement of construction.
- N. Electronic Copies of Construction Documents: The Contractor may request from the Architect electronic files (CAD files) for use in preparing shop drawings. The Contractor shall make requests in writing together with a specific list of drawings and shall execute a release form provided by the Architect.

PART 2 - PRODUCTS - Not Used

PART 3 - EXECUTION - Not Used

END OF SECTION 013000

SECTION 013700 - SCHEDULE OF VALUES

PART 1 - GENERAL

1.01 DESCRIPTION

- A.** Work included: When requested by Architect, provide a detailed breakdown of the agreed Contract Sum showing values allocated to each of the various parts of the Work, as specified herein and in other provisions of the Contract Documents.
- B.** Related Work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, and Sections in Division 1 of these Specifications.

1.02 QUALITY ASSURANCE

- A.** Use required means to assure arithmetical accuracy of the sums described.
- B.** When so required by the Architect, provide copies of the subcontracts or other data acceptable to the Architect, substantiating the sums described.
- C.** When requested by the Architect, provide a list of sub contractors to be used on the project.

1.03 SUBMITTALS

- A.** Prior to the first application for payment, submit a proposed Schedule of Values to the Architect.
 - 1. Meet with the Architect and determine additional data, if any, required to be submitted.
 - 2. Secure the Architect's approval of the Schedule of Values prior to submitting first Application for Partial Payment.

PART 2 - PRODUCTS - Not Used

PART 3 - EXECUTION - Not Used

END OF SECTION 013700

SECTION 014210 REFERENCE STANDARDS AND DEFINITIONS

PART 1 - GENERAL

1.1 SUMMARY

Section includes administrative and procedural requirements for Reference Standards and Definitions.

1.2

A. Definitions: Basic contract definitions are included in the Conditions of the Contract.

1. "Indicated" refers to graphic representations, notes, or schedules on the Drawings; or to other paragraphs or schedules in the Specifications and similar requirements in the Contract Documents. Terms such as "shown," "noted," "scheduled," and "specified" are used to help the user locate the reference. Location is not limited.
2. "Directed," "requested," "authorized," "selected," "approved," "required," and "permitted" mean directed by the Architect, requested by the Architect, and similar phrases.
3. "Approved," when used in conjunction with the Architect's action on the Contractor's submittals, applications, and requests, is limited to the Architect's duties and responsibilities as stated in the Conditions of the Contract.
4. "Regulations" includes laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, as well as rules, conventions, and agreements within the construction industry that control performance of the Work.
5. "Furnish" means to supply and deliver to the Project site, ready for unloading, unpacking, assembly, installation, and similar operations.
6. "Install" describes operations at the Project site including the actual unloading, temporary storage, unpacking, assembling, erecting, placing, anchoring, applying, working to dimension, finishing, curing, protecting, cleaning, and similar operations.
7. "Provide" means to furnish and install, complete and ready for the intended use.
8. "Installer" is the Contractor or another entity engaged by the Contractor, either as an employee, subcontractor, or contractor of lower tier, to perform a particular construction activity, including installation, erection, application, or similar operations. Installers are required to be experienced in the operations they are engaged to perform.
9. The term "experienced," when used with the term "installer," means having successfully completed a minimum of five previous projects similar in size and scope to this Project; being familiar with the special requirements indicated; and having complied with requirements of authorities having jurisdiction.

10. Using a term such as "carpentry" does not imply that certain construction activities must be performed by accredited or unionized individuals of a corresponding generic name, such as "carpenter.
11. "Project site" is the space available to the Contractor for performing construction activities, either exclusively or in conjunction with others performing other work as part of the Project. The extent of the Project site is shown on the Drawings and may or may not be identical with the description of the land on which the Project is to be built.
12. "Testing Agencies": A testing agency is an independent entity engaged to perform specific inspections or tests, either at the Project site or elsewhere, and to report on and, if required, to interpret results of those inspections or tests.

1.3 SPECIFICATION FORMAT

- A. These Specifications are organized into Divisions and Sections based on the multiple division format and CSI/CSC's "Master Format" 2015 version numbering system.

1.4 SPECIFICATION CONTENT

- A. These Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:
 - B. Abbreviated Language: Language used in the Specifications and other Contract Documents is abbreviated. Words and meanings shall be interpreted as appropriate. Words implied, but not stated, shall be interpolated as the sense requires. Singular words shall be interpreted as plural and plural words interpreted as singular where applicable as the context of the Contract Documents indicates.
 - C. Streamlined language is generally used in the Specifications. Requirements expressed in the imperative mood are to be performed by the Contractor. At certain locations in the Section Text, subjective language is used for clarity to describe responsibilities that must be fulfilled indirectly by the Contractor or by others when so noted.
 - D. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.
 - E. Applicability of Standards: Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.
 - F. Publication Dates: Comply with standards in effect as of the date of the Contract Documents.
 - G. Copies of Standards: Copies of applicable standards are not bound with the Contract Documents. Where copies of standards are needed to perform a required construction ac-

tivity, the Contractor shall obtain copies directly from the publication source and make them available on request.

- H. Abbreviations and Names: Where abbreviations and acronyms are used in the Specifications or other Contract Documents, they mean the recognized name of the trade association, standards-producing organization, authorities having jurisdiction, or other entity applicable to the context of the text provision. Refer to Gale Research's "Encyclopedia of Associations" or Columbia Books' "National Trade & Professional Associations of the U.S.," which are available in most libraries.

1.5 PERMITS, LICENSES, AND CERTIFICATES

- A. Permits, Licenses, and Certificates: For the Owner's records, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence, records, and similar documents, established for compliance with standards and regulations bearing on performance of the Work.

PART 2 – PRODUCTS - Not Used

PART 3 – EXECUTION - Not Used

END OF SECTION 014200

SECTION 015000 - TEMPORARY FACILITIES

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Provide temporary facilities needed for the Work including but not necessarily limited to:
1. Temporary utilities such as heat, water, electricity, telephone and emergency power.
 2. Field Office.
 3. Fire Protection
 4. Sanitary facilities.
 5. Enclosures such as tarpaulins, barricades, platforms, walking surfaces, and other items required to maintain access to site and construction areas.
 6. Waste disposal facilities.
 7. Temporary fencing.
 8. Temporary erosion and sedimentation control.
 9. On-site storage facilities.
- B. Related Work:
1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, and Sections in Division 01 of these Specifications.
 2. Equipment furnished by subcontractors shall comply with requirements of applicable safety regulations. Equipment normally furnished by the individual trades for execution of their own portions of the Work are not part of this Section.

1.2 PRODUCT HANDLING

- A. Maintain temporary facilities and controls in proper and safe condition throughout progress of the Work.

PART 2 – PRODUCTS - Not Applicable.

PART 3- EXECUTION

3.1 UTILITIES

- A. Water:
1. Provide all necessary temporary piping and hoses. Upon completion of the Work, remove temporary water facilities.
Contractor shall make arrangements with the local Utility Co. for temporary water facilities.

B. Electricity:

1. Provide all necessary temporary wiring. Upon completion of the Work, remove temporary electrical facilities.
2. Provide area distribution/outlet boxes so located that the individual trades may furnish and use 100 ft. maximum length extension cords safely to obtain power.
3. Contractor shall make arrangements with the local Utility Co. for temporary power and pay all costs associated with temporary power.

C. Heating: Provide and maintain heat necessary for proper conduct of operations and protection of the Work. The Contractor is advised that if portions of the work are scheduled to be performed during winter months, temporary heat shall be provided by the Contractor.

D. Telephone and Data:

1. Make necessary arrangements and pay costs for installation and operation of telephone and data service to the Contractor's location at the site.

E. Lighting:

1. The Contractor shall install and maintain temporary lighting of 1/2 foot candles of illumination in the temporary facilities during entire duration of construction.
 - a. When disrupting existing site lighting, maintain temporary light of 1/2 foot candles of illumination during entire duration of disruption.

3.2 FIELD OFFICE

- A. The Contractor shall provide a temporary field office as necessary for its construction operations.

3.3 FIRE PROTECTION

- A. Provide and maintain fire extinguishers in sufficient sizes and quantities as required by project size and authorities having jurisdiction.

3.4 SANITARY FACILITIES:

- A. Provide temporary sanitary facilities in the quantity required for use by all Contractor and subcontractor personnel.
- B. Maintain in a sanitary condition at all times.

- C. Contractor shall provide portable toilet facilities for use during construction period.

3.4 ENCLOSURES

- A. Provide and maintain for the duration of construction all scaffolds, tarpaulins, canopies, warning signs, steps, platforms, bridges, and other temporary construction necessary for proper completion of the Work in compliance with pertinent safety and other regulations.

3.5 WASTE DISPOSAL FACILITIES

- A. Comply with requirements specified in Section 017419 "Construction Waste Management and Disposal".

3.6 TEMPORARY FENCING

- A. Provide and maintain for the duration of construction a temporary fence and/or barricade of design and type needed to prevent entry onto the Work by the public.
1. Provide a 6 foot high temporary chain link fence to enclose the entire property during the construction period. Provide locked access gates at the street for construction access.
 2. Remove the temporary fence in its entirety at the conclusion of the construction period, or when directed by the Architect.

3.7 TEMPORARY EROSION AND SEDIMENTATION CONTROL

- A. Environmental Protection: Provide protection, operate temporary facilities, and conduct construction as required to comply with environmental regulations and that minimize possible air, waterway, and subsoil contamination or pollution or other undesirable effects.
- B. Temporary Erosion and Sedimentation Control: Comply with requirements of 2003 EPA Construction General Permit or authorities having jurisdiction, whichever is more stringent and requirements specified in Section 311000 "Site Clearing."
- C. Temporary Erosion and Sedimentation Control: Provide measures to prevent soil erosion and discharge of soil-bearing water runoff and airborne dust to undisturbed areas and to adjacent properties and walkways, according to requirements of 2003 EPA Construction General Permit or authorities having jurisdiction, whichever is more stringent.
- D. Stormwater Control: Comply with requirements of authorities having jurisdiction. Provide barriers in and around excavations and subgrade construction to prevent flooding by runoff of stormwater from heavy rains.

3.8 MAINTENANCE AND REMOVAL

- A. Maintain temporary facilities and controls as long as needed for safe and proper completion of the Work.
- B. Remove such temporary facilities and controls as rapidly as progress of the Work will permit, or as directed by the Architect.
- C. Repair or replace existing site elements (lawns, landscaping, shrubbery, paving, etc.) damaged by the work of this section at no additional cost to the Owner.
- D. Repair or replace existing building elements (exterior walls, walks, steps, etc.) damaged by the work of this section at no additional cost to the Owner.

END OF SECTION 015000

SECTION 016000 - MATERIALS, WORKMANSHIP AND EQUIPMENT

PART 1 - GENERAL

1.1 SUMMARY

- A. Administrative and procedural requirements governing the Contractor's selection of products for use in the Project and of workmanship.
- B. "Products" are items purchased for incorporation in the Work, whether purchased for the Project or taken from previously purchased stock.
- C. "Named Products" are items identified by manufacturer's product name, including make or model designation indicated in the manufacturer's product literature.
- D. "Materials" are products that are shaped, cut, worked, mixed, finished, refined or otherwise fabricated, processed, or installed to form a part of the Work.
- E. "Equipment" is a product with operational parts, whether motorized or manually operated, that requires service connections such as wiring or piping.
- F. Source Limitations: To the fullest extent possible, provide products of the same kind, from a single source.
 - 1. When the Contractor has the option of selecting between two or more products, the product selected shall be compatible with products previously selected. The Contractor is responsible for providing products and construction methods that are compatible with products and construction methods of all trades.
- G. Nameplates: Except for required labels and operating data, do not attach manufacturer's nameplates or trademarks on surfaces exposed to view in occupied spaces or on the exterior.
 - 1. Equipment Nameplates: Provide a permanent nameplate on each item of service-connected or power-operated equipment. Locate on an inconspicuous accessible surface. The nameplate shall contain the following information and essential operating data relative to its characteristics and maintenance.
- H. Product Delivery, Storage, and Handling: Deliver, store and handle products in accordance with manufacturer's recommendations, using methods that will prevent damage, deterioration and loss.
 - 1. Schedule delivery to minimize long-term storage and prevent overcrowding construction spaces. Coordinate with installation to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deteri-

- oration, theft and other losses.
2. Deliver products in manufacturer's original sealed container or packaging system, complete with labels and instructions for handling, storing, unpacking, protecting and installing.
 3. Inspect products on delivery to ensure compliance with Contract Documents, and to ensure that products are undamaged and properly protected.
 4. Store products to facilitate inspection and measurement of quantity or counting of units. Store heavy materials away from the structure in a manner that will not endanger supporting construction.
 5. Store products subject to damage by the elements above ground, under cover in a weathertight enclosure, with ventilation adequate to prevent condensation. Maintain temperature and humidity within range required by manufacturer's instructions.
- I. Product Selection: Provide products that comply with the Contract Documents, are undamaged and unused at installation.
1. Provide products complete with all accessories, trim, finish, safety guards and other devices and details needed for a complete installation and for the intended use and effect.
 2. Standard Products: Where available, provide standard products of types that have been produced and used successfully in similar situations on other projects.
 3. Non-Proprietary Specifications: When Specifications list products or manufacturers that are available and may be used, but do not restrict the Contractor to use of these products only, the Contractor may propose any product that complies with Contract requirements. Comply with provisions for "substitutions" to obtain approval for use of an unnamed product.
- J. "Or Equal": When required by statute, any reference in the Specifications to any article, device, product, material, fixture, form or type of construction by name, make or catalog number, such reference shall be interpreted as establishing a standard of quality and shall not be construed as limiting competition; and the Contractor, in such cases, may use any article, device, product, material, fixture, form or type of construction which in the judgment of the Westchester Medical Center and Architect, expressed in writing, is equal to that specified. The Architect shall be the sole and conclusive judge as to the quality of such substitution. Comply with provisions for "substitutions" to obtain approval for use of an unnamed product.
- K. Descriptive Specification Requirements: Where Specifications describe a product, listing characteristics required, with or without use of a brand name, provide a product that provides the characteristics and otherwise complies with requirements.
1. Performance Specification Requirements: Where Specifications require compliance with performance requirements, provide products that comply and are recommended for the application. Manufacturer's recommendations may be contained in product literature, or by certification of performance.

2. Compliance with Standards: Where Specifications require compliance with a standard, select a product that complies with the standard specified.
 3. Visual Matching: Where Specifications require matching a Sample, the Architect's decision on whether a proposed product matches is final. Where no product matches and complies with other requirements, comply with provisions for "substitutions" for selection of a matching product in another category.
 4. Visual Selection: Where requirements include the phrase "...as select a product that complies with other requirements. The Architect will select color, pattern and texture from the product line selected.
- L. Should the Federal Government, because of Declaration of an Emergency, or other cause, establish controls over the use of certain construction materials, then each Contractor, immediately after signing Contract, or immediately after such Declaration of an Emergency, shall furnish the Architect with an itemized list of all critical materials required for use on the Project. For each item, the quantity and approximate date on which delivery will be required shall be indicated.
- M. Installation of Products: Comply with manufacturer's instructions and recommendations for installation of products. Anchor each product securely in place, accurately located and aligned with other Work. Clean exposed surfaces and protect to ensure freedom from damage and deterioration at time of Substantial Completion.
- N. Workmanship:
1. Work shall be performed by persons who are skilled and experienced in their respective trades. All installations shall operate properly and in a first class manner.
 2. Workmanship shall conform to best trade practices. Finished surfaces shall be plumb and level straight and free from imperfections, set firmly to accurate measurements.
 3. Surfaces that will be covered shall be cleaned of foreign matter and loose material. Surfaces shall be clean and free from imperfections and defects that would affect the covering material. Surface defects shall be repaired before applying the covering material.
 4. Material shall be applied and/or installed under proper climatic conditions when they may be affected by temperature, moisture, humidity or dust.
 5. Before any operation is started, adjoining or backup work shall be examined with care to ascertain its fitness to receive the work about to be started. All unsatisfactory conditions shall be corrected. If such unsatisfactory conditions are caused by the work of a separate contractor they shall be directed to the Architect's attention for his decision. Starting the operation shall constitute tacit assurance that previously installed work is correct and shall be considered a waiver of any claim based upon unsuitable conditions.

PART 2 - PRODUCTS - Not Used

PART 3 - EXECUTION - Not used

END OF SECTION 01600

SECTION 016310 - PRODUCT SUBSTITUTIONS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section specifies administrative and procedural requirements for handling requests for substitutions made after award of the Contract.

1.2 SUBSTITUTIONS

- A. Substitutions: Requests for changes in products, materials, equipment, and methods of construction required by Contract Documents proposed by the Contractor after award of the Contract are considered requests for "substitutions." The following are not considered substitutions:
1. Revisions to Contract Documents requested by the Owner or Architect.
 2. Specified options of products and construction methods included in Contract Documents.
 3. Compliance with governing regulations and orders issued by governing authorities.
- B. Submittal: Requests for substitution will be considered if received within 30 days after commencement of the Work. Requests received more than 30 days after commencement of the Work may be considered or rejected at the discretion of the Architect.
1. Submit 3 copies of each request for substitution in the form and in accordance with procedures for Change Order proposals.
 2. Identify the product, or installation method to be replaced in each request. Include related Specification Section and Drawing numbers. Document compliance with requirements for substitutions, and the following information, as appropriate:
 - a. Product Data, including Drawings and descriptions of products, fabrication and installation procedures.
 - b. Samples, where applicable or requested.
 - c. A comparison of significant qualities of the proposed substitution with those specified.
 - d. A list of changes or modifications needed to other parts of the Work and to construction performed by the Owner and any separate Contractors, that will be necessary to accommodate the proposed substitution.
 - e. A statement indicating the substitution's effect on the Construction Schedule compared to the Schedule without approval of the substitution. Indicate the effect of the proposed substitution on overall Contract Time.

- f. Cost information, including a proposal of the net change, if any in the Contract Sum.
 - g. Certification by the Contractor that the substitution is equal to or better in every respect to that required by Contract Documents, and that it will perform adequately in application indicated. Include Contractor's waiver of rights to additional payment or time, that may be necessary because of the substitution's failure to perform adequately.
3. Architect's Action: Within one week of receipt of the request for substitution, the Architect will request additional information necessary for evaluation. Within 2 weeks of receipt of the request, or one week of receipt of additional information, whichever is later, the Architect will notify the Contractor of acceptance or rejection. If a decision on use of a substitute cannot be made within the time allocated, use the product specified. Acceptance will be in the form of a Change Order for substitutions changing the Contract Time or Contract Sum.
- C. Substitutions: The Contractor's substitution request will be received and considered by the Architect when one or more of the following conditions are satisfied, as determined by the Architect; otherwise requests will be returned without action except to record noncompliance with these requirements.
1. Extensive revisions to Contract Documents are not required.
 2. Proposed changes are in keeping with the general intent of Contract Documents.
 3. The request is timely, fully documented and properly submitted.
 4. The request is directly related to an "or equal" clause or similar language in the Contract Documents.
 5. The specified product or method of construction cannot be provided within the Contract Time. The request will not be considered if the product or method cannot be provided as a result of failure to pursue the Work promptly or coordinate activities properly.
 6. The specified product or method of construction cannot receive necessary approval by a governing authority, and the requested substitution can be approved.
 7. A substantial advantage is offered the Owner, in terms of cost, time, energy conservation or other considerations of merit, after deducting offsetting responsibilities the Owner may be required to bear. Additional responsibilities for the Owner may include additional compensation to the Architect for redesign and evaluation services, increased cost of other construction by the Owner or separate contractors, and similar considerations.
 8. The specified product or method of construction cannot be provided in a manner that is compatible with other materials, and where the Contractor certifies that the substitution will overcome the incompatibility.
 9. The specified product or method of construction cannot be coordinated with other materials, and where the Contractor certifies that the proposed substitution can be coordinated.
 10. The specified product or method of construction cannot provide a warranty required by

the Contract Documents and where the Contractor certifies that the proposed substitution provide the required warranty.

- D. Where a proposed substitution involves more than one prime Contractor, each Contractor shall cooperate with the other Contractors involved to coordinate the Work, provide uniformity and consistency, and to assure compatibility of products.
- E. The Contractor's submittal and Architect's acceptance of Shop Drawings, Product Data or Samples that relate to construction activities not complying with the Contract Documents does not constitute an acceptable or valid request for substitution, nor does it constitute approval.

PART 2 - PRODUCTS - Not Used

PART 3 - EXECUTION - Not Used

END OF SECTION 016310

SECTION 017300 - EXECUTION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes general administrative and procedural requirements governing execution of the Work including, but not limited to, the following:
 - 1. Construction layout.
 - 2. Field engineering and surveying.
 - 3. Installation of the Work.
 - 4. Starting and adjusting.
 - 5. Protection of installed construction.

1.2 INFORMATIONAL SUBMITTALS

- A. Certificates: Submit certificate signed by land surveyor certifying that location and elevation of improvements comply with requirements.
- B. Final Property Survey: Submit in accordance with Section 017839 "Project Record Documents"

1.3 QUALITY ASSURANCE

- A. Land Surveyor Qualifications: A professional land surveyor who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing land-surveying services of the kind indicated.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. General: Comply with requirements specified in other Sections.
 - 1. For projects requiring compliance with sustainable design and construction practices and procedures, use products for patching that comply with sustainable design requirements.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Existing Conditions: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify the existence and location of underground utilities, mechanical and electrical systems, and other construction affecting the Work.
 - 1. Before construction, verify the location and invert elevation at points of connection of sanitary sewer, storm sewer, and water-service piping; underground electrical services, and other utilities.
 - 2. Furnish location data for work related to Project that must be performed by public utilities serving Project site.
- B. Examination and Acceptance of Conditions: Before proceeding with each component of the Work, examine substrates, areas, and conditions, with Installer or Applicator present where indicated, for compliance with requirements for installation tolerances and other conditions affecting performance. Record observations.
 - 1. Examine roughing-in for mechanical and electrical systems to verify actual locations of connections before equipment and fixture installation.
 - 2. Examine walls, floors, and roofs for suitable conditions where products and systems are to be installed.
 - 3. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
- C. Proceed with installation only after unsatisfactory conditions have been corrected. Proceeding with the Work indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Existing Utility Information: Furnish information to local utility that is necessary to adjust, move, or relocate existing utility structures, utility poles, lines, services, or other utility appurtenances located in or affected by construction. Coordinate with authorities having jurisdiction.
- B. Field Measurements: Take field measurements as required to fit the Work properly. Recheck measurements before installing each product. Where portions of the Work are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
- C. Space Requirements: Verify space requirements and dimensions of items shown diagrammatically on Drawings.
- D. Review of Contract Documents and Field Conditions: Immediately on discovery of the need for clarification of the Contract Documents caused by differing field conditions outside the control

of Contractor, submit a request for information to Architect according to requirements in Section 013100 "Project Management and Coordination."

3.3 CONSTRUCTION LAYOUT

- A. Verification: Before proceeding to lay out the Work, verify layout information shown on Drawings, in relation to the property survey and existing benchmarks. If discrepancies are discovered, notify Architect promptly.
- B. General: Engage a land surveyor to lay out the Work using accepted surveying practices.
 - 1. Establish benchmarks and control points to set lines and levels at each story of construction and elsewhere as needed to locate each element of Project.
 - 2. Establish limits on use of Project site.
 - 3. Establish dimensions within tolerances indicated. Do not scale Drawings to obtain required dimensions.
 - 4. Inform installers of lines and levels to which they must comply.
 - 5. Check the location, level and plumb, of every major element as the Work progresses.
 - 6. Notify Architect when deviations from required lines and levels exceed allowable tolerances.
 - 7. Close site surveys with an error of closure equal to or less than the standard established by authorities having jurisdiction.
- C. Site Improvements: Locate and lay out site improvements, including pavements, grading, fill and topsoil placement, utility slopes, and rim and invert elevations.
- D. Building Lines and Levels: Locate and lay out control lines and levels for structures, building foundations, column grids, and floor levels, including those required for mechanical and electrical work. Transfer survey markings and elevations for use with control lines and levels. Level foundations and piers from two or more locations.
- E. Record Log: Maintain a log of layout control work. Record deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used. Make the log available for reference by Architect.

3.4 FIELD ENGINEERING

- A. Reference Points: Locate existing permanent benchmarks, control points, and similar reference points before beginning the Work. Preserve and protect permanent benchmarks and control points during construction operations.
- B. Benchmarks: Establish and maintain a minimum of two permanent benchmarks on Project site, referenced to data established by survey control points. Comply with authorities having jurisdiction for type and size of benchmark.
 - 1. Record benchmark locations, with horizontal and vertical data, on Project Record Documents.

- C. Certified Survey: On completion of foundation walls, major site improvements, and other work requiring field-engineering services, prepare a certified survey showing dimensions, locations, angles, and elevations of construction and sitework.
- D. Final Property Survey: Provide in accordance with Section 017839 "Project Record documents".

3.5 INSTALLATION

- A. General: Locate the Work and components of the Work accurately, in correct alignment and elevation, as indicated.
 - 1. Make vertical work plumb and make horizontal work level.
 - 2. Where space is limited, install components to maximize space available for maintenance and ease of removal for replacement.
 - 3. Conceal pipes, ducts, and wiring in finished areas unless otherwise indicated.
- B. Comply with manufacturer's written instructions and recommendations for installing products in applications indicated.
- C. Install products at the time and under conditions that will ensure the best possible results. Maintain conditions required for product performance until Substantial Completion.
- D. Conduct construction operations so no part of the Work is subjected to damaging operations or loading in excess of that expected during normal conditions of occupancy.
- E. Sequence the Work and allow adequate clearances to accommodate movement of construction items on site and placement in permanent locations.
- F. Tools and Equipment: Do not use tools or equipment that produce harmful noise levels.
- G. Templates: Obtain and distribute to the parties involved templates for work specified to be factory prepared and field installed. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing products to comply with indicated requirements.
- H. Attachment: Provide blocking and attachment plates and anchors and fasteners of adequate size and number to securely anchor each component in place, accurately located and aligned with other portions of the Work. Where size and type of attachments are not indicated, verify size and type required for load conditions.
 - 1. Mounting Heights: Where mounting heights are not indicated, mount components at heights directed by Architect.
 - 2. Allow for building movement, including thermal expansion and contraction.
 - 3. Coordinate installation of anchorages. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

- I. Joints: Make joints of uniform width. Where joint locations in exposed work are not indicated, arrange joints for the best visual effect. Fit exposed connections together to form hairline joints.
- J. Hazardous Materials: Use products, cleaners, and installation materials that are not considered hazardous.

3.6 STARTING AND ADJUSTING

- A. Start equipment and operating components to confirm proper operation. Remove malfunctioning units, replace with new units, and retest.
- B. Adjust equipment for proper operation. Adjust operating components for proper operation without binding.
- C. Test each piece of equipment to verify proper operation. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.

3.7 PROTECTION OF INSTALLED CONSTRUCTION

- A. Provide final protection and maintain conditions that ensure installed Work is without damage or deterioration at time of Substantial Completion.
- B. Comply with manufacturer's written instructions for temperature and relative humidity.

END OF SECTION 017300

SECTION 017419 - CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes administrative and procedural requirements for the following:

1. Recycling nonhazardous demolition and construction waste.
2. Disposing of nonhazardous demolition and construction waste.

1.2 DEFINITIONS

- A. Construction Waste: Building and site improvement materials and other solid waste resulting from construction, remodeling, renovation, or repair operations. Construction waste includes packaging.
- B. Demolition Waste: Building and site improvement materials resulting from demolition or selective demolition operations.
- C. Disposal: Removal off-site of demolition and construction waste and subsequent sale, recycling, reuse, or deposit in landfill or incinerator acceptable to authorities having jurisdiction.
- D. Recycle: Recovery of demolition or construction waste for subsequent processing in preparation for reuse.
- E. Salvage: Recovery of demolition or construction waste and subsequent sale or reuse in another facility.
- F. Salvage and Reuse: Recovery of demolition or construction waste and subsequent incorporation into the Work.

1.3 PERFORMANCE REQUIREMENTS

- A. General: Achieve end-of-Project rates for salvage/recycling of **75** percent by weight of total non-hazardous solid waste generated by the Work. Facilitate recycling and salvage of materials.

1.4 ACTION SUBMITTALS

- A. Waste Management Plan: Submit plan within 7 days of date established for the Notice to Proceed.

1.5 INFORMATIONAL SUBMITTALS

- A. Waste Reduction Progress Reports: Concurrent with each Application for Payment, submit report. Include the following information:
 - 1. Material category.
 - 2. Generation point of waste.
 - 3. Total quantity of waste in tons.
 - 4. Quantity of waste recycled, both estimated and actual in tons.
- B. Waste Reduction Calculations: Before request for Substantial Completion, submit calculated end-of-Project rates for salvage, recycling, and disposal as a percentage of total waste generated by the Work.
- C. Records of Donations: Indicate receipt and acceptance of salvageable waste donated to individuals and organizations. Indicate whether organization is tax exempt.
- D. Records of Sales: Indicate receipt and acceptance of salvageable waste sold to individuals and organizations. Indicate whether organization is tax exempt.
- E. Recycling and Processing Facility Records: Indicate receipt and acceptance of recyclable waste by recycling and processing facilities licensed to accept them. Include manifests, weight tickets, receipts, and invoices.
- F. Landfill and Incinerator Disposal Records: Indicate receipt and acceptance of waste by landfills and incinerator facilities licensed to accept them. Include manifests, weight tickets, receipts, and invoices.
- G. Qualification Data: For waste management coordinator.

1.6 QUALITY ASSURANCE

- A. Waste Management Coordinator Qualifications: LEED-Accredited Professional, certified by USGBC.

1.7 WASTE MANAGEMENT PLAN

- A. General: Develop a waste management plan according to ASTM E 1609 and requirements in this Section. Plan shall consist of waste identification, waste reduction work plan, and cost/revenue analysis. Distinguish between demolition and construction waste. Indicate quantities by weight or volume, but use same units of measure throughout waste management plan.
- B. Waste Identification: Indicate anticipated types and quantities of demolition site-clearing and construction waste generated by the Work. Include estimated quantities and assumptions for estimates.

- C. Waste Reduction Work Plan: List each type of waste and whether it will be recycled, or disposed of in landfill or incinerator. Include points of waste generation, total quantity of each type of waste, quantity for each means of recovery, and handling and transportation procedures.
1. Recycled Materials: Include list of local receivers and processors and type of recycled materials each will accept. Include names, addresses, and telephone numbers.
 2. Disposed Materials: Indicate how and where materials will be disposed of. Include name, address, and telephone number of each landfill and incinerator facility.
 3. Handling and Transportation Procedures: Include method that will be used for separating recyclable waste including sizes of containers, container labeling, and designated location where materials separation will be performed.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 PLAN IMPLEMENTATION

- A. General: Implement approved waste management plan. Provide handling, containers, storage, signage, transportation, and other items as required to implement waste management plan during the entire duration of the Contract.
- B. Waste Management Coordinator: Engage a waste management coordinator to be responsible for implementing, monitoring, and reporting status of waste management work plan.
- C. Training: Train workers, subcontractors, and suppliers on proper waste management procedures, as appropriate for the Work occurring at Project site.
1. Distribute waste management plan to everyone concerned within three days of submittal return.
 2. Distribute waste management plan to entities when they first begin work on-site. Review plan procedures and locations established for salvage, recycling, and disposal.
- D. Site Access and Temporary Controls: Conduct waste management operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
1. Designate and label specific areas on Project site necessary for separating materials that are to be salvaged, recycled, reused, donated, and sold.
 2. Comply with Section 015000 "Temporary Facilities and Controls" for controlling dust and dirt, environmental protection, and noise control.

3.2 RECYCLING DEMOLITION AND CONSTRUCTION WASTE, GENERAL

- A. General: Recycle paper and beverage containers used by on-site workers.
- B. Recycling Incentives: Revenues, savings, rebates, tax credits, and other incentives received for recycling waste materials shall accrue to Owner.
- C. Procedures: Separate recyclable waste from other waste materials, trash, and debris. Separate recyclable waste by type at Project site to the maximum extent practical according to approved construction waste management plan.
 - 1. Provide appropriately marked containers or bins for controlling recyclable waste until they are removed from Project site. Include list of acceptable and unacceptable materials at each container and bin.
 - a. Inspect containers and bins for contamination and remove contaminated materials if found.
 - 2. Stockpile processed materials on-site without intermixing with other materials. Place, grade, and shape stockpiles to drain surface water. Cover to prevent windblown dust.
 - 3. Stockpile materials away from construction area. Do not store within drip line of remaining trees.
 - 4. Store components off the ground and protect from the weather.
 - 5. Remove recyclable waste from Owner's property and transport to recycling receiver or processor.

3.3 RECYCLING DEMOLITION WASTE

- A. Asphalt Paving: Break up and transport paving to asphalt-recycling facility.
- B. Concrete: Remove reinforcement and other metals from concrete and sort with other metals.
 - 1. Pulverize concrete to maximum 1-1/2-inch size.
- C. Masonry: Remove metal reinforcement, anchors, and ties from masonry and sort with other metals.
 - 1. Pulverize masonry to maximum 3/4-inch size.
 - 2. Clean and stack undamaged, whole masonry units on wood pallets.
- D. Wood Materials: Sort and stack members according to size, type, and length. Separate lumber, engineered wood products, panel products, and treated wood materials.
- E. Metals: Separate metals by type.
 - 1. Structural Steel: Stack members according to size, type of member, and length.

2. Remove and dispose of bolts, nuts, washers, and other rough hardware.

- F. Asphalt Shingle Roofing: Separate organic and glass-fiber asphalt shingles and felts. Remove and dispose of nails, staples, and accessories.
- G. Gypsum Board: Stack large clean pieces on wood pallets or in container and store in a dry location. Remove edge trim and sort with other metals. Remove and dispose of fasteners.
- H. Piping: Reduce piping to straight lengths and store by type and size. Separate supports, hangers, valves, sprinklers, and other components by type and size.
- I. Conduit: Reduce conduit to straight lengths and store by type and size.

3.4 RECYCLING CONSTRUCTION WASTE

A. Packaging:

- 1. Cardboard and Boxes: Break down packaging into flat sheets. Bundle and store in a dry location.
- 2. Polystyrene Packaging: Separate and bag materials.
- 3. Pallets: As much as possible, require deliveries using pallets to remove pallets from Project site. For pallets that remain on-site, break down pallets into component wood pieces and comply with requirements for recycling wood.
- 4. Crates: Break down crates into component wood pieces and comply with requirements for recycling wood.

B. Wood Materials:

- 1. Clean Cut-Offs of Lumber: Grind or chip into small pieces.
- 2. Clean Sawdust: Bag sawdust that does not contain painted or treated wood.

C. Gypsum Board: Stack large clean pieces on wood pallets or in container and store in a dry location.

- 1. Clean Gypsum Board: Grind scraps of clean gypsum board using small mobile chipper or hammer mill. Screen out paper after grinding.

3.5 DISPOSAL OF WASTE

A. General: Except for items or materials to be salvaged, recycled, or otherwise reused, remove waste materials from Project site and legally dispose of them in a landfill or incinerator acceptable to authorities having jurisdiction.

- 1. Except as otherwise specified, do not allow waste materials that are to be disposed of accumulate on-site.
- 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.

- B. Burning: Do not burn waste materials.
- C. Burning: Burning of waste materials is permitted only at designated areas on Owner's property, provided required permits are obtained. Provide full-time monitoring for burning materials until fires are extinguished.
- D. Disposal: Remove waste materials and dispose of at designated spoil areas on Owner's property.
- E. Disposal: Remove waste materials from Owner's property and legally dispose of them.

END OF SECTION 017419

SECTION 017700 - CLOSEOUT PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for contract closeout, including, but not limited to, the following:
 - 1. Substantial Completion procedures.
 - 2. Final completion procedures.
 - 3. Warranties.
 - 4. Final cleaning.
 - 5. Repair of the Work.

1.2 SUBMITTALS

- A. Product Data: For cleaning agents.
- B. Contractor's List of Incomplete Items: Initial submittal at Substantial Completion.
- C. Certified List of Incomplete Items: Final submittal at Final Completion.

1.3 CLOSEOUT SUBMITTALS

- A. Certificates of Release: From authorities having jurisdiction.
- B. Certificate of Insurance: For continuing coverage.
- C. Field Report: For pest control inspection.

1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Schedule of Maintenance Material Items: For maintenance material submittal items specified in other Sections.

1.5 SUBSTANTIAL COMPLETION PROCEDURES

- A. Contractor's List of Incomplete Items: Prepare and submit a list of items to be completed and corrected (Contractor's punch list), indicating the value of each item on the list and reasons why the Work is incomplete.

- B. Submittals Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.
1. Certificates of Release: Obtain and submit releases from authorities having jurisdiction permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
 2. Submit closeout submittals specified in other Division 01 Sections, including project record documents, operation and maintenance manuals, final completion construction photographic documentation, damage or settlement surveys, property surveys, and similar final record information.
 3. Submit closeout submittals specified in individual Divisions 02 through 31 Sections, including specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
 4. Submit maintenance material submittals specified in individual Divisions 02 through 31 Sections, including tools, spare parts, extra materials, and similar items, and deliver to location designated by Architect. Label with manufacturer's name and model number where applicable.
 - a. Schedule of Maintenance Material Items: Prepare and submit schedule of maintenance material submittal items, including name and quantity of each item and name and number of related Specification Section. Obtain Architect's signature for receipt of submittals.
 5. Submit test/adjust/balance records.
- C. Procedures Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.
1. Advise Owner of pending insurance changeover requirements.
 2. Make final changeover of permanent locks and deliver keys to Owner. Advise Owner's personnel of changeover in security provisions.
 3. Complete startup and testing of systems and equipment.
 4. Perform preventive maintenance on equipment used prior to Substantial Completion.
 5. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems.
 6. Advise Owner of changeover in heat and other utilities.
 7. Participate with Owner in conducting inspection and walkthrough with local emergency responders.
 8. Terminate and remove temporary facilities from Project site, along with mockups, construction tools, and similar elements.
 9. Complete final cleaning requirements, including touchup painting.
 10. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.
- D. Inspection: Submit a written request for inspection to determine Substantial Completion a minimum of 10 days prior to date the work will be completed and ready for final inspection and

tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Architect, that must be completed or corrected before certificate will be issued.

1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
2. Results of completed inspection will form the basis of requirements for final completion.

1.6 FINAL COMPLETION PROCEDURES

A. Preliminary Procedures: Before requesting final inspection for determining final completion, complete the following:

1. Submit a final Application for Payment according to Division 01 Section "Payment Procedures."
2. Certified List of Incomplete Items: Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Architect. Certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
3. Certificate of Insurance: Submit evidence of final, continuing insurance coverage complying with insurance requirements.
4. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems.

B. Inspection: Submit a written request for final inspection to determine acceptance. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.

1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.

1.7 LIST OF INCOMPLETE ITEMS (PUNCH LIST)

A. Organization of List: Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction.

1. Organize list of spaces in sequential order, starting with exterior areas first and proceeding from lowest floor to highest floor.
2. Organize items applying to each space by major element, including categories for ceiling, individual walls, floors, equipment, and building systems.
3. Submit list of incomplete items in the following format:

- a. PDF electronic file. Architect will return annotated copy.

1.8 SUBMITTAL OF PROJECT WARRANTIES

- A. Time of Submittal: Submit written warranties on request of Architect for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated, or when delay in submittal of warranties might limit Owner's rights under warranty.
- B. Organize warranty documents into an orderly sequence based on the table of contents of the Project Manual.
 1. Bind warranties and bonds in heavy-duty, three-ring, vinyl-covered, loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2-by-11-inch paper.
 2. Provide heavy paper dividers with plastic-covered tabs for each separate warranty. Mark tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product and the name, address, and telephone number of Installer.
 3. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project name, and name of Contractor.
 4. Warranty Electronic File: Scan warranties and bonds and assemble complete warranty and bond submittal package into a single indexed electronic PDF file with links enabling navigation to each item. Provide bookmarked table of contents at beginning of document.
- C. Provide additional copies of each warranty to include in operation and maintenance manuals.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Cleaning Agents: Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.
 1. Use cleaning products that comply with Green Seal's GS-37, or if GS-37 is not applicable, use products that comply with the California Code of Regulations maximum allowable VOC levels.

PART 3 - EXECUTION

3.1 FINAL CLEANING

- A. General: Perform final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
 - 1. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion for entire Project or for a designated portion of Project:
 - a. Clean Project site, yard, and grounds, in areas disturbed by construction activities, including landscape development areas, of rubbish, waste material, litter, and other foreign substances.
 - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
 - c. Rake grounds that are neither planted nor paved to a smooth, even-textured surface.
 - d. Remove tools, construction equipment, machinery, and surplus material from Project site.
 - e. Remove snow and ice to provide safe access to building.
 - f. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore reflective surfaces to their original condition.
 - g. Remove debris and surface dust from limited access spaces, including roofs, plenums, shafts, trenches, equipment vaults, manholes, attics, and similar spaces.
 - h. Sweep concrete floors broom clean in unoccupied spaces.
 - i. Vacuum carpet and similar soft surfaces, removing debris and excess nap; clean according to manufacturer's recommendations if visible soil or stains remain.
 - j. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compounds and other noticeable, vision-obscuring materials. Replace chipped or broken glass and other damaged transparent materials. Polish mirrors and glass, taking care not to scratch surfaces.
 - k. Remove labels that are not permanent.
 - l. Wipe surfaces of mechanical and electrical equipment, elevator equipment, and similar equipment. Remove excess lubrication, paint and mortar droppings, and other foreign substances.
 - m. Clean plumbing fixtures to a sanitary condition, free of stains, including stains resulting from water exposure.
 - n. Replace disposable air filters and clean permanent air filters. Clean exposed surfaces of diffusers, registers, and grills.
 - o. Clean light fixtures, lamps, globes, and reflectors to function with full efficiency.

p. Leave Project clean and ready for occupancy.

C. Pest Control: Comply with pest control requirements in Division 01 Section "Temporary Facilities and Controls." Prepare written report.

3.2 REPAIR OF THE WORK

A. Complete repair and restoration operations before requesting inspection for determination of Substantial Completion.

B. Repair or remove and replace defective construction. Repairing includes replacing defective parts, refinishing damaged surfaces, touching up with matching materials, and properly adjusting operating equipment. Where damaged or worn items cannot be repaired or restored, provide replacements. Remove and replace operating components that cannot be repaired. Restore damaged construction and permanent facilities used during construction to specified condition.

1. Remove and replace chipped, scratched, and broken glass, reflective surfaces, and other damaged transparent materials.
2. Touch up and otherwise repair and restore marred or exposed finishes and surfaces. Replace finishes and surfaces that already show evidence of repair or restoration.
 - a. Do not paint over "UL" and other required labels and identification, including mechanical and electrical nameplates. Remove paint applied to required labels and identification.
3. Replace parts subject to operating conditions during construction that may impede operation or reduce longevity.
4. Replace burned-out bulbs, bulbs noticeably dimmed by hours of use, and defective and noisy starters in fluorescent and mercury vapor fixtures to comply with requirements for new fixtures.

END OF SECTION 017700

SECTION 017839 - PROJECT RECORD DOCUMENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for project record documents, including the following:
1. Record Drawings.
 2. Record Specifications.
 3. Record Product Data.
 4. Final Property Survey.

1.2 CLOSEOUT SUBMITTALS

- A. Record Drawings: Comply with the following:
1. Number of Copies: Submit two set(s) of marked-up record prints.
 2. Number of Copies: Submit copies of record Drawings as follows:
 - a. Initial Submittal:
 - 1) Submit PDF electronic files of scanned record prints and one set of file prints.
 - 2) Architect will indicate whether general scope of changes, additional information recorded, and quality of drafting are acceptable.
 - b. Final Submittal:
 - 1) Submit PDF electronic files of scanned record prints and three sets of prints.
 - 2) Print each drawing, whether or not changes and additional information were recorded.
- B. Record Specifications: Submit one paper copy of Project's Specifications, including addenda and contract modifications.

PART 2 - PRODUCTS

2.1 RECORD DRAWINGS

- A. Record Prints: Maintain one set of marked-up paper copies of the Contract Drawings and Shop Drawings, incorporating new and revised Drawings as modifications are issued.

1. Preparation: Mark record prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to provide information for preparation of corresponding marked-up record prints.
 - a. Give particular attention to information on concealed elements that would be difficult to identify or measure and record later.
 - b. Record data as soon as possible after obtaining it.
 - c. Record and check the markup before enclosing concealed installations.
2. Mark the Contract Drawings and Shop Drawings completely and accurately. Use personnel proficient at recording graphic information in production of marked-up record prints.
3. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at same location.
4. Note Construction Change Directive numbers, alternate numbers, Change Order numbers, and similar identification, where applicable.

2.2 RECORD SPECIFICATIONS

- A. Preparation: Mark Specifications to indicate the actual product installation where installation varies from that indicated in Specifications, addenda, and contract modifications.
 1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 2. Mark copy with the proprietary name and model number of products, materials, and equipment furnished, including substitutions and product options selected.
 3. Record the name of manufacturer, supplier, Installer, and other information necessary to provide a record of selections made.
 4. Note related Change Orders, record Product Data, and record Drawings where applicable.
- B. Format: Submit record Specifications as paper copy.

2.3 RECORD PRODUCT DATA

- A. Preparation: Mark Product Data to indicate the actual product installation where installation varies substantially from that indicated in Product Data submittal.
 1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 2. Include significant changes in the product delivered to Project site and changes in manufacturer's written instructions for installation.
 3. Note related Change Orders, record Specifications, and record Drawings where applicable.
- B. Format: Submit record Product Data as annotated PDF electronic file.

2.4 MISCELLANEOUS RECORD SUBMITTALS

- A. Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submittal in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.
- B. Format: Submit miscellaneous record submittals as PDF electronic file.

2.5 FINAL PROPERTY SURVEY

- A. Final Property Survey: Engage a licensed land surveyor to prepare a final property survey showing significant features (real property) for Project. Include on the survey a certification, signed by land surveyor, that principal metes, bounds, lines, and levels of Project are accurately positioned as shown on the survey. Show on the final survey all new work, improvements, modifications, utilities, final grades and final floor elevations.
 - 1. Recording: At Substantial Completion, have the final property survey recorded by or with authorities having jurisdiction as the official "property survey."
 - 2. Submit 5 signed and sealed copies and 1 PDF electronic file showing the Work performed and record survey data.

PART 3 - EXECUTION

3.1 RECORDING AND MAINTENANCE

- A. Recording: Maintain one copy of each submittal during the construction period for project record document purposes. Post changes and revisions to project record documents as they occur; do not wait until end of Project.
- B. Maintenance of Record Documents and Samples: Store record documents and Samples in the field office apart from the Contract Documents used for construction. Do not use project record documents for construction purposes. Maintain record documents in good order and in a clean, dry, legible condition, protected from deterioration and loss. Provide access to project record documents for Architect's reference during normal working hours.

END OF SECTION 017839

SECTION 028300 – LEAD PAINT AWARENESS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Revised Hazardous Materials Inspection Report (June 2016).

1.2 SUMMARY OF WORK

- A. Work of this Section includes requirements for worker protection and waste disposal related to structure demolition work involving lead-based paint (LBP)-coated building components and surfaces (the “Work” at 20 Cooper Avenue in Milford, Connecticut (the “Site”).
- B. The procedures referenced herein shall be utilized during required structure demolition work specified elsewhere that may impact building components coated with LBP. The following painted components were determined to be coated with LBP:
 - 1. White Wood 4” x 4” Posts;
 - 2. White Wood Walls; and
 - 3. White Wood Door Casings.
- C. The structure demolition work impacting LBP may result in dust and debris exposing workers to levels of lead above the Occupational Safety and Health Administration’s (OSHA) Action Level. Worker protection, training, and engineering controls referenced herein shall be strictly followed, until completion of exposure assessment with results indicating exposures below the “Action Level.” **This Section does not involve lead abatement, but identified worker protection requirements for trades involved in the demolition and disposal procedures if lead is involved in the demolition waste stream.**
- D. Construction activities disturbing surfaces with lead-containing paint that are likely to be employed, such as demolition, sanding, grinding, welding, cutting and burning, have been known to expose workers to levels of lead in excess of the OSHA Permissible Exposure Limit (PEL). All work specified in the technical sections of the Contract Documents shall also be in conformance with this Technical specification section 02091 for Lead Paint Awareness.

1.3 DEFINITIONS

- B. The following definitions relative to LBP shall apply:
 - 1. Action Level (AL) - The allowable employee exposure, without regard to use of respiratory protection, to an airborne concentration of lead over an eight-hour time-weighted average (TWA) as defined by OSHA. The current action level is thirty micrograms per cubic meter of air (30 µg/m³).

2. Architect – Lothrop Associates,LLP Architects
3. Area Monitoring - The sampling of lead concentrations, which is representative of the airborne lead concentrations that may reach the breathing zone of personnel potentially exposed to lead.
4. Biological Monitoring - The analysis of a person's blood and/or urine, to determine the level of lead concentration in the body.
5. CDC - The Center for Disease Control
6. Change Room - An area provided with separate facilities for clean protective work clothing and equipment and for street clothes, which prevents cross-contamination.
7. Component Person - A person employed by the Contractor who is capable of identifying existing and predictable lead hazards in the surroundings or working conditions, and who has authorization to take prompt corrective measures to eliminate them as defined by OSHA.
8. Consultant – Fuss & O’Neill EnviroScience
9. EPA - United States Environmental Protection Agency
10. Exposure Assessment - An assessment conducted by an employer to determine if any employee may be exposed to lead at or above the action level.
11. High Efficiency Particulate Air (HEPA) - A type of filtering system capable of filtering out particles of 0.3 microns diameter from a body of air at 99.97% efficiency or greater.
12. HUD - United States Housing and Urban Development
13. Lead - Refers to metallic lead, inorganic lead compounds, and organic lead soaps. Excluded from this definition are other organic lead compounds.
14. Lead Work Area - An area enclosed in a manner to prevent the spread of lead dust, paint chips, or debris resulting from lead containing paint disturbance.
15. Lead Paint - Refers to paints, glazes, and other surface coverings containing a toxic level of lead.
16. MSHA - Mine Safety and Health Administration
17. NARI - National Association of The Remodeling Industry
18. NIOSH - National Institute of Occupational Safety and Health
19. OSHA - Occupational Safety and Health Administration
20. Owner – Gail and Jack Trez
21. Permissible Exposure Limit (PEL) - The maximum allowable limit of exposure to an airborne concentration of lead over an eight (8)-hour TWA, as defined by OSHA. The current PEL is fifty micrograms per cubic meter of air ($50 \mu\text{g}/\text{m}^3$). Extended workdays lower the PEL by the formula: PEL equals 400 divided by the number of hours of work.
22. Personal Monitoring - Sampling of lead concentrations within the breathing zone of an employee to determine the 8 hour time weighted average concentration in accordance with OSHA Title 29 CFR, Parts 1910.1025 and 1926.62. Samples shall be representative of the employee's work tasks. Breathing zone shall be considered an area within a sphere with a radius of 18-inches and centered at the nose or mouth of an employee.
23. Resource Conservation and Recovery Act (RCRA) - RCRA establishes regulatory levels of hazardous chemicals. There are eight (8) heavy metals of concern for disposal: arsenic, barium, cadmium, chromium, lead, mercury, selenium, and silver. Six (6) of the metals are typically in paints, excluding selenium and silver.
24. SDS - Safety Data Sheets
25. TWA - Time Weighted Average

26. Toxic Level of Lead - A level of lead, when present in dried paint or plaster, contains more than 0.50% lead by dry weight as measured by atomic absorption spectrophotometry (AAS) or 1.0 milligram per square centimeter (mg/cm²) as measured by on site testing utilizing an x ray fluorescence analyzer. (Term is specific to State of CT regulations and HUD guidelines only)
27. Toxicity Characteristic Leaching Procedure (TCLP) - The United States Environmental Protection Agency (EPA) required sample preparation and analysis for determining the hazard characteristics of a waste material.

1.4 REGULATIONS AND STANDARDS

- A. The following regulations, standards, and ordinances of federal, state, and local agencies are applicable and made a part of this specification by reference:

1. American National Standards Institute (ANSI)
 - a. ANSI 288.2 - 1980 Respiratory Protection
2. Code of Federal Regulation (CFR)
 - a. Title 29 CFR, Part 1910.134 - Respiratory Protection
 - b. Title 29 CFR, Part 1910.1025 – Lead
 - c. Title 29 CFR, Part 1910.1200 - Hazard Communication
 - d. Title 29 CFR, Part 1926.55 - Gases, Vapors, Fumes, Dusts, and Mists
 - e. Title 29 CFR, Part 1926.57 - Ventilation
 - f. Title 29 CFR, Part 1926.59 - Hazard Communication in Construction
 - g. Title 29 CFR, Part 1926.62 - Lead in Construction Interim Final Rule
 - h. Title 40 CFR, Parts 124 and 270 - Hazardous Waste Permits
 - i. Title 40 CFR, Part 172 - Hazardous Materials Tables and Communication Regulations
 - j. Title 40 CFR, Part 178 - Shipping Container Specifications
 - k. Title 40 CFR, Part 260 - Hazardous Waste Management Systems: General
 - l. Title 40 CFR, Part 261 - Identification and Listing of Hazardous Waste
 - m. Title 40 CFR, Part 262 - Generators of Hazardous Waste
 - n. Title 40 CFR, Part 263 - Transporters of Hazardous Waste
 - o. Title 40 CFR, Part 264 - Owner and Operators of Hazardous Waste Treatment, Storage, and Disposal Facilities
 - p. Title 40 CFR, Part 265 - Interim Statutes for Owner and Operators of Hazardous Waste Treatment, Storage, and Disposal Facilities
 - q. Title 40 CFR, Part 268 - Lead Disposal Restrictions
 - r. Title 49 CFR, Parts 170 - 180
3. Underwriters Laboratories, Inc. (UL)
 - a. UL586 - 1990 High Efficiency Particulate Air Filter Units

1.5 QUALITY ASSURANCE

- A. Hazard Communication Program
1. The Contractor shall establish and implement a Hazard Communication Program as required by OSHA Title 29 CFR, Part 1926.59.

B. Compliance Plan (Site-Specific)

1. The Contractor shall establish a written compliance plan, which is specific to the project site, to include the following:
 - a. A description of work activity involving lead including equipment used, material included, controls in place, crew size, employee job responsibilities, operating procedures, and maintenance practices.
 - b. Methods of engineering controls to be used to control lead exposure.
 - c. The proposed technology the Contractor will implement in meeting the PEL.
 - d. Air monitoring data documenting the source of lead emissions.
 - e. A detailed schedule for implementing the program, including documentation of appropriate supply of equipment, etc.
 - f. Proposed work practice which establishes proper protective work clothing, housekeeping methods, hygiene facilities, and practices.
 - g. Worker rotation schedule, if proposed, to reduce TWA.
 - h. A description of methods for informing workers of potential lead exposure.

C. Hazardous Waste Management

1. The Contractor shall establish a Hazardous Waste Management Plan, which shall comply with applicable regulations and address the following:
 - a. Identification of hazardous wastes
 - b. Estimated quantity of waste to be disposed
 - c. Names and qualifications of each subcontractor who will be transporting, storing, treating, and disposing of wastes
 - d. Disposal facility location and 24-hour point of contact
 - e. Establish EPA state hazardous waste and identification numbers if applicable
 - f. Names and qualifications (experience and training) of personnel who will be working on site with hazardous wastes.
 - g. List of waste handling equipment to be used in performing the work to include cleaning, volume reduction, if applicable, and transport equipment
 - h. Qualifications of laboratory to be utilized for TCLP sampling and analysis
 - i. Spill prevention, containment, and countermeasure plan (SPCC)
 - j. Work plan and schedule for waste containment, removal, treatment, and disposal

D. Medical Examinations

1. Before exposure to lead-contaminated dust, provide workers with a comprehensive medical examination as required by OSHA Title 29 CFR, Parts 1910.1025 and 1926.62.
2. The examination shall not be required if adequate records show that employees have been examined as required by OSHA Title 29 CFR, Part 1926.62 within the last year.
3. Medical examination shall include, at a minimum, approval to wear respiratory protection and biological monitoring.

E. Training

1. The Contractor shall ensure that workers are trained to perform lead paint disturbing activities and disposal operations prior to the start of work, in accordance with OSHA Title 29 CFR, Part 1926.62.

F. Respiratory Protection Program

1. The Contractor shall furnish each employee required to wear a negative pressure respirator with a respirator fit test at the time of initial fitting and at least once every six months thereafter, as required by OSHA Title 29 CFR, Part 1926.62.
2. The Contractor shall establish a Respiratory Protection Program in accordance with ANSI Z88.2, OSHA Title 29 CFR, Parts 1910.134 and 1926.62.

1.6 SUBMITTALS

A. The Contractor shall submit the following to the Consultant in one complete package prior to the pre-construction meeting and at least 10 business days before the start of the Work:

1. Submit a schedule to the Owner and the Consultant, which defines a timetable for executing and completing the project, including work area preparations, removal, cleanup, and decontamination.
2. Submit a current valid certificate of insurance.
3. Submit the name and address of the hauling contractor and location of the landfill to be used. Also submit current valid operating permits and certificates of insurance for the transporter and landfill.
4. Submit video documentation showing the existing building conditions prior to the start of work. The Contractor shall be responsible for all costs associated with damage to the building and its contents that are not shown on the video documentation.
5. Submit the plans and construction details for the construction of the decontamination systems and the isolation of the work areas as may be necessary for compliance with this specification and applicable regulations.
6. Submit copies of medical records for each employee to be used on the project, including results of biological monitoring and a notarized statement by the examining physician that such an examination occurred.
7. Submit workers' valid training certificates.
8. Submit record of successful respirator fit testing performed by a qualified individual within the previous six months, for each employee to be used on this project with the employee's name and social security number with each record.
9. Submit the name and address of Contractor's blood lead testing lab, OSHA CDC listing, and certification in the State of Connecticut.
10. Submit detailed product information on all materials and equipment proposed for demolition work on this project.
11. Submit pertinent information regarding the qualifications of the Project Supervisor (competent person) for this project, as well as a list of past projects completed.
12. Submit a chain-of-command for the project.

13. Submit a site-specific Emergency Action Plan for the project.
14. Submit a written site-specific written Respiratory Protection Program for employees for the Work, including make, model and NIOSH approval numbers of respirators to be used at the Site (if applicable).
15. No work on the Site will be allowed to begin until the Owner and the Consultant as listed herein accept the Pre-Construction Submittals. Any delay caused by the Contractor's refusal or inability to submit this documentation accurately, completely, and in a timely manner does not constitute a cause for change order or a time extension;

B. The following shall be submitted to the Consultant during the Work:

1. Results of personal air sampling
2. Training and medical records for new employees to start Site work (24-hours in advance)

C. The following shall be submitted to the Consultant at the completion of the Work:

1. Copies of all air sampling results
2. Contractor logs
3. Copies of manifests and receipts acknowledging disposal of all waste material from the project showing delivery date, quantity, and appropriate signature of landfill's authorized representative.

1.7 PERSONAL PROTECTION

A. Exposure Assessment

1. The Contractor shall determine if any worker will be exposed to lead at or above the action level.
2. The exposure assessment shall identify the level of exposure a worker would be subjected to without respiratory protection.
3. The exposure assessment shall be achieved by obtaining personal air monitoring samples representative of a full shift at least (8-hour TWA).
4. During the period of the exposure assessment, the Contractor shall institute the following procedures for protection of workers:
 - a. Protective clothing shall be utilized
 - b. Respiratory protection
 - c. Change areas shall be provided
 - d. Hand washing facilities and shower
 - e. Biological monitoring
 - f. Training of workers

B. Respiratory Protection

1. The Contractor shall furnish appropriate respirators approved by NIOSH/MSHA for use in atmospheres containing lead dust.
2. Respirators shall comply with the requirements of OSHA Title 29 CFR, Part 1926.62.
3. Workers shall be instructed in all aspects of respiratory protection.

4. The Contractor shall have an adequate supply of HEPA filter elements and spare parts on-site for all types of respirators in use.
5. The following minimum respirator protection for use during paint removal or demolition of components and surfaces with lead paint shall be the half-face air purifying respirator with a minimum of dual P100 filter cartridges for exposures (not in excess of $500 \mu\text{g}/\text{m}^3$ or $10 \times \text{PEL}$).

C. Protective Clothing

1. Personal protective clothing shall be provided for all workers, supervisors, and authorized visitors entering the work area.
2. Each worker shall be provided daily with a minimum of two complete disposable coverall suits.
3. Removal workers shall not be limited to two (2) coveralls, and the Contractor shall supply additional coveralls as necessary.
4. Under no circumstances shall anyone entering the abatement area be allowed to re-use a contaminated disposable suit.
5. Disposable suits (TYVEK™ or equivalent), and other personal protective equipment (PPE) shall be donned prior to entering a lead control area. A change room shall be provided for workers to don suits and other PPE with separate areas to store street clothes and personal belongings.
6. Eye protection for personnel engaged in lead operations shall be furnished when the use of a full-face respirator is not required.
7. Goggles with side shields shall be worn when working with power tools or a material that may splash or fragment, or if protective eye wear is specified on the SDS for a particular product to be used on the project.

1.8 PERSONAL MONITORING

A. General.

1. The Contractor shall be required to perform the personal air sampling activities during lead paint disturbing work. The results of such air sampling shall be posted, provided to individual workers and submitted to the Client as described herein.

B. Air Sampling.

1. Air samples shall be collected for the duration of the work shift or for 8-hours, whichever is less. Personal air samples need not be collected every day after the first day, if working conditions remain unchanged, but must be collected each time there is a change in removal operations, either in terms of the location or in the type of work. Sampling will be used to determine 8-hour TWA. The Contractor shall be responsible for personal air sampling as outlined in OSHA Title 29 CFR, Parts 1910.1025 & 1926.62.
2. Air sampling results shall be reported to individual workers in written form no more than 48-hours after the completion of a sampling cycle. The reporting document shall list each sample's result, sampling time and date, personnel monitored and their social security numbers, flow rate, sample duration, sample yield, cassette size, and analysts' name and company, and shall include an interpretation of the results. Air sample analysis results will be reported in $\mu\text{g}/\text{m}^3$.

C. Testing Laboratory.

1. The Contractor's testing lab shall be currently participating in AIHA's Environmental Lead Laboratory Accreditation Program (ELLAP). The Contractor shall submit to the Engineer for review and acceptance, the name and address of the laboratory, certification(s) of AIHA participation, a listing of relevant experience in air lead analysis, and presentation of a documented Quality Assurance and Quality Control Program.

PART 2 - PRODUCTS

2.1 GENERAL

- A. Any substitution in materials, equipment, or methods to those specified shall be approved by the Owner, Owner, and Consultant prior to use. Any requests for substitution shall be provided in writing to the Owner, Owner, and Consultant. The request shall clearly state the rationale for the substitution.
- B. Submit to the Architect and Consultant product data of all materials and equipment and samples of all materials to be considered as an alternate.
- C. Product data shall consist of manufacturer; catalog sheets, brochures, diagrams, schedules, performance charts, illustrations, SDS, and other standard descriptive data. Submittal data shall be clearly marked to identify pertinent materials, products or equipment and show performance characteristics and capacities.
- D. Samples shall be of sufficient size and quantity to clearly illustrate the functional characteristics of the product or material with integrally related parts and attachment devices.

2.2 MATERIALS AND PRODUCTS

- A. Deliver all materials in the original packages, containers, or bundles bearing the name of the manufacturer and the brand name and product technical description.
- B. Damaged or deteriorating materials shall not be used and shall be removed from the premises.
- C. The Contractor shall have available sufficient inventory or dated purchase orders for materials necessary for the project including protective clothing, respirators, filter cartridges, polyethylene (poly) sheeting of proper size and thickness, tape, and air filters.
- D. Materials
 1. Poly sheeting in a roll size to minimize the frequency of joints shall be delivered to the Site with factory label indicating 6-mil.
 2. Poly disposable bags shall be 6-mil. Tie wraps for bags shall be plastic, five-inches long (minimum), pointed and looped to secure filled plastic bags.
 3. Tape or spray adhesive will be capable of sealing joints in adjacent poly sheets and for attachment of poly sheeting to finished or unfinished surfaces of dissimilar materials and capable of adhering onto both dry and wet conditions, including use of amended water.

4. Impermeable containers are to be used to receive and retain any lead-containing or contaminated materials until disposal at an acceptable disposal site. The containers shall be labeled in accordance with EPA and DOT standards.
5. HEPA-filtered exhaust systems shall be used during powered dust-generating abatement operations. The use of powered equipment without HEPA exhausts on this Site shall be prohibited.

2.3 TOOLS AND EQUIPMENT

- A. Provide suitable tools for all lead disturbing operations.
- B. The Contractor shall have available power cables or sources such as generators (where required).
- C. Vacuum units, of suitable size and capacities for the project, shall have HEPA filter(s) capable of trapping and retaining 99.97% of all mono-dispersed particles of 0.3 micrometers in diameter.

PART 3 - EXECUTION

3.1 PRE-CONSTRUCTION MEETING

- A. At least one week prior to the start of work, a Pre-Construction Meeting will be scheduled and must be attended by the Contractor and any Subcontractors. The assigned Contractor Site Supervisor must attend this meeting.
- B. The Contractor shall present a detailed project schedule and project submittal package at the Pre-Construction Meeting. Variations, amendments, and corrections to the presented schedule will be discussed, and the Owner and Consultant will inform the Contractor of any scheduling adjustments for this project.
- C. Following the Pre-Construction Meeting, the Contractor shall submit a revised schedule (if needed) no later than one week after the meeting.

3.2 WORKER PROTECTION/TRAINING

- A. The Contractor shall provide appropriate training, respiratory and other PPE, and biological monitoring for each worker and ensure proper usage during potential lead exposure and the initial exposure assessment.
- B. Workers who will perform procedures must have completed one of the following training courses:
 1. EPA Lead Abatement Supervisor (40-hours)
 2. EPA Lead Abatement Worker (32-hours)
 3. HUD/EPA course "Work Smart, Work Wet, and Work Clean to Work Lead Safe" (8-hours)
 4. HUD/NARI course "The Remodeler's and Renovator's Lead Based Paint Training Program" (8-hours).
 5. HUD "Lead Safe Work Practices" (8-hours)

3.3 CONTRACTOR'S RESPONSIBILITIES

- A. The Contractor shall be responsible for establishing and maintaining controls referenced herein to prevent dispersal of lead contamination from the lead work area.
- B. The Contractor shall also be responsible for conducting work with applicable federal, state, and local regulations as referenced herein.

3.4 WORKER HYGIENE PRACTICES *(Required during initial exposure assessment and if results of air sampling are above OSHA Action Level)*

- A. Work Area Entry.
 - 1. Workers shall don PPE prior to entering work area, including respiratory protection, disposable coveralls, gloves, headgear, and footwear.
- B. Work Area Departure.
 - 1. While leaving respirators on, workers shall remove all gross contamination, debris, and dust from disposable coveralls and proceed to change room, and remove coveralls and footwear and place in hazardous waste disposal container.
- C. Hand washing Facilities.
 - 1. All workers must wash their hands and faces upon leaving the work area.
- D. Equipment.
 - 1. All equipment used by workers inside the work area shall be wet-wiped or bagged for later decontamination before removal from the work area.
- E. Prohibited Activities.
 - 1. Under no circumstances shall workers eat, drink, smoke, chew gum or tobacco, apply cosmetics, or remove their respirators in the work area.
- F. Shock Hazards.
 - 1. The Contractor shall be responsible for using safe procedures to avoid electrical hazards. All temporary electrical wiring will be protected by ground fault circuit interrupters (GFCI).

3.5 LEAD WORK AREA *(Required during initial exposure assessment and if results of air sampling are above OSHA Action Level)*

- A. The Contractor shall place lead warning signs at all entrances and exits from the work area. Signage shall be a minimum of 20" x 14" and shall state the following:

**WARNING
LEAD WORK AREA
POISON
NO SMOKING OR EATING OR DRINKING
UNAUTHORIZED ENTRY PROHIBITED**

- B. The Contractor shall designate a change room as specified in this Section. The change room shall consist of two layers of 6-mil thickness poly sheeting on the floor surface adjacent to the lead work area. The change room shall have separate storage facilities for street clothes to avoid cross-contamination.
- C. The Contractor shall provide potable water for hand and face washing and provide a portable shower unit.
- D. The Contractor shall place 6- mil poly drop cloths on floor/ground surfaces prior to beginning removal work to facilitate clean-up.

3.6 WORK AREA CLEAN-UP

- A. The Contractor shall remove all loose chips and debris from floor surfaces and place in hazardous waste disposal bags.
- B. The Contractor shall clean using a HEPA-filter equipped vacuum the adjacent surfaces to remove dust and debris.
- C. Poly drop cloths shall be cleaned and properly disposed of general construction and demolition waste.

3.7 WASTE DISPOSAL

- A. The Contractor's contractual liability shall be the proper disposal of all non-hazardous wastes generated at the Site in accordance with all applicable federal, state, and local regulations as referenced herein.
 - 1. Fuss & O'Neill EnviroScience collected a sample for TCLP analysis for disposal characterization of the anticipated waste stream. The result of the TCLP analysis was < 5.0 milligrams per liter (mg/L), indicating the waste is non-hazardous and can be transported and disposed as such.

3.8 CONSULTANT

- A. The Architect may retain a Consultant for the purpose of construction administration and project monitoring during demolition work at the Site.
- B. The Consultant will represent the Architect and Owner in all tasks of the project at the discretion of the Architect.

3.9 CONSULTANT'S RESPONSIBILITIES

- A. The Consultant may conduct air sampling to ascertain the integrity of controls that protect the environmental from possible lead contamination. Independently, the Contractor shall monitor air quality within the work area to ascertain the protection of employees and to comply with OSHA regulations.
- B. The Consultant's project monitor may collect and analyze air samples during the following period:
 - 1. Demolition Period. If required, the Consultant's project monitor shall collect air samples on a daily basis during the work period. A sufficient number of area air samples shall be collected outside of the work area, to evaluate the degree of cleanliness or contamination of the environment during removal. Additional air samples may be collected inside the work area and decontamination system, at the discretion of the project monitor.
- C. If the project monitor determines that the building air quality has become contaminated from the project, they shall immediately inform the Contractor to cease all demolition operations and implement a work stoppage clean-up procedure. The Contractor shall conduct a thorough clean-up of the areas designated by the Consultant. No further removal work may occur until the Consultant has assessed that the air has been decontaminated.
- D. Pre-abatement and abatement air samples shall be collected as required to obtain a volume of 600 liters of air. Air samples shall be analyzed by NIOSH Method 7300 sampling protocol.

3.10 CONSULTANT'S INSPECTION RESPONSIBILITIES

- A. Consultant may conduct inspections throughout the progress of the demolition project. Inspections shall be conducted to document the progress of the work, as well as the procedures and practices employed by the Contractor.
- B. The Consultant shall perform the following inspections during the course of abatement activities:
 - 1. Pre-commencement Inspection. Pre-commencement inspections shall be performed at the time requested by the Contractor. The Consultant shall be informed a minimum of 12-hours prior to the time the inspection is required. If deficiencies are identified during the pre-commencement inspection, the Contractor shall perform the necessary adjustments to obtain compliance.
 - 2. Work Area Inspections. Work area inspections shall be conducted on a daily basis at the discretion of the Consultant. During the work inspections, the Consultant will observe the Contractor's removal methods and procedures, assess project progress, and inform the Contractor of specific remedial activities if deficiencies are noted.

END OF SECTION 028300

SECTION 033000 CAST-IN-PLACE CONCRETE

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Furnish all labor, materials, tools, equipment, transportation and services to complete all concrete work.

1.2 SUBMITTALS

- A. Concrete mix design shall be submitted for review.
- B. Product Data: submit manufacturer's data with application and installation instructions for all admixtures, patching compounds, waterstops, joint systems, or any other proprietary materials or items.
- C. Reinforcement shop drawings shall be submitted for review, showing fabrication, bending and placement of steel reinforcing bars. Submit four prints.
- D. Submit for review a detailed description of the methods which will be used for curing concrete, for cold weather protection of concrete, and for hot weather concreting.

1.3 STANDARDS

- A. Applicable portions of the following codes and standards are hereby made part of this specification in their entirety as though fully set forth herein.
- B. ACI 301-10 "Standard Specification for Structural Concrete."
- C. ACI 318-08 "Building Code Requirements For Reinforced Concrete" and commentary.
- D. ACI 315-99 "Details and Detailing of Concrete Reinforcement."

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Reinforcing steel shall be stored off of the ground on wood sleepers.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Concrete shall be in accordance with ASTM C94-07 "Standard Specification for Ready-Mixed Concrete."
- B. Cement: ASTM C150 TYPE I or II. Only one brand of cement shall be used.
- C. Normal weight aggregates: ASTM C33, aggregates shall be from a single source.
- D. Air entraining admixtures: ASTM C260.
- E. Water-reducing and retarding: ASTM C494, and containing not more than 1% chloride ions.
- F. Mix water shall be clean, fresh, and potable.
- G. Non-shrink grout: Five Star Grout or approved equal.
- H. Curing compounds: ASTM C309.
- I. Accelerating admixture: PolarSet by W.R. Grace or Accelguard 80 by Euclid Chemical Company or equivalent.
- J. Premolded joint filler: ASTM D1751
- K. Pumping admixture: Darex Pumping Aid by W.R. Grace or equivalent.

2.2 PROPORTIONING

- A. Concrete compressive strength at 28 days: 3500 PSI for foundation walls, grade beams and pile caps, 3500 psi for slabs on grade.
- B. Concrete proportions shall be selected in accordance with ACI 211.1-08.
- C. All concrete shall be air-entrained except interior floor slabs which are not exposed to freezing temperatures. Total air content shall be not less than 4% and not more than 8% by volume.
- D. Water-cement ratio shall not exceed 0.50.
- E. Maximum slump: 4 inches for slabs, 5 inches for all other concrete.
Minimum slump: 2 inches.
- F) The nominal maximum size of coarse aggregate shall be not larger than:
 - 1. 1/5 the narrowest dimension between sides of forms

2. 1/3 the depth of slabs
 3. 3/4 the minimum clear spacing between reinforcing bars.
- G. Calcium chloride shall not be used.
- H. All admixtures shall be approved by the Engineer.
- I. Concrete proportions shall be established on the basis of previous field experience or laboratory trial batches with the same materials to be employed in the work.
- J. Use accelerating admixture in all concrete placed at ambient temperatures below 40 degrees F.

2.3 STEEL REINFORCEMENT

- A. Recycled Content of Steel Products: Postconsumer recycled content plus one-half of preconsumer recycled content not less than 25 percent.
- B. Reinforcing Bars: ASTM A 615, Grade 60, deformed.
- C. Low-Alloy-Steel Reinforcing Bars: ASTM A 706, deformed.
- D. Reinforcing Bars: ASTM A 615, Grade 60 ASTM A 706, deformed bars, ASTM A 775, with less than 2 percent damaged coating in each 12-inch bar length.
- E. Plain-Steel Welded-Wire Reinforcement: ASTM A 1064, plain, fabricated from as-drawn steel wire into flat sheets.
- F. Deformed-Steel Welded-Wire Reinforcement: ASTM A 1064, flat sheet.
- G. Welded-Wire Reinforcement: ASTM A 884, Class A coated, Type 1, plain steel.
- H. Bar Supports: Bolsters, chairs, spacers, and other devices for spacing, supporting, and fastening reinforcing bars and welded-wire reinforcement in place. Manufacture bar supports from steel wire, plastic, or precast concrete according to CRSI's "Manual of Standard Practice."

PART 3 – EXECUTION

3.1 FORMWORK

- A. Forms shall result in a final structure that conforms to shapes, lines, and dimensions as required by the design drawings and specifications.
- B. Forms shall be substantial and sufficiently tight to prevent leakage of mortar.
- C. Forms shall be properly braced or tied together to maintain position and shape.
- D. Formwork shall conform to ACI 347.

- E. Wall forms shall be prefabricated panel forms with steel frames and plywood panels similar to Symons Steel-Ply forms. Unframed plywood panel forms similar to Simplex or Advance forms will not be permitted.
- F. Form ties shall be type with break-off or screw-out ends and plugs which may be easily removed at least 3/4" back of surface of the concrete.
- G. Before placing the reinforcing steel or the concrete, the surface of the forms shall be covered with an acceptable form release coating material that will effectively prevent absorption of moisture, prevent bond with the concrete, and not stain the concrete surfaces.
- H. Excess form release coating material shall not stand in puddles in the forms nor shall come in contact with hardened concrete against which fresh concrete is to be placed or reinforcing steel.
- I. Formwork for columns, walls, sides of beams, and other parts not supporting the weight of the concrete may be removed as soon as the concrete has hardened sufficiently to resist damage from removal operations.
- J. Forms and shoring in the formwork used to support the weight of concrete in beams, slabs and other structural members shall remain in place until the concrete has reached the minimum strength of 80% of the specified 28 day compressive strength.
- K. Install bulkheads, boxes, etc., for openings required for piping, conduits, and other equipment for other trades.
- L. Clean forms prior to concrete placement. Remove all chips, wood, sawdust, dirt, rubbish, or other debris.
- M. Chamfer strips shall be placed in the corners of forms to produce beveled edges on surfaces exposed to view.

3.2 REINFORCEMENT

- A. Reinforcing bars: ASTM A615 grade 60, $F_y = 60,000$ psi.
- B. Reinforcement shall be maintained free from dust, mud, rust, oil, ice or debris.
- C. Fabrication and placement of reinforcing steel shall be in accordance with CRSI "Manual of Standard Practice" and CRSI "Placing Reinforcing Bars".
- D. Reinforcing bars shall not be welded.
- E. Minimum cover on reinforcement:
 - 1. concrete cast against earth: 3"
 - 2. concrete exposed to earth or weather:

#6 and larger: 2"
#5 and smaller: 1½ "

3. interior surfaces:
slabs, walls, joists ¾"
beams, columns 1½"
 4. slabs on grade with vapor barrier: 1"
- F. Splices shall be lapped 40 bar diameters and securely tied.
- G. Heat shall not be used to bend reinforcing bars.
- H. Reinforcing steel shall be securely wired together at all intersections.

3.3 WELDED WIRE FABRIC

- A. Welded wire fabric: ASTM A185 and A82.
- B. Welded wire fabric shall be furnished in flat sheets, not rolls.
- C. Welded wire fabric shall be lapped 6 inches and tied at all edges.
- D. Welded wire fabric shall be fabricated and installed in accordance with "Manual of Standard Practice - Welded Wire Fabric", Wire Reinforcement Institute, Inc..
- E. Welded wire fabric in slabs on grade shall be supported off of the ground.

3.4 JOINTS AND EMBEDDED ITEMS

- A. Maximum length of pours between wall construction joints shall be 25 feet. Location of joints shall be approved by the Architect.
- B. Wall construction joints shall have a 2x4 key and horizontal wall reinforcement shall be continued across joints.
- C. Saw-cut control joints in slabs on grade and slabs on grade at 25 feet on center, maximum. Joints shall be neat and straight.
- D. Slab control joints shall be cut as soon as the concrete can accept it without raveling, but in no case later than 24 hours after concrete placement.
- E. Slab control joints shall be saw-cut to a depth of 1/4 the slab thickness.
- F. Welded wire fabric shall be stopped 6 inches on either side of slab control joints.
- G. Saw-cut control joints shall be filled with Euco 700 Epoxy Joint Filler, manufactured by The

Euclid Chemical Company or equivalent. Joints shall be filled not sooner than 90 days after slab placement. Newly cut joints should be cleaned of the slurry from saw-cutting with clean water and compressed air and covered with duct tape to prevent joint from filling with debris prior to installing joint filler.

- H. V-chamfer wall construction joints where exposed to view.
- I. Anchor bolts and other embedded items shall be positioned accurately and supported against displacement prior to concrete placement.
- J. All sleeves, inserts, anchors, and embedded items required for adjoining work or for its support shall be placed prior to concreting.
- K. All contractors whose work is related to the concrete or must be supported by it shall be given ample notice and opportunity to introduce and/or furnish embedded items before the concrete is placed.
- L. Conduits and pipes of aluminum shall not be embedded in concrete.
- M. Separate slabs on grade from foundation walls with 1/2" premolded joint filler.

3.5 PRODUCTION OF CONCRETE

- A. Concrete shall be batched, mixed and transported in accordance with ASTM C94 and ACI 304.6R-2009.
- B. Batching plant equipment and facilities shall conform to "Certification of Ready Mixed Concrete Production Facilities" of the National Ready Mixed Concrete Association.
- C. Admixtures shall be charged into the mixer as solutions and shall be measured by means of an acceptable mechanical dispensing device. The liquid shall be considered a part of the mixing water.
- D. If more than one admixture is used in the concrete, they shall be added separately.
- E. Ready-mixed concrete trucks shall not be loaded in excess of their rated capacity.

3.6 PLACING

- A. Do not pour concrete until forms and subgrade have been thoroughly cleaned and are free of frost mud, ice, water or debris.
- B. Convey concrete from truck to forms as rapidly as possible by methods which will prevent segregation or loss of ingredients. Place in forms as nearly as practicable to its final position.

- C. When placement is started, carry on as a continuous operation until the placing of a section is complete. Cold joints are not permitted.
- D. Consolidate concrete by mechanical vibration. Do not use vibrators to transport concrete in forms.
- E. No concrete shall be placed in freezing weather or when freezing weather is forecast by the Weather Bureau to occur within 36 hours, unless special measures and precautions are taken to heat the water and aggregates and to protect concrete from freezing after being placed.
 - 1. Curing And Protection: Beginning immediately after placement, concrete shall be protected from premature drying, excessively hot or cold temperatures, and mechanical damage and shall be maintained with minimal moisture loss at a relative constant temperature for the period necessary for hydration of the cement and hardening of the concrete.
 - 2. Concrete surfaces not covered by forms or within the inter-tidal elevations shall be protected from loss of surface moisture for not less than seven days using moisture protection as specified herein.
 - 3. If cold-weather concreting is anticipated, a preconstruction meeting should be held to define how cold weather concreting methods will be used. When the mean daily ambient temperature is at or below 40 degrees F or 45 degrees F and falling the Contractor shall follow the requirements of ACI 306.1, "Standard Specification for Cold Weather Concreting":
 - a. Set up proper enclosure and heat to 50 degrees F for at least two (2) hours before starting any pour. Set up individual thermometers within enclosure to monitor ambient temperatures near the face of fresh concrete. Thermometers shall be placed at a maximum of 50-foot centers, at major corners or returns, and at ends of concrete sections. Monitor and record temperatures in a log at early morning, noon, and early evening.
 - b. Use a water-reducing admixture with an accelerated set, but do not use or rely upon any material as an anti-freeze. Use of calcium chloride is not permitted.
 - c. Use vented heaters with blowers so placed that they do not produce localized hot spots which may dry out the concrete. Exposure to exhaust gases from combustion heaters is prohibited for the first 24 hours of the curing period.
 - d. Maintain the temperature of the formwork at not less than 50 degrees F. but not greater than 70 degrees F for 48 hours after completion of pour; formwork may be stripped after 72 hours after completion of pour. After 48 hours of maintaining at least 50 degrees F, the temperature may be allowed to drop gradually and shall be kept above 32 degrees F for a period of seven (7) days after completion of pour. Protection during this period may be provided by existing enclosure or by means indicated below.
 - e. Protection may be provided by use of insulation methods. Adequate insulation shall consist of at least one of the following: 12" of dry earth; provide moisture

cover if over slab concrete. 4" of hay under adequate moisture cover, 1" of insulation blankets with vapor barrier seal. Other insulating material acceptable to the Architect. NOTE: Extreme conditions of temperature or wind may require more protection.

- f. Concrete may not be placed on frozen ground.
 - g. All frozen concrete shall be removed from the job and replaced at the Contractor's expense.
- F. No concrete shall be placed when the temperature is greater than 90 degrees F unless special measures are taken to cool the water and aggregate and to protect the concrete from rapid drying.
 - G. No concrete shall be placed during rain, sleet, or snow unless protection is provided.
 - H. The maximum elapsed time between introduction of water and placing shall be one hour.
 - I. Protect adjacent finish materials against splattering or dripping of concrete during placement.

3.7 FINISHING OF FORMED SURFACES

- A. Form tie holes shall be dampened and filled with mortar.
- B. All formed surfaces exposed to view shall receive a grout rubbed finish to produce a smooth, dense surface, without pits or irregularities. All fins and projections shall be removed using a carborundum stone. Surfaces shall be saturated and brushed with a grout mix consisting of one part Portland cement to one part fine sand, filling all voids. Grout shall be smoothed with a sponge float. After the surface has dried thoroughly, it shall be rubbed with dry burlap to remove any dried grout. Finishing shall be performed within 24 hours of form removal.
- C. Top of walls shall be floated to a texture comparable to formed surfaces.
- D. Any honeycombed concrete shall be removed and patched to match adjacent concrete surfaces. Chip out all defective material to sound concrete. A bonding agent shall be used to bond the patch to the concrete.

3.8 SLABS

- A. Exterior slabs, ramps, steps, platforms and sidewalks shall receive a coarse broom finish.
- B. Finishing Tolerances: Finish floor slabs to true planes within 1/8 inch in 10 feet, as determined by a 10 foot straightedge placed anywhere on the slab in any direction.

3.9 CURING AND PROTECTION

- A. Concrete shall be maintained above 50 degrees F and in a moist condition for at least the first 7 days after placement.

- B. Provisions for curing of concrete shall be in accordance with ACI 308.1-11.
- C. Curing compound shall be Sonneborn, Kure-N-Seal, WB or equivalent.
- D. One coat of curing compound shall be applied to all slabs as soon as concrete is firm enough to walk on. The Contractor shall verify that the curing compound is compatible with the finish floor materials and where an incompatibility exists, the slab shall be moist cured.
- E. In cold weather, concrete shall be protected in accordance with ACI 306R-10.
- F. In hot weather, concrete shall be protected in accordance with ACI 305R-10.

3.10 TESTING AND INSPECTIONS

- A. All testing and inspections shall be performed by a NVLAP accredited testing and inspection service Agency/ Laboratory under a Contract Allowance specified elsewhere. Testing Agency/ Laboratory shall be hired by the Contractor and approved by the Architect and Building Inspector.
 - 1. Concrete testing and sampling.
 - 2. Steel Reinforcing inspection.
- B. The testing and inspection service Agency/Laboratory shall maintain a full time Professional Engineer on staff who shall stamp and sign all test reports.
- C. A minimum of four compression test specimens shall be made for each 50 cubic yards of concrete or not less than four for each day's placement. One cylinder shall be tested at seven days and three at 28 days. If any one of the first two cylinders tested at 28 days does not achieve the specified compressive strength, the last cylinder shall be tested at 56 days. The specimens shall be carefully stored and transported so as not to damage them in any way. Records shall be kept, identifying each cylinder with the locations of placement from which test cylinders were taken. Cylinders shall be cast in accordance with ASTM C31 and tested in accordance with ASTM C39.
- D. Slump tests shall be performed on every concrete truck load in accordance with ASTM C143.
- E. Air content shall be tested by the pressure pot method in accordance with ASTM C231. Air content tests shall be performed when each set of test cylinders are cast.
- F. If any concrete fails to develop the required 28 day strength, the Architect may order core tests at the Contractor's expense, and if the concrete in place is below strength, the Architect may order the removal and replacement of such concrete at the Contractor's expense, including the extra cost of the Architect's and Consulting Engineer's inspections and redesign.
- G. Test and Inspection reports shall be submitted to the Architect, Consulting Engineer, Contractor, and Building Inspector within 10 days of the date of test. If any test fails to meet the specifications, the Engineer shall be immediately notified.

END OF SECTION 033000

SECTION 051200 - STRUCTURAL STEEL FRAMING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Structural steel.
2. Grout.

1.2 DEFINITIONS

- A. Structural Steel: Elements of the structural frame indicated on Drawings and as described in AISC-05,AISC 303, "Code of Standard Practice for Steel Buildings and Bridges."

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Show fabrication of structural-steel components.
1. Erection plans
 2. Fabrication and piece details of all steel members and connections

1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For fabricator

1.5 QUALITY ASSURANCE

- A. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1,"Structural Welding Code - Steel."
- B. Comply with applicable provisions of the following specifications and documents:
1. AISC-05,AISC 303.
 2. AISC-05,AISC 360.
 3. RCSC's "Specification for Structural Joints Using ASTM A 325 or A 490 Bolts."

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Connections: Provide details of simple shear connections required by the Contract Documents to be selected or completed by structural-steel fabricator to withstand loads indicated and comply with other information and restrictions indicated.
 - 1. Select and complete connections using schematic details indicated and AISC 360.

2.2 STRUCTURAL-STEEL MATERIALS

- A. Rolled Shapes: ASTM A992
 - 1. Finish: Shop prime, except where encased in concrete.
- B. Channels, Angles, M-Shapes: ASTM A 36, Grade 36 .
 - 1. Finish: Shop prime, except where encased in concrete.
 - 2. Finish: Hot-dip zinc coating, ASTM A 153, Class C, where exposed to view.
- C. Plate and Bar: ASTM A 36, Grade 36.
 - 1. Finish: Shop prime, except where encased in concrete.
- D. Steel Pipe: ASTM A 53, Structural Pipe, or ASTM A-501.
 - 1. Finish: Shop prime, except where encased in concrete.
- E. Tube Shapes: ASTM A500, Grade B.
 - 1. Finish: Shop prime, except where encased in concrete.
- F. Welding Electrodes: ASTM A-233, Type E70XX series for all structural connections.

2.3 BOLTS, CONNECTORS, AND ANCHORS

- A. High-Strength Bolts, Nuts, and Washers: ASTM A 325, Type 1, heavy-hex steel structural bolts; Type 1, hardened carbon-steel washers; all with plain finish.
 - 1. Direct-Tension Indicators: ASTM F 959, Type 325 compressible-washer type with plain finish.
- B. Unheaded Anchor Rods: ASTM F 1554, Grade 36, weldable.
 - 1. Configuration: Hooked.
 - 2. Finish: Hot-dip zinc coating, ASTM A 153, Class C.
- C. Headed Anchor Rods: ASTM F 1554, Grade 36 , weldable, straight.
 - 1. Finish: Hot-dip zinc coating, ASTM A 153, Class C.

D. Threaded Rods: ASTM A 36, Grade B7.

1. Finish: Hot-dip zinc coating, ASTM A 153, Class C.

2.4 PRIMER

A. Primer: SSPC-Paint 25, Type I, red zinc oxide, rust inhibitive primer.

B. Primer: Fabricator's standard lead- and chromate-free, nonasphaltic, rust-inhibiting primer complying with MPI#79 and compatible with topcoat.

2.5 GROUT

A. Nonmetallic, Shrinkage-Resistant Grout: ASTM C-827, with a minimum 2500 PSI at 28 day compressive strength factory-packaged, nonmetallic aggregate grout, noncorrosive and nonstaining, mixed with water to consistency suitable for application and a 30-minute working time.

2.6 FABRICATION

A. Structural Steel: Fabricate and assemble in shop to greatest extent possible. Fabricate according to AISC 303, "Code of Standard Practice for Steel Buildings and Bridges," and to AISC 360.

2.7 SHOP CONNECTIONS

A. High-Strength Bolts: Shop install high-strength bolts according to RCSC's "Specification for Structural Joints Using ASTM A 325 or A 490 Bolts" for type of bolt and type of joint specified.

1. Bolts: $\frac{3}{4}$ inch diameter.

2. Joint Type: Tension control, fully tightened. Snub type not permitted.

B. Weld Connections: Comply with AWS D1.1 and AWS D1.8 for tolerances, appearances, welding procedure specifications, weld quality, and methods used in correcting welding work.

2.8 SHOP PRIMING

A. Shop prime steel surfaces except the following:

1. Surfaces embedded in concrete or mortar. Extend priming of partially embedded members to a depth of 2 inches.

2. Surfaces to be field welded.

3. Surfaces of high-strength bolted, slip-critical connections.

4. Galvanized surfaces.

- B. Surface Preparation: Clean surfaces to be painted. Remove loose rust and mill scale and spatter, slag, or flux deposits. Prepare surfaces according to the following specifications and standards:
 - 1. SSPC-SP 2, "Hand Tool Cleaning."
 - 2. SSPC-SP 3, "Power Tool Cleaning."
 - 3. SSPC-SP 7/NACE No. 4, "Brush-off Blast Cleaning."
- C. Priming: Immediately after surface preparation, apply primer according to manufacturer's written instructions and at rate recommended by SSPC to provide a minimum dry film thickness of 1.5 mils. Use priming methods that result in full coverage of joints, corners, edges, and exposed surfaces.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verify, with certified steel erector present, elevations of concrete- and masonry-bearing surfaces and locations of anchor rods, bearing plates, and other embedments for compliance with requirements.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 ERECTION

- A. Set structural steel accurately in locations and to elevations indicated and according to AISC 303 and AISC 360.
- B. Baseplates, Bearing Plates and Leveling Plates: Clean concrete- and masonry-bearing surfaces of bond-reducing materials, and roughen surfaces prior to setting plates. Clean bottom surface of plates.
 - 1. Set plates for structural members on wedges, shims, or setting nuts as required.
 - 2. Weld plate washers to top of baseplate.
 - 3. Snug-tighten anchor rods after supported members have been positioned and plumbed. Do not remove wedges or shims but, if protruding, cut off flush with edge of plate before packing with grout.
 - 4. Promptly pack grout solidly between bearing surfaces and plates so no voids remain. Neatly finish exposed surfaces; protect grout and allow to cure. Comply with manufacturer's written installation instructions for shrinkage-resistant grouts.
- C. Maintain erection tolerances of structural steel within AISC 303, "Code of Standard Practice for Steel Buildings and Bridges."

3.3 FIELD CONNECTIONS

- A. Weld Connections: Comply with AWS D1.1 and AWS D1.8 for tolerances, appearances, welding procedure specifications, weld quality, and methods used in correcting welding work.
 - 1. Comply with AISC 303 and AISC 360 for bearing, alignment, adequacy of temporary connections, and removal of paint on surfaces adjacent to field welds.
 - 2. Remove backing bars or runoff tabs where indicated, back gouge, and grind steel smooth.
 - 3. Assemble and weld built-up sections by methods that maintain true alignment of axes without exceeding tolerances in AISC 303, "Code of Standard Practice for Steel Buildings and Bridges," for mill material.

3.4 SOURCE QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform shop tests and inspections.
 - 1. Provide testing agency with access to places where structural-steel work is being fabricated or produced to perform tests and inspections.
- B. Moment Connections: Inspect and test moment connections using ultrasonic testing in accordance with ASTM E164.
- C. Bolted Connections: Inspect and test shop-bolted connections according to RCSC's "Specification for Structural Joints Using ASTM A 325 or A 490 Bolts."
- D. Welded Connections: Visually inspect shop-welded connections according to AWS D1.1 and the following inspection procedures, at testing agency's option:
 - 1. Liquid Penetrant Inspection: ASTM E 165.
 - 2. Magnetic Particle Inspection: ASTM E 709; performed on root pass and on finished weld. Cracks or zones of incomplete fusion or penetration are not accepted.
 - 3. Ultrasonic Inspection: ASTM E 164.
 - 4. Radiographic Inspection: ASTM E 94.
- E. Prepare test and inspection reports.

END OF SECTION 051200

SECTION 061000 - ROUGH CARPENTRY

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Framing with dimension lumber.
2. Framing with engineered wood products.
3. Wood blocking and nailers.
4. Wood furring
5. Plywood backing panels.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of process and factory-fabricated product.

1. Include data for wood-preservative treatment from chemical treatment manufacturer and certification by treating plant that treated materials comply with requirements.
2. Include data for fire retardant treatment from chemical treatment manufacturer and certification by treating plant that treated materials comply with requirements.

1.3 INFORMATIONAL SUBMITTALS

A. Material Certificates: For dimension lumber specified to comply with minimum allowable unit stresses. Indicate species and grade selected for each use and design values approved by the ALSC Board of Review.

B. Evaluation Reports: For the following, from ICC-ES:

1. Wood-preservative-treated wood.
2. Fire-retardant-treated wood.
3. Engineered wood products.
4. Power-driven fasteners.
5. Powder-actuated fasteners.
6. Expansion anchors.
7. Metal framing anchors.

PART 2 - PRODUCTS

2.1 WOOD PRODUCTS, GENERAL

- A. Lumber: DOC PS 20 and applicable rules of grading agencies indicated. If no grading agency is indicated, provide lumber that complies with the applicable rules of any rules-writing agency certified by the ALSC Board of Review. Provide lumber graded by an agency certified by the ALSC Board of Review to inspect and grade lumber under the rules indicated.
 - 1. Factory mark each piece of lumber with grade stamp of grading agency.
 - 2. For exposed lumber indicated to receive a stained or natural finish, mark grade stamp on end or back of each piece.
 - 3. Provide dressed lumber, S4S, unless otherwise indicated.
- B. Maximum Moisture Content of Lumber: 19 percent for 2-inch nominal thickness or less, 19 percent for more than 2-inch nominal thickness unless otherwise indicated.
- C. Engineered Wood Products: Provide engineered wood products acceptable to authorities having jurisdiction and for which current model code research or evaluation reports exist that show compliance with building code in effect for Project.
 - 1. Allowable Design Stresses: Provide engineered wood products with allowable design stresses, as published by manufacturer, that meet or exceed those indicated. Manufacturer's published values shall be determined from empirical data or by rational engineering analysis and demonstrated by comprehensive testing performed by a qualified independent testing agency.

2.2 WOOD-PRESERVATIVE-TREATED LUMBER

- A. Preservative Treatment by Pressure Process: AWPA U1; Use Category UC2 for interior construction not in contact with the ground, Use Category UC3b for exterior construction not in contact with the ground, and Use Category UC4a for items in contact with the ground.
 - 1. Preservative Chemicals: Acceptable to authorities having jurisdiction and containing no arsenic or chromium. Do not use inorganic boron (SBX) for sill plates.
- B. Kiln-dry lumber after treatment to a maximum moisture content of 19 percent. Do not use material that is warped or that does not comply with requirements for untreated material.
- C. Mark lumber with treatment quality mark of an inspection agency approved by the ALSC Board of Review.
- D. Application: Treat items indicated on Drawings, and the following:
 - 1. Wood , nailers, curbs, blocking, and similar members in connection with roofing, flashing, vapor barriers, and waterproofing.
 - 2. Wood sills, sleepers, blocking, furring, and similar concealed members in contact with masonry or concrete.

3. Wood framing and furring attached directly to the interior of below-grade exterior masonry or concrete walls.
4. Wood framing members that are less than 18 inches above the ground in crawlspaces or unexcavated areas.
5. Wood floor plates that are installed over concrete slabs-on-grade.

2.3 FIRE-RETARDANT-TREATED MATERIALS

- A. General: Where fire-retardant-treated materials are indicated, use materials complying with requirements in this article, that are acceptable to authorities having jurisdiction, and with fire-test-response characteristics specified as determined by testing identical products per test method indicated by a qualified testing agency.
- B. Fire-Retardant-Treated Lumber and Plywood by Pressure Process: Products with a flame spread index of 25 or less when tested according to ASTM E 84, and with no evidence of significant progressive combustion when the test is extended an additional 20 minutes, and with the flame front not extending more than 10.5 feet beyond the centerline of the burners at any time during the test.
 1. Exterior Type: Treated materials shall comply with requirements specified above for fire-retardant-treated lumber and plywood by pressure process after being subjected to accelerated weathering according to ASTM D 2898. Use for exterior locations and where indicated.
 2. Interior Type A: Treated materials shall have a moisture content of 28 percent or less when tested according to ASTM D 3201 at 92 percent relative humidity. Use where exterior type is not indicated.
- C. Kiln-dry lumber after treatment to a maximum moisture content of 19 percent. Kiln-dry plywood after treatment to a maximum moisture content of 15 percent.
- D. Identify fire-retardant-treated wood with appropriate classification marking of qualified testing agency.
- E. Application: Treat items indicated on Drawings, and the following:
 1. Attic floor
 2. Exposed plywood backing panels.

2.4 DIMENSION LUMBER FRAMING

- A. Non-Load-Bearing Interior Partitions: Construction or No. 2 grade or better.
 1. Application: All interior partitions.
 2. Species:
 - a. Douglas Fir-Larch (north); NLGA
 - b. Eastern softwoods; NeLMA.

- B. Framing Other Than Non-Load-Bearing Interior Partitions: No. 2 grade or better.
 - 1. Application: Framing other than interior partitions.
 - 2. Species:
 - a. Southern pine; SPIB.
 - b. Douglas fir-larch (north); NLGA.

- C. Exposed Framing: Provide material hand-selected for uniformity of appearance and freedom from characteristics, on exposed surfaces and edges, that would impair finish appearance, including decay, honeycomb, knot-holes, shake, splits, torn grain, and wane.
 - 1. Application: Exposed exterior and interior framing indicated to receive a stained or natural finish.
 - 2. Species and Grade: As indicated above for load-bearing construction of same type.

2.5 ENGINEERED WOOD PRODUCTS

- A. Engineered Wood Products, General: Products shall contain no urea formaldehyde.

- B. Laminated-Veneer Lumber: Structural composite lumber made from wood veneers with grain primarily parallel to member lengths, evaluated and monitored according to ASTM D 5456 and manufactured with an exterior-type adhesive complying with ASTM D 2559.
 - 1. Manufacturer: I-Level-Microlam by Weyerhaeuser or equivalent.
 - 2. Flexural stress, $F_b = 2,600$ psi.
 - 3. Modulus of elasticity, $E = 1,900,000$ psi.
 - 4. Compression perpendicular to grain, $F_{c\perp} = 750$ psi
 - 5. Compression parallel to grain, $F_{c\parallel} = 2,510$ psi
 - 6. Horizontal shear, $F_v = 285$ psi.
 - 7. Tension Stress, $F_t = 1,555$ psi

- C. Parallel strand lumber, PSL manufactured by Weyerhaeuser or Equivalent, Service Level 1. PSL material shall have the following minimum allowable stresses:
 - 1. Flexural stress, $F_b = 2,900$ psi.
 - 2. Modulus of elasticity, $E = 2,00,000$ psi.
 - 3. Compression perpendicular to grain, $F_{c\perp} = 750$ psi
 - 4. Compression parallel to grain, $F_{c\parallel} = 2,900$ psi
 - 5. Horizontal shear, $F_v = 290$ psi.
 - 6. Tension Stress, $F_t = 2,025$ psi

- D. P.T. Parallel strand lumber, PSL shall be Wolmanized Parallam manufactured by Weyerhaeuser, service level 2 or equivalent. PSL material shall have the following minimum allowable stresses:
 - 1. Flexural stress, $F_b = 1,827$ psi.

2. Modulus of elasticity, $E = 1,460,000$ psi.
3. Compression perpendicular to grain, $F_{c\perp} = 368$ psi
4. Compression parallel to grain, $F_{c\parallel} = 1,508$ psi
5. Horizontal shear, $F_v = 197$ psi.
6. Tension Stress, $F_t = 1,397$ psi

E. Wood I-Joists: Prefabricated units, I-shaped in cross section, made with solid or structural composite lumber flanges and wood-based structural panel webs, let into and bonded to flanges. Provide units complying with material requirements of and with structural capacities established and monitored according to ASTM D 5055.

1. Manufacturer: Trus-Joist or equivalent.
2. Web Material: Either oriented strand board or plywood, complying with DOC PS 1 or DOC PS 2, Exposure 1.
3. Structural Properties: Provide units with depths and design values not less than those indicated.
4. APA ratings referenced in subparagraph below are easy to designate structural properties required, but retaining below may reduce competition by eliminating manufacturers that do not participate in APA program. See Evaluations.
5. Provide units complying with APA PRI-400, factory marked with APA trademark indicating nominal joist depth, joist class, span ratings, mill identification, and compliance with APA standard.
6. Refer to drawings for related information.

F. Rim Boards: Product designed to be used as a load-bearing member and to brace wood I-joists at bearing ends, complying with research/evaluation report for I-joists.

1. Material: All-veneer product or product made from any combination solid lumber, wood strands, and veneers .
2. Thickness: 1-1/4 inches.
3. Provide performance-rated product complying with APA PRR-401, rim board grade, factory marked with APA trademark indicating thickness, grade, and compliance with APA standard.
4. 1.3 E "Timberland" LSL rim board material, unless otherwise noted on the drawings. Rim depth shall match I Joist depth.

2.6 MISCELLANEOUS LUMBER

A. General: Provide miscellaneous lumber indicated and lumber for support or attachment of other construction, including the following:

1. Blocking.
2. Nailers.
3. Furring.
4. Grounds.

B. For items of dimension lumber size, provide Construction or No. 2 grade lumber of any species.

- C. For concealed boards, provide lumber with **15** percent maximum moisture content and any of the following species and grades:
 - 1. Eastern softwoods; No. 2 Common grade; NeLMA.
 - 2. Northern species; No. 2 Common grade; NLGA.

2.7 PLYWOOD BACKING PANELS

- A. Equipment Backing Panels: DOC PS 1, fire-retardant treated, in thickness indicated or, if not indicated, not less than 3/4-inch nominal thickness.
 - 1. Plywood shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

2.8 FASTENERS

- A. General: Provide fasteners of size and type indicated that comply with requirements specified in this article for material and manufacture.
 - 1. Where rough carpentry is exposed to weather, in ground contact, pressure-preservative treated, or in area of high relative humidity, provide fasteners with hot-dip zinc coating complying with ASTM A 153.
- B. Power-Driven Fasteners: NES NER-272.
- C. Bolts: Steel bolts complying with ASTM A 307, Grade ; with ASTM A 563 hex nuts and, where indicated, flat washers.

2.9 METAL FRAMING ANCHORS

- A. Metal Framing Anchors: Manufactured by Simpson Strong Tie or an approve equal.
- B. Allowable Design Loads: Provide products with allowable design loads, as published by manufacturer, that meet or exceed those of basis-of-design products. Manufacturer's published values shall be determined from empirical data or by rational engineering analysis and demonstrated by comprehensive testing performed by a qualified independent testing agency.
- C. Galvanized-Steel Sheet: Hot-dip, zinc-coated steel sheet complying with ASTM A 653/A 653M, G60 coating designation.
 - 1. Use for interior locations unless otherwise indicated.
- D. Hot-Dip, Heavy-Galvanized Steel Sheet: ASTM A 653; structural steel (SS), high-strength low-alloy steel Type A (HSLAS Type A), or high-strength low-alloy steel Type B (HSLAS Type B); G185 coating designation; and not less than 0.036 inch thick.

1. Use for wood-preserved-treated lumber and where indicated.

2.10 MISCELLANEOUS MATERIALS

- A. Sill-Sealer Gaskets: Glass-fiber-resilient insulation, fabricated in strip form, for use as a sill sealer; 1-inch nominal thickness, compressible to 1/32 inch ; selected from manufacturer's standard widths to suit width of sill members indicated.
- B. Flexible Flashing: Composite, self-adhesive, flashing product consisting of a pliable, butyl rubber compound, bonded to a high-density polyethylene film, aluminum foil, or spunbonded polyolefin to produce an overall thickness of not less than 0.025 inch.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Set rough carpentry to required levels and lines, with members plumb, true to line, cut, and fitted. Fit rough carpentry to other construction; scribe and cope as needed for accurate fit. Locate furring, nailers, blocking, grounds, and similar supports to comply with requirements for attaching other construction.
- B. Framing Standard: Comply with AF&PA's WCD 1, "Details for Conventional Wood Frame Construction," unless otherwise indicated.
- C. Framing with Engineered Wood Products: Install engineered wood products to comply with manufacturer's written instructions.
- D. Install fire-retardant treated plywood backing panels with classification marking of testing agency exposed to view.
- E. Metal Framing Anchors: Install metal framing anchors to comply with manufacturer's written instructions. Install fasteners through each fastener hole.
- F. Do not splice structural members between supports unless otherwise indicated.
- G. Comply with AWWA M4 for applying field treatment to cut surfaces of preservative-treated lumber.
- H. Where wood-preserved-treated lumber is installed adjacent to metal decking, install continuous flexible flashing separator between wood and metal decking.
- I. Securely attach rough carpentry work to substrate by anchoring and fastening as indicated, complying with the following:
 1. NES NER-272 for power-driven fasteners.

2. Table R602.3(1), "Fastener Schedule for Structural Members," and Table R602.3(2), "Alternate Attachments," ICC's International Residential Code for One- and Two-Family Dwellings, as referenced by the State of Connecticut Building Code

3.2 PROTECTION

- A. Protect wood that has been treated with inorganic boron (SBX) from weather. If, despite protection, inorganic boron-treated wood becomes wet, apply EPA-registered borate treatment. Apply borate solution by spraying to comply with EPA-registered label.
- B. Protect rough carpentry from weather. If, despite protection, rough carpentry becomes wet, apply EPA-registered borate treatment. Apply borate solution by spraying to comply with EPA-registered label.

END OF SECTION 061000

SECTION 061600 - SHEATHING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Wall sheathing.
2. Roof sheathing.
3. Subflooring.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of process and factory-fabricated product. Indicate component materials and dimensions and include construction and application details.
1. Include data for wood-preservative treatment from chemical treatment manufacturer and certification by treating plant that treated plywood complies with requirements.

1.3 INFORMATIONAL SUBMITTALS

- A. Evaluation Reports: For following products, from ICC-ES:
1. Preservative-treated plywood.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

2.2 WOOD PANEL PRODUCTS

- A. Emissions: Products shall meet the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- B. Plywood: DOC PS 1.

2.3 PRESERVATIVE-TREATED PLYWOOD

- A. Preservative Treatment by Pressure Process: AWPA U1; Use Category UC2 for interior construction, Use Category UC3b for exterior construction.
- B. Mark plywood with appropriate classification marking of an inspection agency acceptable to authorities having jurisdiction.
- C. Application: Treat items indicated on Drawings and plywood in contact with masonry or concrete or used with roofing, flashing, vapor barriers, and waterproofing.

2.4 WALL SHEATHING

- A. Plywood Wall Sheathing: APA rated, Exterior, Structural I sheathing.
 - 1. Span rating: 12/0, 16/0,20/0 for stud spacing 16 inches on center or less.
 - 2. Thickness: as indicated on the drawings.

2.5 ROOF SHEATHING

- A. Plywood Roof Sheathing: APA rated, Exterior, Structural I sheathing.
 - 1. Thickness: as indicated on the drawings.

2.6 SUBFLOORING AND UNDERLAYMENT

- A. Plywood Combination Subfloor-Underlayment: DOC PS 1, Exterior, Structural I, C-C Plugged single-floor panels.
- B. Plywood Subflooring: Exterior, Structural I single-floor panels or sheathing.

2.7 FASTENERS

- A. General: Provide fasteners of size and type indicated that comply with requirements specified in this article for material and manufacture.
 - 1. For roof and wall sheathing, provide fasteners with hot-dip zinc coating complying with ASTM A 153 Type 304 stainless steel.

2.8 MISCELLANEOUS MATERIALS

- A. Adhesives for Field Gluing Panels to Framing: Formulation complying with APA AFG-01 ASTM D 3498 that is approved for use with type of construction panel indicated by manufacturers of both adhesives and panels.
 - 1. Adhesives shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

2. Adhesives shall comply with the testing and product requirements of the California Department of Health Service "Standard Practice for the Testing of Volatile Organic Emissions for Various Materials using Small Scale Environmental Chambers".

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Do not use materials with defects that impair quality of sheathing or pieces that are too small to use with minimum number of joints or optimum joint arrangement. Arrange joints so that pieces do not span between fewer than three support members.
- B. Cut panels at penetrations, edges, and other obstructions of work; fit tightly against abutting construction unless otherwise indicated.
- C. Securely attach to substrate by fastening as indicated, complying with the following:
 1. NES NER-272 for power-driven fasteners.
 2. Table R602.3(1), "Fastener Schedule for Structural Members," and Table R602.3(2), "Alternate Attachments," in ICC's "International Residential Code for One- and Two-Family Dwellings."
- D. Coordinate wall and roof sheathing installation with flashing and joint-sealant installation so these materials are installed in sequence and manner that prevent exterior moisture from passing through completed assembly.
- E. Do not bridge building expansion joints; cut and space edges of panels to match spacing of structural support elements.

3.2 WOOD STRUCTURAL PANEL INSTALLATION

- A. General: Comply with applicable recommendations in APA Form No. E30, "Engineered Wood Construction Guide," for types of structural-use panels and applications indicated.
- B. Fastening Methods: Fasten panels as indicated below:
 1. Combination Subfloor-Underlayment:
 - a. Glue and nail to wood framing.
 - b. Space panels 1/8 inch apart at edges and ends.
 2. Subflooring:
 - a. Glue and nail to wood framing.
 - b. Space panels 1/8 inch apart at edges and ends.

3. Wall and Roof Sheathing:
 - a. Nail to wood framing.
 - b. Space panels 1/8 inch apart at edges and ends.

END OF SECTION 061600

SECTION 062013 - EXTERIOR FINISH CARPENTRY

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Exterior cellular PVC and foam plastic trim.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of process and factory-fabricated product.
- B. Samples: For each type of product involving selection of colors, profiles, or textures.

1.3 INFORMATIONAL SUBMITTALS

- A. Compliance Certificates:
 - 1. For lumber that is not marked with grade stamp.
 - 2. For preservative-treated wood that is not marked with treatment-quality mark.
- B. Evaluation Reports: For the following, from ICC-ES:
 - 1. Wood-preservative-treated wood
 - 2. Cellular PVC trim.
 - 3. Foam plastic moldings.

PART 2 - PRODUCTS

2.1 MATERIALS, GENERAL

- A. Lumber: DOC PS 20.
 - 1. Factory mark each piece of lumber with grade stamp of inspection agency indicating grade, species, moisture content at time of surfacing, and mill.
 - a. For exposed lumber, mark grade stamp on end or back of each piece.

2.2 WOOD-PRESERVATIVE-TREATED MATERIALS

- A. Preservative Treatment by Pressure Process: AWWPA U1; Use Category UC3b.
1. Kiln dry lumber after treatment to a maximum moisture content of 19 and 18 percent respectively.
 2. Preservative Chemicals: Acceptable to authorities having jurisdiction and containing no arsenic or chromium.
 3. Application: All exterior lumber.

2.3 EXTERIOR TRIM

- A. Lumber Trim:
1. Species and Grade: Southern pine, pressure-preservative treated; B & B; SPIB.
 2. Maximum Moisture Content: 19 percent.
 3. Face Surface: Surfaced (smooth).
- B. Cellular PVC Trim: Extruded, expanded PVC with a small-cell microstructure, recommended by manufacturer for exterior use, made from UV- and heat-stabilized, rigid material.
1. Manufacturer: Azek or an approved equal.
 2. Shapes and profiles: As indicated on the drawings.
 3. Density: Not less than 31 lb/cu. ft. .
 4. Heat Deflection Temperature: Not less than 130 deg F, according to ASTM D 648.
 5. Water Absorption: Not more than 1 percent, according to ASTM D 570.
 6. Flame-Spread Index: 75 or less, according to ASTM E 84.

2.4 MISCELLANEOUS MATERIALS

- A. Fasteners for Exterior Finish Carpentry: Provide nails or screws, in sufficient length to penetrate not less than 1-1/2 inches into wood substrate.
1. For prefinished items, provide matching prefinished aluminum fasteners where face fastening is required.
 2. For applications not otherwise indicated, provide stainless-steel fasteners.
 3. For exterior trim, provide stainless steel finish nails or trim screws.

2.5 METAL FRAMING ANCHORS

- A. Metal Framing Anchors: Manufactured by Simpson Strong Tie or an approve equal.
- B. Allowable Design Loads: Provide products with allowable design loads, as published by manufacturer, that meet or exceed those of basis-of-design products. Manufacturer's published values shall be determined from empirical data or by rational engineering analysis and demonstrated by comprehensive testing performed by a qualified independent testing agency.

- C. Hot-Dip, Heavy-Galvanized Steel Sheet: ASTM A 653; structural steel (SS), high-strength low-alloy steel Type A (HSLAS Type A), or high-strength low-alloy steel Type B (HSLAS Type B); G185 coating designation; and not less than 0.036 inch thick.
 - 1. Use for wood-preservative-treated lumber and where indicated.
- D. Sealants: Latex, complying with ASTM C 834 Type OP, Grade NF and with applicable requirements in Section 079200 "Joint Sealants," recommended by sealant manufacturer and manufacturer of substrates for intended application.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Install exterior finish carpentry level, plumb, true, and aligned with adjacent materials. Use concealed shims where necessary for alignment.
 - 1. Scribe and cut exterior finish carpentry to fit adjoining work. Refinish and seal cuts as recommended by manufacturer.
 - 2. Install stairs with no more than 3/16-inch variation between adjacent treads and risers and with no more than 3/8-inch variation between largest and smallest treads and risers within each flight.

3.2 STANDING AND RUNNING TRIM INSTALLATION

- A. Install cellular PVC trim to comply with manufacturer's written instructions.
- B. Install trim with minimum number of joints practical, using full-length pieces from maximum lengths of lumber available. Do not use pieces less than 24 inches long except where necessary.
 - 1. Use scarf joints for end-to-end joints.
 - 2. Stagger end joints in adjacent and related members.
- C. Fit exterior joints to exclude water. Cope at returns and miter at corners.
- D. Countersink fasteners and fill fastener holes flush with matching color sealant or manufacturer provided filler.

END OF SECTION 062013

SECTION 064300 – INTERIOR WOOD STAIRS AND RAILINGS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Interior wood stairs and railings, including rough carriages for stairs.
2. Attic access pull down ladder.

1.2 ACTION SUBMITTALS

- A. Shop Drawings: Show location of each item, dimensioned plans and elevations, large-scale details, attachment devices, and other components.

1.3 INFORMATIONAL SUBMITTALS

- A. Woodwork Quality Standard Compliance Certificates: AWI Quality Certification Program certificates.

1.4 QUALITY ASSURANCE

- A. Fabricator Qualifications: Certified participant in AWI's Quality Certification Program
- B. Installer Qualifications: Fabricator of products and Certified participant in AWI's Quality Certification Program.

1.5 FIELD CONDITIONS

- A. Environmental Limitations: Do not deliver or install wood stairs and railings until building is enclosed, wet work is complete, and HVAC system is operating and maintaining temperature and relative humidity at occupancy levels during the remainder of the construction period.

PART 2 - PRODUCTS

2.1 WOODWORK MANUFACTURERS

- A. Manufacturer: Basis of Design, subject to compliance with requirements, provide products as indicated on the drawings or an approved equal.

2.2 WOOD STAIRS AND RAILINGS

- A. Quality Standard: Unless otherwise indicated, comply with the "Architectural Woodwork Standards" for grades of interior architectural woodwork indicated for construction, finishes, installation, and other requirements.
- B. Grade: Premium.
- C. Wood for Transparent Finish: Red Oak
- D. Wood for Opaque Finish: Poplar

2.3 WOOD MATERIALS

- A. Wood Products: Provide materials that comply with requirements of referenced quality standard for each type of woodwork and quality grade specified unless otherwise indicated.
 - 1. Wood Moisture Content: 5 to 10 percent.

2.4 MISCELLANEOUS MATERIALS

- A. Furring, Blocking, Shims, and Hanging Strips: Softwood or hardwood lumber, kiln dried to less than 15 percent moisture content.
- B. Rough Carriages for Stairs: Laminated veneer lumber, made with an exterior-type adhesive complying with ASTM D 2559, and with the following allowable design values as determined according to ASTM D 5456:
 - 1. Extreme Fiber Stress in Bending, Edgewise: 3100 psi for 12-inch nominal-depth members.
 - 2. Modulus of Elasticity, Edgewise: 2,000,000 psi.
- C. Anchors: Select material, type, size, and finish required for each substrate for secure anchorage. Provide metal expansion sleeves or expansion bolts for post-installed anchors. Use nonferrous-metal or hot-dip galvanized anchors and inserts at inside face of exterior walls and at floors.

- D. Handrail Brackets: Cast from aluminum with wall flange drilled for exposed anchor and tapped for concealed hanger bolt and with support arm for screwing to underside of rail. Sized to provide 1-1/2-inch clearance between handrail and wall.
- E. Adhesives: Do not use adhesives that contain urea formaldehyde.
- F. VOC Limits for Installation Adhesives and Sealants: Use products that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
 - 1. Wood Glues: 30 g/L.
 - 2. Multipurpose Construction Adhesives: 70 g/L.
 - 3. Structural Wood Member Adhesive: 140 g/L.

2.5 FABRICATION

- A. Fabricate wood stairs and railings to dimensions, profiles, and details indicated. Ease edges to radius indicated for the following:
 - 1. Corners of Solid-Wood (Lumber) Members: 1/16 inch unless otherwise indicated.
- B. Complete fabrication, including assembly and hardware application, to maximum extent possible before shipment to Project site. Disassemble components only as necessary for shipment and installation. Where necessary for fitting at site, provide ample allowance for scribing, trimming, and fitting.
- C. Cut carriages to accurately fit treads and risers. Glue treads to risers, and glue and nail treads and risers to carriages.
 - 1. Fabricate stairs with treads and risers no more than 1/8 inch from indicated position and no more than 1/16 inch out of relative position for adjacent treads and risers.

2.6 ATTIC ACCESS PULL DOWN LADDER

- A. Manufacturers standard aluminum pull down attic ladder with insulated flush ceiling cover.
 - 1. Manufacturer: Werner or an approved equal.
 - 2. Model: AE2210
 - 3. Rough opening: 22 1/2inches by 54 inches

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before installation, condition wood stairs and railings to average prevailing humidity conditions in installation areas.

3.2 INSTALLATION

- A. Grade: Install wood stairs and railings to comply with same grade as item to be installed.
- B. Stairs: Securely anchor carriages to supporting substrates. Install stairs with treads and risers no more than 1/8 inch from indicated position.
- C. Railings:
 - 1. General: Install rails with no more than 1/8 inch in 96-inch variation from a straight line.
 - 2. Stair Rails: Glue and dowel or pin balusters to treads and railings, and railings to newel posts.
 - 3. Wall Rails: Support rails on indicated metal brackets securely fastened to wall framing.
- D. Touch up finishing work specified in this Section after installation of wood stairs and railings. Fill nail holes with matching filler where exposed.
- E. Attic pull down ladder:
 - 1. Install in accordance with manufacturers printed instructions.

END OF SECTION 064300

SECTION 064600 – INTERIOR WOOD TRIM AND FRAMES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Interior standing and running trim.
 - 2. Interior wood frames, jambs and casings.
 - 3. Shop priming interior trim and frames.
 - 4. Closet and utility shelving.
 - 5. Wood furring, blocking, shims, and hanging strips for installing woodwork items unless concealed within other construction before woodwork installation.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Show location of each item, dimensioned plans and elevations, large-scale details, attachment devices, and other components.
- C. Samples: For each type of interior trim.

1.3 FIELD CONDITIONS

- A. Weather Limitations for Exterior Work: Proceed with installation of exterior wood trim only when existing and forecasted weather conditions permit work to be performed and at least one coat of specified finish to be applied without exposure to rain, snow, or dampness.
- B. Environmental Limitations for Interior Work: Do not deliver or install interior wood trim until building is enclosed, wet work is complete, and HVAC system is operating and maintaining temperature and relative humidity at occupancy levels during the remainder of the construction period.

PART 2 - PRODUCTS

2.1 WOOD TRIM FABRICATORS

- A. Fabricators: Subject to compliance with requirements, fabricator optional, subject to Architect's acceptance.

2.2 WOOD TRIM AND FRAMES, GENERAL

- A. Quality Standard: Unless otherwise indicated, comply with the "Architectural Woodwork Standards" for grades of wood trim indicated for construction, finishes, installation, and other requirements.

2.3 INTERIOR STANDING AND RUNNING TRIM , CASINGS AND FRAMES FOR OPAQUE FINISH

- A. Grade: Premium.
- B. Wood Species: Poplar.

2.4 CLOSET AND UTILITY SHELVING

- A. Shelving: Made from the following material:
 - 1. Wire ventilated epoxy coated metal shelving system, manufactured by Rubbermaid or an approved equal.
- B. Shelf Brackets and mounting hardware: manufacturer's standard metal in matching finish and color.
- C. Clothes Rods: metal, 1-1/2-inch- diameter. Match finish and color of shelving.

2.5 WOOD MATERIALS

- A. Wood Products: Provide materials that comply with requirements of referenced quality standard for each type of wood trim and quality grade specified unless otherwise indicated.
 - 1. Wood Moisture Content for Interior Materials: 5 to 10 percent.

2.6 MISCELLANEOUS MATERIALS

- A. Interior Furring, Blocking, Shims, and Hanging Strips: Softwood or hardwood lumber, kiln dried to less than 15 percent moisture content.
- B. Provide self-drilling screws for metal-framing supports.
- C. Anchors: Select material, type, size, and finish required for each substrate for secure anchorage. Provide metal expansion sleeves or expansion bolts for post-installed anchors. Use nonferrous-metal or hot-dip galvanized anchors and inserts at inside face of exterior walls and at floors.
- D. Adhesives: Do not use adhesives that contain urea formaldehyde.

- E. VOC Limits for Installation Adhesives and Sealants: Use products that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
 - 1. Wood Glues: 30 g/L.
 - 2. Multipurpose Construction Adhesives: 70 g/L.
 - 3. Structural Wood Member Adhesive: 140 g/L.
 - 4. Architectural Sealants: 250 g/L.

2.7 FABRICATION

- A. Fabricate wood trim and frames to dimensions, profiles, and details indicated. Ease edges to radius indicated for the following:
 - 1. Edges of Solid-Wood (Lumber) Members: 1/16 inch unless otherwise indicated.
 - 2. Edges of Rails and Similar Members More Than 3/4 Inch Thick: 1/8 inch.
- B. Backout or groove backs of flat trim members and kerf backs of other wide, flat members except for members with ends exposed in finished work.

2.8 SHOP PRIMING

- A. Interior Wood Trim and frames for Opaque Finish: Shop prime with one coat of wood primer specified in Section 099123 "Interior Painting."
- B. Preparations for Finishing: Comply with referenced quality standard for sanding, filling countersunk fasteners, sealing concealed surfaces, and similar preparations for finishing wood trim, as applicable to each unit of work.
 - 1. Backpriming: Apply one coat of sealer or primer, compatible with finish coats, to concealed surfaces of wood trim. Apply two coats to surfaces installed in contact with concrete or masonry and to end-grain surfaces.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before installation, condition wood trim to average prevailing humidity conditions in installation areas.

3.2 INSTALLATION

- A. Grade: Install wood trim and frames to comply with same grade as item to be installed.

- B. Install wood trim and frames level, plumb, true, and straight. Shim as required with concealed shims. Install level and plumb to a tolerance of 1/8 inch in 96 inches .
- C. Scribe and cut wood trim and frames to fit adjoining work, refinish cut surfaces, and repair damaged finish at cuts.
- D. Anchor wood trim to anchors or blocking built in or directly attached to substrates. Secure with countersunk, concealed fasteners and blind nailing. Use fine finishing nails or finishing screws for exposed fastening, countersunk and filled flush with woodwork.
- E. Standing and Running Trim: Install with minimum number of joints possible, using full-length pieces (from maximum length of lumber available) to greatest extent possible. Do not use pieces less than 36 inches long except where shorter single-length pieces are necessary. Scarf running joints and stagger in adjacent and related members.
 - 1. Install wall railings on indicated metal brackets securely fastened to wall framing.
 - 2. Install standing and running trim with no more variation from a straight line than 1/8 inch in 96 inches.

END OF SECTION 064600

SUMMARY SECTION 072100 - THERMAL INSULATION

PART 1 - GENERAL

1.1

- A. Section Includes:
 - 1. Extruded polystyrene foam-plastic board.
 - 2. Glass-fiber blanket.
 - 3. Mineral wool blanket.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Low-emitting product certification.

1.3 INFORMATIONAL SUBMITTALS

- A. Product test reports.
- B. Research reports.

PART 2 - PRODUCTS

2.1 EXTRUDED POLYSTYRENE FOAM-PLASTIC BOARD

- A. Extruded polystyrene boards in this article are also called "XPS boards."
- B. Extruded Polystyrene Board : ASTM C 578, 25-psi minimum compressive strength; unfaced; maximum flame-spread and smoke-developed indexes of 25 and 450, respectively, per ASTM E 84.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Dow Chemical Company (The).
 - b. Owens Corning.
 - c. An approved equal.
 - 2. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.

- a. R- Value per inch: 5
- b. Thickness: As indicated.

2.2 GLASS-FIBER BLANKET

- A. Sustainability Requirements: Provide glass-fiber blanket insulation as follows:
 1. Free of Formaldehyde: Insulation manufactured with 100 percent acrylic binders and no formaldehyde.
 2. Low Emitting: Insulation tested according to ASTM D 5116 and shown to emit less than 0.05-ppm formaldehyde.
- B. Glass-Fiber Blanket, Kraft Faced: ASTM C 665, Type II (nonreflective faced), Class C (faced surface not rated for flame propagation); Category 1 (membrane is a vapor barrier).
- C. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 1. Knauf Insulation.
 2. Owens Corning.
 3. An approved equal.
- D. Thickness and R Value: As indicated on the drawings.

2.3 MINERAL-WOOL BLANKETS

- A. Mineral-Wool Blanket, Unfaced : ASTM C 665, Type I (blankets without membrane facing); consisting of fibers; with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively, per ASTM E 84; passing ASTM E 136 for combustion characteristics.
 1. Manufacturer: Roxul or an approved equal

2.4 ACCESSORIES

- A. Insulation for Miscellaneous Voids:
 1. Glass-Fiber Insulation: ASTM C 764, Type II, loose fill; with maximum flame-spread and smoke-developed indexes of 5, per ASTM E 84.
 2. Spray Polyurethane Foam Insulation: ASTM C 1029, Type II, closed cell, with maximum flame-spread and smoke-developed indexes of 75 and 450, respectively, per ASTM E 84.
- B. Insulation Anchors, Spindles, and Standoffs: As recommended by manufacturer.
- C. Adhesive for Bonding Insulation: Product compatible with insulation and air and water barrier materials, and with demonstrated capability to bond insulation securely to substrates without damaging insulation and substrates.

- D. Eave Ventilation Troughs: Preformed, rigid fiberboard or plastic sheets designed and sized to fit between roof framing members and to provide ventilation between insulated attic spaces and vented eaves.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Comply with insulation manufacturer's written instructions applicable to products and applications.
- B. Install insulation that is undamaged, dry, and unsoiled and that has not been left exposed to ice, rain, or snow at any time.
- C. Extend insulation to envelop entire area to be insulated. Fit tightly around obstructions and fill voids with insulation. Remove projections that interfere with placement.
- D. Provide sizes to fit applications and selected from manufacturer's standard thicknesses, widths, and lengths. Apply single layer of insulation units unless multiple layers are otherwise shown or required to make up total thickness or to achieve R-value.

3.2 INSTALLATION OF SLAB INSULATION

- A. On vertical slab edge and foundation surfaces, set insulation units using manufacturer's recommended adhesive according to manufacturer's written instructions.
 - 1. If not otherwise indicated, extend insulation a minimum of 24 inches below exterior grade line.
- B. On horizontal surfaces, loosely lay insulation units according to manufacturer's written instructions. Stagger end joints and tightly abut insulation units.
 - 1. If not otherwise indicated, extend insulation a minimum of 24 inches in from exterior walls.

3.3 INSTALLATION OF INSULATION IN FRAMED CONSTRUCTION

- A. Blanket Insulation: Install in cavities formed by framing members according to the following requirements:
 - 1. Use insulation widths and lengths that fill the cavities formed by framing members. If more than one length is required to fill the cavities, provide lengths that will produce a snug fit between ends.

2. Place insulation in cavities formed by framing members to produce a friction fit between edges of insulation and adjoining framing members.
 3. Maintain 3-inch clearance of insulation around recessed lighting fixtures not rated for or protected from contact with insulation.
 4. For wood-framed construction, install blankets according to ASTM C 1320 and as follows:
 - a. With faced blankets having stapling flanges, lap blanket flange over flange of adjacent blanket to maintain continuity of vapor retarder once finish material is installed over it.
 5. Vapor-Retarder-Faced Blankets: Tape joints and ruptures in vapor-retarder facings, and seal each continuous area of insulation to ensure airtight installation.
 - a. Exterior Walls: Set units with facing placed toward interior of construction.
 6. Attics: Install eave ventilation troughs between roof framing members in insulated attic spaces at vented eaves.
- B. Miscellaneous Voids: Install insulation in miscellaneous voids and cavity spaces where required to prevent gaps in insulation using the following materials:
1. Glass-Fiber Insulation: Compact to approximately 40 percent of normal maximum volume equaling a density of approximately 2.5 lb/cu. ft..
 2. Spray Polyurethane Insulation: Apply according to manufacturer's written instructions.

END OF SECTION 072100

SECTION 072500 - WEATHER BARRIERS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Building wrap.
 - 2. Flexible flashing.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.3 INFORMATIONAL SUBMITTALS

- A. Evaluation Reports: For water-resistive barrier and flexible flashing, from ICC-ES.

PART 2 - PRODUCTS

2.1 WATER-RESISTIVE BARRIER

- A. Building Wrap: ASTM E 1677, Type I air barrier; with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, when tested according to ASTM E 84; UV stabilized; and acceptable to authorities having jurisdiction.
 - 1. Manufacturer: Subject to compliance with requirements, provide products by one of the following:
 - a. Tyvek, by the Dow Chemical Co.
 - b. An approved equal.
 - 2. Water-Vapor Permeance: Not less than 50 g through 1 sq. m of surface in 24 hours per ASTM E 96/E 96M, Desiccant Method (Procedure A).
 - 3. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.
- B. Building-Wrap Tape: Pressure-sensitive plastic tape recommended by building-wrap manufacturer for sealing joints and penetrations in building wrap.

2.2 MISCELLANEOUS MATERIALS

- A. Butyl Rubber, Flexible Flashing: Self-adhesive rubberized-asphalt compound, bonded to a high-density polyethylene film, aluminum foil, or spunbonded polyolefin to produce an overall thickness of not less than 0.025 inch.

PART 3 - EXECUTION

3.1 WATER-RESISTIVE BARRIER INSTALLATION

- A. Cover sheathing with water-resistive barrier as follows:
 - 1. Cut back barrier 1/2 inch on each side of the break in supporting members at expansion-or control-joint locations.
 - 2. Apply barrier to cover vertical flashing with a minimum 4-inch overlap unless otherwise indicated.
- B. Building Wrap: Comply with manufacturer's written instructions.
 - 1. Seal seams, edges, fasteners, and penetrations with tape.
 - 2. Extend into jambs of openings and seal corners with tape.

3.2 FLEXIBLE FLASHING INSTALLATION

- A. Apply flexible flashing where indicated to comply with manufacturer's written instructions.
 - 1. Lap seams and junctures with other materials at least 4 inches except that at flashing flanges of other construction, laps need not exceed flange width.
 - 2. Lap flashing over water-resistive barrier at bottom and sides of openings.
 - 3. Lap water-resistive barrier over flashing at heads of openings.

END OF SECTION 072500

SECTION 073113 - ASPHALT SHINGLES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Asphalt shingles.
 - 2. Underlayment.
 - 3. Ridge vents.
 - 4. Metal flashing and trim.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Samples: For each exposed product and for each color and texture specified.

1.3 INFORMATIONAL SUBMITTALS

- A. Product test reports.
- B. Evaluation reports.
- C. Sample warranty.

1.4 CLOSEOUT SUBMITTALS

- A. Maintenance data.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: An authorized representative who is trained and approved by manufacturer.

1.6 WARRANTY

- A. Manufacturer's Warranty: Manufacturer agrees to repair or replace asphalt shingles that fail within specified warranty period.

1. Material Warranty Period: Limited Lifetime, from date of Substantial Completion, prorated, with first 10 years non-prorated.
2. Wind-Speed Warranty Period: Asphalt shingles will resist blow-off or damage caused by wind speeds of up to 130 mph for 15 years from date of Substantial Completion.
3. Algae-Resistance Warranty Period: Asphalt shingles will not discolor for 15 years from date of Substantial Completion.
4. Workmanship Warranty Period: One year from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Exterior Fire-Test Exposure: Provide asphalt shingles and related roofing materials identical to those of assemblies tested for Class A fire resistance according to ASTM E 108 or UL 790 by Underwriters Laboratories, Inc. or another testing and inspecting agency acceptable to authorities having jurisdiction. Identify products with appropriate markings of applicable testing agency.

2.2 GLASS-FIBER-REINFORCED ASPHALT SHINGLES

- A. Laminated-Strip Asphalt Shingles: ASTM D 3462, laminated, multi-ply overlay construction, glass-fiber reinforced, mineral-granule surfaced, and self-sealing.
 1. Manufacturer: Basis of Design, Subject to compliance with requirements, provide the following: CertainTeed, Landmark Premium
 2. Butt Edge: Straight cut.
 1. Strip Size: Manufacturer's standard.
 2. Algae Resistance: Granules resist algae discoloration.
 3. Impact Resistance: UL 2218, Class 4.
 4. Color and Blends: As selected by Architect from manufacturer's full range.
- B. Hip and Ridge Shingles: Manufacturer's standard units to match asphalt shingles.

2.3 UNDERLAYMENT MATERIALS

- A. Felt: ASTM D 226, asphalt-saturated organic felts, nonperforated.
 1. Type: Type I
- B. Self-Adhering Sheet Underlayment, Granular Surfaced: ASTM D 1970, minimum of 55-mil-thick sheet; glass-fiber-mat-reinforced, SBS-modified asphalt; mineral-granule surfaced; with release backing; cold applied, by same manufacturer as shingles.
- C. Self-Adhering Sheet Underlayment, Polyethylene Faced: ASTM D 1970, minimum of 40-mil-thick, slip-resisting, polyethylene-film-reinforced top surface laminated to SBS-modified asphalt adhesive, with release backing; cold applied, by same manufacturer as shingles.

2.4 RIDGE VENTS

- A. Rigid Ridge Vent: Manufacturer's standard, rigid section high-density polypropylene or other UV-stabilized plastic ridge vent for use under ridge shingles.
 - 1. Minimum Net Free Area: 12 square inches per foot.
 - 2. Features:
 - a. Nonwoven geotextile filter strips.
 - b. External deflector baffles.

2.5 ACCESSORIES

- A. Asphalt Roofing Cement: ASTM D 4586, Type II, asbestos free.
- B. Roofing Nails: ASTM F 1667; aluminum, stainless-steel, copper, or hot-dip galvanized-steel wire shingle nails, minimum 0.120-inch diameter, sharp-pointed, with a minimum 3/8-inch-diameter flat head and of sufficient length to penetrate 3/4 inch into solid wood decking or extend at least 1/8 inch through plywood sheathing.
 - 1. Shank: Barbed.
 - 2. Where nails are in contact with metal flashing, use nails made from same metal as flashing.
- C. Felt-Underlayment Nails: Aluminum, stainless-steel, or hot-dip galvanized-steel wire with low-profile capped heads or disc caps, 1-inch minimum diameter.
- D. Synthetic-Underlayment Fasteners: As recommended in writing by synthetic-underlayment manufacturer for application indicated.

2.6 METAL FLASHING AND TRIM

- A. General: Comply with requirements in Section 076200 "Sheet Metal Flashing and Trim."
 - 1. Sheet Metal: Aluminum, painted.
- B. Fabricate sheet metal flashing and trim to comply with recommendations in SMACNA's "Architectural Sheet Metal Manual" that apply to design, dimensions, metal, and other characteristics of the item.

PART 3 - EXECUTION

3.1 UNDERLAYMENT INSTALLATION

- A. General: Comply with underlayment manufacturer's written installation instructions applicable to products and applications indicated unless more stringent requirements apply.

- B. Single-Layer Felt Underlayment: Install on roof deck parallel with and starting at the eaves. Lap sides a minimum of 2 inches over underlying course. Lap ends a minimum of 4 inches. Stagger end laps between succeeding courses at least 72 inches. Fasten with felt-underlayment nails.
1. Install felt underlayment on roof deck not covered by self-adhering sheet underlayment. Lap sides of felt over self-adhering sheet underlayment not less than 3 inches in direction that sheds water. Lap ends of felt not less than 6 inches over self-adhering sheet underlayment.
 2. Install fasteners at no more than 36 inches o.c.
- C. Double-Layer Felt Underlayment: Install on roof deck parallel with and starting at the eaves. Install a 19-inch- wide starter course at eaves and completely cover with full-width second course. Install succeeding courses lapping previous courses 19 inches in shingle fashion. Lap ends a minimum of 6 inches. Stagger end laps between succeeding courses at least 72 inches. Fasten with felt-underlayment nails.
1. Apply a continuous layer of asphalt roofing cement over starter course and on felt-underlayment surface to be concealed by succeeding courses as each felt course is installed. Apply at locations indicated on Drawings.
 2. Install felt underlayment on roof sheathing not covered by self-adhering sheet underlayment. Lap edges over self-adhering sheet underlayment not less than 3 inches in direction that sheds water.
 3. Terminate felt underlayment extended up not less than 4 inches against sidewalls, curbs, chimneys, and other roof projections.
 4. Install fasteners at no more than 36 inch o.c.
- D. Self-Adhering Sheet Underlayment: Install, wrinkle free, on roof deck. Comply with low-temperature installation restrictions of underlayment manufacturer if applicable. Install lapped in direction that sheds water. Lap sides not less than 3-1/2 inches. Lap ends not less than 6 inches staggered 24 inches between courses. Roll laps with roller. Cover underlayment within seven days.
1. Prime concrete and masonry surfaces to receive self-adhering sheet underlayment.

3.2 METAL FLASHING INSTALLATION

- A. General: Install metal flashings and other sheet metal to comply with requirements in Section 076200 "Sheet Metal Flashing and Trim."
1. Install metal flashings according to recommendations in ARMA's "Residential Asphalt Roofing Manual" and NRCA's "NRCA Guidelines for Asphalt Shingle Roof Systems."

3.3 ASPHALT-SHINGLE INSTALLATION

- A. General: Install asphalt shingles according to manufacturer's written instructions, recommendations in ARMA's "Residential Asphalt Roofing Manual," and recommendations in NRCA's "NRCA Guidelines for Asphalt Shingle Roof Systems."

- B. Install starter strip along lowest roof edge, consisting of an asphalt-shingle strip with tabs removed with self-sealing strip face up at roof edge.
 - 1. Extend asphalt shingles 3/4 inch over fasciae at eaves and rakes.
 - 2. Install starter strip along rake edge.
- C. Install first and remaining courses of asphalt shingles stair-stepping diagonally across roof deck with manufacturer's recommended offset pattern at succeeding courses, maintaining uniform exposure.
- D. Install first and remaining courses of asphalt shingles stair-stepping diagonally across roof deck with manufacturer's recommended offset pattern at succeeding courses, maintaining uniform exposure.
- E. Install asphalt shingles by single-strip column or racking method, maintaining uniform exposure. Install full-length first course followed by cut second course, repeating alternating pattern in succeeding courses.
- F. Fasten asphalt-shingle strips with a minimum of four roofing nails located according to manufacturer's written instructions.
 - 1. Where roof slope exceeds 21:12, seal asphalt shingles with asphalt roofing cement spots after fastening with additional roofing nails.
 - 2. Where roof slope is less than 4:12, seal asphalt shingles with asphalt roofing cement spots.
 - 3. When ambient temperature during installation is below 50 deg F , seal asphalt shingles with asphalt roofing cement spots.
- G. Open Valleys: Cut and fit asphalt shingles at open valleys, trimming upper concealed corners of shingle strips. Maintain uniform width of exposed open valley from highest to lowest point.
 - 1. Set valley edge of asphalt shingles in a 3-inch- wide bed of asphalt roofing cement.
 - 2. Do not nail asphalt shingles to metal open-valley flashings.
- H. Ridge Vents: Install continuous ridge vents over asphalt shingles according to manufacturer's written instructions. Fasten with roofing nails of sufficient length to penetrate sheathing.
- I. Hip and Ridge Shingles: Maintain same exposure of cap shingles as roofing shingle exposure. Lap cap shingles at ridges to shed water away from direction of prevailing winds. Fasten with roofing nails of sufficient length to penetrate sheathing.
 - 1. Fasten ridge cap asphalt shingles to cover ridge vent without obstructing airflow.

END OF SECTION 073113

SECTION 074633 - VINYL SIDING AND SOFFITS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes vinyl siding and soffits.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. For vinyl siding, include VSI's official certification logo printed on Product Data.
- B. Samples: For vinyl siding and soffit including related accessories.

1.3 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For vinyl siding Installer.
- B. Product certificates.
- C. Research/evaluation reports.
- D. Sample warranty.

1.4 CLOSEOUT SUBMITTALS

- A. Maintenance data.

1.5 QUALITY ASSURANCE

- A. Vinyl Siding Installer Qualifications: A qualified installer who employs a VSI-certified Installer on Project.
- B. Mockups: Build mockups to verify selections made under Sample submittals and to demonstrate aesthetic effects and to set quality standards for fabrication and installation.
 - 1. Build mockup of typical wall area as shown on Drawings.
 - 2. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.6 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace products that fail in materials or workmanship within specified warranty period.
 - 1. Warranty Period: Limited Lifetime, from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 VINYL SIDING

- A. General: Integrally colored vinyl siding complying with ASTM D 3679.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Alcoa Home Exteriors, Inc.
 - b. CertainTeed Corp. (Monogram 4L)
 - c. An Approved Equal.
- B. Vinyl Siding Certification Program: Provide products that are listed in VSI's list of certified products.
- C. Horizontal Pattern: 4 inch exposure in beaded-edge, double board style.
- D. Texture: Wood grain.
- E. Nominal Thickness: 0.040 inch.
- F. Minimum Profile Depth (Butt Thickness): 1/2 inch.
- G. Nailing Hem: Double thickness.
- H. Finish: Wood-grain print with clear protective coating containing not less than 70 percent PVDF.
 - 1. Colors: As selected by Architect from manufacturer's full range of colors..

2.2 VINYL SOFFIT

- A. Vinyl Soffit: Integrally colored product complying with ASTM D 4477.
 - 1. Manufacturer: Same Manufacturer and Warranty as vinyl siding.
 - 2. Type: CertainTeed Universal "Triple 4" vented soffit or an approved equal.
- B. Vinyl Siding Certification Program: Provide products that are listed in VSI's list of certified products.

- C. Pattern: 4 inch exposure in V-grooved, triple board style.
- D. Texture: Smooth, Matte.
- E. Ventilation: Provide perforated soffit unless otherwise indicated.
- F. Nominal Thickness: 0.040 inch.
- G. Minimum Profile Depth: 1/2 inch .
- H. Colors: As selected by Architect from manufacturer's full range of colors.

2.3 ACCESSORIES

- A. Siding Accessories, General: Provide starter strips, edge trim, outside and inside corner caps, and other items as recommended by siding manufacturer for building configuration.
 - 1. Provide accessories made from same material as and matching color and texture of adjacent siding unless otherwise indicated.
- B. Vinyl Accessories: Integrally colored vinyl accessories complying with ASTM D 3679 except for wind-load resistance.
 - 1. Texture: Wood grain.
- C. Colors for Decorative Accessories: As selected by Architect from manufacturer's full range of colors.
- D. Flashing: Provide aluminum flashing complying with Section 076200 "Sheet Metal Flashing and Trim" at window and door heads and where indicated.
 - 1. Finish for Aluminum Flashing: High-performance organic finish, same color as siding.
- E. Fasteners:
 - 1. For fastening to wood, use siding nails of sufficient length to penetrate a minimum of 1 inch into wood substrate.
 - 2. For fastening vinyl, use aluminum fasteners. Where fasteners are exposed to view, use prefinished aluminum fasteners in color to match item being fastened.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General: Comply with manufacturer's written installation instructions applicable to products and applications indicated unless more stringent requirements apply.

1. Center nails in elongated nailing slots without binding siding to allow for thermal movement.
- B. Install vinyl siding and soffit and related accessories according to ASTM D 4756.
 1. Install fasteners for horizontal vinyl siding no more than 16 inches o.c.
- C. Install joint sealants as specified in Section 079200 "Joint Sealants" and to produce a weathertight installation.

3.2 ADJUSTING AND CLEANING

- A. Remove damaged, improperly installed, or otherwise defective materials and replace with new materials complying with specified requirements.
- B. Clean finished surfaces according to manufacturer's written instructions and maintain in a clean condition during construction.

END OF SECTION 074633

SECTION 077100 - ROOF SPECIALTIES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Roof-edge specialties.
2. Roof-edge drainage systems.
3. Reglets and counterflashings.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of product.

B. Shop Drawings: For roof specialties.

1. Include plans, elevations, expansion-joint locations, keyed details, and attachments to other work. Distinguish between plant- and field-assembled work.

C. Samples: For each type of roof specialty and for each color and texture specified.

1.3 INFORMATIONAL SUBMITTALS

A. Product Test Reports: For tests performed by a qualified testing agency.

B. Sample warranty.

1.4 CLOSEOUT SUBMITTALS

A. Maintenance Data: For roofing specialties to include in maintenance manuals.

1.5 QUALITY ASSURANCE

A. Manufacturer Qualifications: A qualified manufacturer offering products meeting requirements that are FM Approvals listed for specified class.

- B. WARRANTY
- C. Roofing-System Warranty: Roof specialties are included in warranty provisions in Section 073113 "Asphalt Shingles".
- D. Special Warranty on Painted Finishes: Manufacturer agrees to repair finish or replace roof specialties that show evidence of deterioration of factory-applied finishes within specified warranty period.
 - 1. Fluoropolymer Finish: Deterioration includes, but is not limited to, the following:
 - a. Color fading more than 5 Hunter units when tested according to ASTM D 2244.
 - b. Chalking in excess of a No. 8 rating when tested according to ASTM D 4214.
 - c. Cracking, checking, peeling, or failure of paint to adhere to bare metal.
 - 2. Finish Warranty Period: 20 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. FM Approvals' Listing: Manufacture and install roof-edge specialties that are listed in FM Approvals' "RoofNav" and approved for windstorm classification Class 1-90. Identify materials with FM Approvals' markings.
- B. SPRI Wind Design Standard: Manufacture and install roof-edge specialties tested according to SPRI ES-1 and capable of resisting the following design pressures:
 - 1. Design Pressure: 130MPH wind speed..
- C. Thermal Movements: Allow for thermal movements from ambient and surface temperature changes to prevent buckling, opening of joints, hole elongation, overstressing of components, failure of joint sealants, failure of connections, and other detrimental effects. Provide clips that resist rotation and avoid shear stress as a result of thermal movements. Base calculations on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
 - 1. Temperature Change (Range): 120 deg F , ambient;, material surfaces.

2.2 ROOF-EDGE DRAINAGE SYSTEMS

- A. Gutters: Manufactured in uniform section lengths not exceeding 12 feet , with matching corner units, ends, outlet tubes, and other accessories. Elevate back edge at least 1 inch above front edge. Furnish flat-stock gutter straps, gutter brackets, expansion joints, and expansion-joint covers fabricated from same metal as gutters.

1. Aluminum Sheet: 0.032 inch thick.
2. Gutter Profile: As indicated according to SMACNA's "Architectural Sheet Metal Manual."
3. Corners: Factory mitered and mechanically clinched and sealed watertight].
4. Gutter Supports: Gutter brackets with finish matching the gutters.
5. Gutter Accessories: Continuous hinged leaf guard of solid metal designed to shed leaves; Aluminum wire ball downspout strainer; Flat ends.

B. Downspouts: Corrugated rectangular complete with smooth-curve elbows, manufactured from the following exposed metal. Furnish with metal hangers, from same material as downspouts, and anchors.

1. Formed Aluminum: 0.032 inch thick.

2.3 REGLETS AND COUNTERFLASHINGS

A. Reglets: Manufactured units formed to provide secure interlocking of separate reglet and counterflashing pieces, from the following exposed metal:

1. Stainless Steel: 0.019 inch thick.
2. Stucco Type, Embedded: Provide reglets with upturned fastening flange and extension leg of length to match thickness of applied finish materials.
3. Concrete Type, Embedded: Provide temporary closure tape to keep reglet free of concrete materials, special fasteners for attaching reglet to concrete forms, and guides to ensure alignment of reglet section ends.

2.4 MATERIALS

A. Aluminum Sheet: ASTM B 209, alloy as standard with manufacturer for finish required, with temper to suit forming operations and performance required.

B. Stainless-Steel Sheet: ASTM A 240 or ASTM A 666, Type 304.

2.5 MISCELLANEOUS MATERIALS

A. Fasteners: Manufacturer's recommended fasteners, suitable for application and designed to meet performance requirements. Furnish the following unless otherwise indicated:

1. Exposed Penetrating Fasteners: Gasketed screws with hex washer heads matching color of sheet metal.
2. Fasteners for Aluminum: Aluminum: Series 300 stainless steel.
3. Fasteners for Stainless-Steel Sheet: Series 300 stainless steel.

B. Elastomeric Sealant: ASTM C 920, elastomeric silicone polymer sealant of type, grade, class, and use classifications required by roofing-specialty manufacturer for each application.

- C. Butyl Sealant: ASTM C 1311, single-component, solvent-release butyl rubber sealant; polyisobutylene plasticized; heavy bodied for hooked-type joints with limited movement.
- D. Bituminous Coating: Cold-applied asphalt emulsion complying with ASTM D 118.
- E. Asphalt Roofing Cement: ASTM D 4586, asbestos free, of consistency required for application.

2.6 FINISHES

- A. Coil-Coated Aluminum Sheet Finishes:
 - 1. High-Performance Organic Finish: Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
 - a. Three-Coat Fluoropolymer: AAMA 2605. Fluoropolymer finish containing not less than 70 percent PVDF resin by weight in both color coat and clear topcoat.
 - 2. Color: As selected by Architect.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. General: Install roof specialties according to manufacturer's written instructions. Anchor roof specialties securely in place, with provisions for thermal and structural movement. Use fasteners, solder, protective coatings, separators, underlayments, sealants, and other miscellaneous items as required to complete roof-specialty systems.
 - 1. Install roof specialties level, plumb, true to line and elevation; with limited oil-canning and without warping, jogs in alignment, buckling, or tool marks.
 - 2. Provide uniform, neat seams with minimum exposure of solder and sealant.
 - 3. Install roof specialties to fit substrates and to result in weathertight performance. Verify shapes and dimensions of surfaces to be covered before manufacture.
 - 4. Torch cutting of roof specialties is not permitted.
 - 5. Do not use graphite pencils to mark metal surfaces.
- B. Metal Protection: Protect metals against galvanic action by separating dissimilar metals from contact with each other or with corrosive substrates by painting contact surfaces with bituminous coating or by other permanent separation as recommended by manufacturer.
 - 1. Coat concealed side of uncoated aluminum and stainless-steel roof specialties with bituminous coating where in contact with wood, ferrous metal, or cementitious construction.
 - 2. Bed flanges in thick coat of asphalt roofing cement where required by manufacturers of roof specialties for waterproof performance.
- C. Expansion Provisions: Allow for thermal expansion of exposed roof specialties.

1. Space movement joints at a maximum of 12 feet with no joints within 18 inches of corners or intersections unless otherwise indicated on Drawings.
 2. When ambient temperature at time of installation is between 40 and 70 deg F., set joint members for 50 percent movement each way. Adjust setting proportionately for installation at higher ambient temperatures.
- D. Fastener Sizes: Use fasteners of sizes that penetrate wood blocking or sheathing not less than 1-1/4 inches for nails and not less than 3/4 inch for wood screws, substrate not less than recommended by fastener manufacturer to achieve maximum pull-out resistance.
- E. Seal concealed joints with butyl sealant as required by roofing-specialty manufacturer.
- F. Seal joints as required for weathertight construction. Place sealant to be completely concealed in joint. Do not install sealants at temperatures below 40 deg F .

3.2 ROOF-EDGE DRAINAGE-SYSTEM INSTALLATION

- A. General: Install components to produce a complete roof-edge drainage system according to manufacturer's written instructions. Coordinate installation of roof perimeter flashing with installation of roof-edge drainage system.
- B. Gutters: Join and seal gutter lengths. Allow for thermal expansion. Attach gutters to firmly anchored gutter supports spaced not more than 24 inches apart. Attach ends with rivets and seal with sealant to make watertight. Slope to downspouts.
1. Install gutter with expansion joints at locations indicated but not exceeding 50 feet apart. Install expansion-joint caps.
 2. Install continuous leaf guards on gutters with noncorrosive fasteners, hinged to swing open for cleaning gutters.
- C. Downspouts: Join sections with manufacturer's standard telescoping joints. Provide hangers with fasteners designed to hold downspouts securely to walls and 1 inch away from walls; locate fasteners at top and bottom and at approximately 60 inches o.c.
1. Provide elbows at base of downspouts at grade to direct water away from building.
 2. Connect downspouts to underground drainage system indicated.

3.3 REGLET AND COUNTERFLASHING INSTALLATION

- A. Embedded Reglets: See Section 033000 "Cast-in-Place Concrete" for installation of reglets.
- B. Surface-Mounted Reglets: Install reglets to receive flashings where flashing without embedded reglets is indicated on Drawings.

3.4 CLEANING AND PROTECTION

- A. Clean exposed metal surfaces of substances that interfere with uniform oxidation and weathering.
- B. Clean and neutralize flux materials. Clean off excess solder and sealants.
- C. Remove temporary protective coverings and strippable films as roof specialties are installed.

END OF SECTION 077100

SECTION 079200 - JOINT SEALANTS

PART 1 -

PART 2 - GENERAL

2.1 SUMMARY

- A. Section Includes:
 - 1. Silicone joint sealants.
 - 2. Urethane joint sealants.
 - 3. Latex joint sealants.

2.2 SUBMITTALS

- A. Product Data: For each joint-sealant product indicated.
- B. Samples: For each kind and color of joint sealant required.
- C. Joint-Sealant Schedule: Include the following information:
 - 1. Joint-sealant application, joint location, and designation.
 - 2. Joint-sealant manufacturer and product name.
 - 3. Joint-sealant formulation.
 - 4. Joint-sealant color.
- D. Product test reports.
- E. Warranties.

2.3 WARRANTY

- A. Special Installer's Warranty: Manufacturer's standard form in which Installer agrees to repair or replace joint sealants that do not comply with performance and other requirements specified in this Section within specified warranty period.
 - 1. Warranty Period: One year from date of Substantial Completion.

- B. Special Manufacturer's Warranty: Manufacturer's standard form in which joint-sealant manufacturer agrees to furnish joint sealants to repair or replace those that do not comply with performance and other requirements specified in this Section within specified warranty period.
 - 1. Warranty Period: Five (5) years from date of Substantial Completion.

PART 3 - PRODUCTS

3.1 MATERIALS, GENERAL

- A. VOC Content of Interior Sealants: Provide sealants and sealant primers for use inside the weatherproofing system that comply with the following limits for VOC content when calculated according to 40 CFR 59, Part 59, Subpart D (EPA Method 24):
 - 1. Architectural Sealants: 250 g/L.
 - 2. Sealant Primers for Nonporous Substrates: 250 g/L.
 - 3. Sealant Primers for Porous Substrates: 775 g/L.
- B. Liquid-Applied Joint Sealants: Comply with ASTM C 920 and other requirements indicated for each liquid-applied joint sealant specified, including those referencing ASTM C 920 classifications for type, grade, class, and uses related to exposure and joint substrates.
 - 1. Suitability for Immersion in Liquids. Where sealants are indicated for Use I for joints that will be continuously immersed in liquids, provide products that have undergone testing according to ASTM C 1247. Liquid used for testing sealants is deionized water, unless otherwise indicated.
- C. Stain-Test-Response Characteristics: Where sealants are specified to be nonstaining to porous substrates, provide products that have undergone testing according to ASTM C 1248 and have not stained porous joint substrates indicated for Project.

3.2 SILICONE JOINT SEALANTS

- A. Mildew-Resistant Silicone Joint Sealant (SS) ASTM C 920.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Dow Corning Corporation.
 - b. GE Advanced Materials - Silicones.
 - c. Pecora Corporation.
 - d. An approved equal.
 - 2. Type: Single component (S).
 - 3. Grade: Nonsag (NS).
 - 4. Class: 50.

5. Uses Related to Exposure: Nontraffic (NT).

3.3 URETHANE JOINT SEALANTS

A. Urethane Joint Sealant (US) ASTM C 920.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Pecora Corporation.
 - b. Sika Corporation; Construction Products Division.
 - c. Or an approved equal.
2. Type: Single component (S).
3. Grade: Nonsag (NS).
4. Class: 50.
5. Uses Related to Exposure: Traffic (T) and Nontraffic (NT).

3.4 LATEX JOINT SEALANTS

A. Latex Joint Sealant (LS): Acrylic latex or siliconized acrylic latex, ASTM C 834, Type OP, Grade NF.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Pecora Corporation.
 - b. Tremco Incorporated.
 - c. An approved equal.

3.5 JOINT SEALANT BACKING

- A. Cylindrical Sealant Backings: ASTM C 1330, Type C (closed-cell material with a surface skin), and of size and density to control sealant depth and otherwise contribute to producing optimum sealant performance.
- B. Bond-Breaker Tape: Polyethylene tape or other plastic tape recommended by sealant manufacturer.

3.6 MISCELLANEOUS MATERIALS

- A. Primer: Material recommended by joint-sealant manufacturer where required for adhesion of sealant to joint substrates indicated, as determined from preconstruction joint-sealant-substrate tests and field tests.

- B. Cleaners for Nonporous Surfaces: Chemical cleaners acceptable to manufacturers of sealants and sealant backing materials.
- C. Masking Tape: Nonstaining, nonabsorbent material compatible with joint sealants and surfaces adjacent to joints.

PART 4 - EXECUTION

4.1 PREPARATION

- A. Surface Cleaning of Joints: Clean out joints immediately before installing joint sealants to comply with joint-sealant manufacturer's written instructions.
 - 1. Remove laitance and form-release agents from concrete.
 - 2. Clean nonporous joint substrate surfaces with chemical cleaners or other means that do not stain, harm substrates, or leave residues capable of interfering with adhesion of joint sealants.
- B. Joint Priming: Prime joint substrates where recommended by joint-sealant manufacturer or as indicated by preconstruction joint-sealant-substrate tests or prior experience. Apply primer to comply with joint-sealant manufacturer's written instructions. Confine primers to areas of joint-sealant bond; do not allow spillage or migration onto adjoining surfaces.
- C. Masking Tape: Use masking tape where required to prevent contact of sealant or primer with adjoining surfaces that otherwise would be permanently stained or damaged by such contact or by cleaning methods required to remove sealant smears. Remove tape immediately after tooling without disturbing joint seal.

4.2 INSTALLATION

- A. Sealant Installation Standard: Comply with recommendations in ASTM C 1193 for use of joint sealants as applicable to materials, applications, and conditions indicated.
- B. Install sealant backings of kind indicated to support sealants during application and at position required to produce cross-sectional shapes and depths of installed sealants relative to joint widths that allow optimum sealant movement capability.
 - 1. Do not leave gaps between ends of sealant backings.
 - 2. Do not stretch, twist, puncture, or tear sealant backings.
 - 3. Remove absorbent sealant backings that have become wet before sealant application and replace them with dry materials.
- C. Install bond-breaker tape behind sealants where sealant backings are not used between sealants and backs of joints.

- D. Install sealants using proven techniques that comply with the following and at the same time backings are installed:
1. Place sealants so they directly contact and fully wet joint substrates.
 2. Completely fill recesses in each joint configuration.
 3. Produce uniform, cross-sectional shapes and depths relative to joint widths that allow optimum sealant movement capability.
- E. Tooling of Nonsag Sealants: Immediately after sealant application and before skinning or curing begins, tool sealants according to requirements specified in subparagraphs below to form smooth, uniform beads of configuration indicated; to eliminate air pockets; and to ensure contact and adhesion of sealant with sides of joint.
1. Remove excess sealant from surfaces adjacent to joints.
 2. Use tooling agents that are approved in writing by sealant manufacturer and that do not discolor sealants or adjacent surfaces.
 3. Provide concave joint profile per Figure 8A in ASTM C 1193, unless otherwise indicated.
- F. Clean off excess sealant or sealant smears adjacent to joints as the Work progresses by methods and with cleaning materials approved in writing by manufacturers of joint sealants and of products in which joints occur.

4.3 JOINT-SEALANT SCHEDULE

- A. Joint-Sealant Application: Exterior joints in horizontal traffic surfaces.
1. Joint Locations:
 - a. Isolation and contraction joints in cast-in-place concrete slabs and walks.
 - b. Tile control and expansion joints.
 - c. Joints between different materials listed above.
 - d. Other joints as indicated.
 2. Joint Sealant: Urethane (US).
 3. Joint-Sealant Color: As selected by Architect from manufacturer's full range of colors.
- B. Joint-Sealant Application: Exterior joints in vertical surfaces and horizontal nontraffic surfaces.
1. Joint Locations:
 - a. Control and expansion joints in unit masonry.
 - b. Joints between different materials listed above.
 - c. Perimeter joints between materials listed above and frames of doors, windows, and louvers.
 - d. Other joints as indicated.
 2. Joint Sealant: Silicone (SS)

3. Joint-Sealant Color: As selected by Architect from manufacturer's full range of colors.
- C. Joint-Sealant Application: Interior joints in horizontal traffic surfaces.
1. Joint Locations:
 - a. Isolation joints in cast-in-place concrete slabs.
 - b. Control and expansion joints in tile flooring.
 - c. Other joints as indicated.
 2. Joint Sealant: Urethane (US)
 3. Joint-Sealant Color: As selected by Architect from manufacturer's full range of colors.
- D. Joint-Sealant Application: Interior joints in vertical surfaces and horizontal nontraffic surfaces.
1. Joint Locations:
 - a. Control and expansion joints on exposed interior surfaces of exterior walls.
 - b. Vertical joints on exposed surfaces of walls and partitions.
 - c. Perimeter joints between interior wall surfaces and frames of interior doors and windows.
 - d. Other joints as indicated.
 2. Joint Sealant: Latex (LS).
 3. Joint-Sealant Color: As selected by Architect from manufacturer's full range of colors.
- E. Joint-Sealant Application: Mildew-resistant interior joints in vertical surfaces and horizontal nontraffic surfaces.
1. Joint Sealant Location:
 - a. Joints between plumbing fixtures and adjoining walls, floors, and counters.
 - b. Tile control and expansion joints where indicated.
 - c. Other joints as indicated.
 2. Joint Sealant: Silicone (SS).
 3. Joint-Sealant Color: As selected by Architect from manufacturer's full range of colors.

END OF SECTION 079200

SECTION 081113 - HOLLOW METAL DOORS AND FRAMES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes hollow-metal doors and frames.

1.2 DEFINITIONS

- A. Minimum Thickness: Minimum thickness of base metal without coatings according to NAAMM-HMMA 803 or SDI A250.8.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Include elevations, door edge details, frame profiles, metal thicknesses, preparations for hardware, and other details.
- C. Schedule: Prepared by or under the supervision of supplier, using same reference numbers for details and openings as those on Drawings.

1.4 INFORMATIONAL SUBMITTALS

- A. Product test reports.

PART 2 - PRODUCTS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Ceco Door Products; an Assa Abloy Group company.
 - 2. Curries Company; an Assa Abloy Group company.
 - 3. An approved equal.

2.2 PERFORMANCE REQUIREMENTS

- A. Fire-Rated Assemblies: Complying with NFPA 80 and listed and labeled by a qualified testing agency acceptable to authorities having jurisdiction for fire-protection ratings indicated, based on testing at positive pressure according to NFPA 252 or UL 10C, where required.

1. Smoke- and Draft-Control Assemblies: Provide assemblies with gaskets listed and labeled for smoke and draft control by a qualified testing agency acceptable to authorities having jurisdiction, based on testing according to UL 1784 and installed in compliance with NFPA 105.
2. Temperature-Rise Limit: provide doors that have a maximum transmitted temperature end point of not more than 450 deg F above ambient after 30 minutes of standard fire-test exposure.

2.3 INTERIOR HOLLOW-METAL DOORS AND FRAMES

A. Standard-Duty Doors and Frames: SDI A250.8, Level 1.

1. Physical Performance: Level C according to SDI A250.4.
2. Doors:
 - a. Type: Flush.
 - b. Thickness: 1-3/4 inches.
 - c. Face: Metallic-coated steel sheet, minimum thickness of 0.042 inch, with minimum A40 coating.
 - d. Edge Construction: Model 1, Full Flush.
 - e. Core: Manufacturer's standard insulation material.
3. Thermal-Rated Doors: Provide doors fabricated with thermal-resistance value (R-value) of not less than 2.1 deg F x h x sq. ft./Btu when tested according to ASTM C 1363.
4. Frames:
 - a. Materials: Metallic-coated steel sheet, minimum thickness of 0.053 inch, with minimum A40 coating.
 - b. Construction: Face welded.
5. Exposed Finish: Prime.

2.4 FRAME ANCHORS

A. Jamb Anchors:

1. Type: Anchors of minimum size and type required by applicable door and frame standard, and suitable for performance level indicated.
2. Quantity: Minimum of three anchors per jamb, with one additional anchor for frames with no floor anchor.

B. Floor Anchors: Formed from same material as frames, minimum thickness of 0.042 inch , and as follows:

1. Monolithic Concrete Slabs: Clip-type anchors, with two holes to receive fasteners.

2.5 MATERIALS

- A. Recycled Content of Steel Products: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **25** percent.
- B. Cold-Rolled Steel Sheet: ASTM A 1008, Commercial Steel (CS), Type B; suitable for exposed applications.
- C. Hot-Rolled Steel Sheet: ASTM A 1011, Commercial Steel (CS), Type B; free of scale, pitting, or surface defects; pickled and oiled.
- D. Metallic-Coated Steel Sheet: ASTM A 653, Commercial Steel (CS), Type B.
- E. Frame Anchors: ASTM A 879/A 879M, Commercial Steel (CS), 04Z coating designation; mill phosphatized.
 - 1. For anchors built into exterior walls, steel sheet complying with ASTM A 1008 or ASTM A 1011, hot-dip galvanized according to ASTM A 153, Class B.
- F. Inserts, Bolts, and Fasteners: Hot-dip galvanized according to ASTM A 153.
- G. Power-Actuated Fasteners in Concrete: From corrosion-resistant materials.
- H. Grout: ASTM C 476, except with a maximum slump of 4 inches , as measured according to ASTM C 143.
- I. Mineral-Fiber Insulation: ASTM C 665, Type I (blankets without membrane facing).
- J. Bituminous Coating: Cold-applied asphalt mastic, compounded for 15-mil dry film thickness per coat.

2.6 HARDWARE

- A. Refer to Section 087100 "Door Hardware"

1. FABRICATION

- A. Fabricate hollow-metal work to be rigid and free of defects, warp, or buckle. Accurately form metal to required sizes and profiles, with minimum radius for metal thickness. Where practical, fit and assemble units in manufacturer's plant. To ensure proper assembly at Project site, clearly identify work that cannot be permanently factory assembled before shipment.
- B. Hollow-Metal Doors:
 - 1. Exterior Doors: Provide weep-hole openings in bottoms of doors to permit moisture to escape. Seal joints in top edges of doors against water penetration.

- C. Hollow-Metal Frames: Where frames are fabricated in sections due to shipping or handling limitations, provide alignment plates or angles at each joint, fabricated of same thickness metal as frames.
 - 1. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners unless otherwise indicated.
 - 2. Grout Guards: Weld guards to frame at back of hardware mortises in frames to be grouted.
 - 3. Floor Anchors: Weld anchors to bottoms of jambs with at least four spot welds per anchor.
 - 4. Jamb Anchors: Provide 3 anchors per jamb equally spaced.
 - 5. Door Silencers: Except on weather-stripped frames, drill stops to receive door silencers.
 - a. Single-Door Frames: Drill stop in strike jamb to receive three door silencers.
- D. Hardware Preparation: Factory prepare hollow-metal work to receive templated mortised hardware; include cutouts, reinforcement, mortising, drilling, and tapping according to SDI A250.6, the Door Hardware Schedule, and templates.
 - 1. Comply with applicable requirements in SDI A250.6 and BHMA A156.115 for preparation of hollow-metal work for hardware.

2.6 STEEL FINISHES

- A. Prime Finish: Clean, pretreat, and apply manufacturer's standard primer.
 - 1. Shop Primer: SDI A250.10.

2.7 ACCESSORIES

- A. Grout Guards: Formed from same material as frames, not less than 0.016 inch thick.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Hollow-Metal Frames: Install hollow-metal frames for doors, of size and profile indicated. Comply with SDI A250.11 or NAAMM-HMMA 840 as required by standards specified.
 - 1. Set frames accurately in position; plumbed, aligned, and braced securely until permanent anchors are set. After wall construction is complete, remove temporary braces, leaving surfaces smooth and undamaged.
 - a. At fire-rated openings, install frames according to NFPA 80.

- b. Install door silencers in frames before grouting.
 - c. Remove temporary braces necessary for installation only after frames have been properly set and secured.
 - d. Check plumb, square, and twist of frames as walls are constructed. Shim as necessary to comply with installation tolerances.
 - e. Field apply bituminous coating to backs of frames that will be filled with grout containing antifreezing agents.
 2. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor, and secure with postinstalled expansion anchors.
 - a. Floor anchors may be set with power-actuated fasteners instead of postinstalled expansion anchors if so indicated and approved on Shop Drawings.
 3. Masonry Walls: Coordinate installation of frames to allow for solidly filling space between frames and masonry with grout.
 4. Installation Tolerances: Adjust hollow-metal door frames for squareness, alignment, twist, and plumb to the following tolerances:
 - a. Squareness: Plus or minus 1/16 inch , measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
 - b. Alignment: Plus or minus 1/16 inch, measured at jambs on a horizontal line parallel to plane of wall.
 - c. Twist: Plus or minus 1/16 inch, measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
 - d. Plumbness: Plus or minus 1/16 inch, measured at jambs at floor.
- B. Hollow-Metal Doors: Fit hollow-metal doors accurately in frames, within clearances specified below. Shim as necessary.
 1. Non-Fire-Rated Steel Doors:
 - a. Between Door and Frame Jambs and Head: 1/8 inch plus or minus 1/32 inch.
 - b. Between Edges of Pairs of Doors: 1/8 inch to 1/4 inch plus or minus 1/32 inch.
 - c. At Bottom of Door: 5/8 inch plus or minus 1/32 inch.
 - d. Between Door Face and Stop: 1/16 inch to 1/8 inch plus or minus 1/32 inch.
- C. Hardware: Install each door hardware item to comply with manufacturer's written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work.

3.2 ADJUSTING AND CLEANING

- A. Final Adjustments: Check and readjust operating hardware items immediately before final inspection. Leave work in complete and proper operating condition. Remove and replace defective work, including hollow-metal work that is warped, bowed, or otherwise unacceptable.
- B. Remove grout and other bonding material from hollow-metal work immediately after installation.
- C. Prime-Coat Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat and apply touchup of compatible air-drying, rust-inhibitive primer.

END OF SECTION 081113

SECTION 081417 - WOOD AND FIBERGLASS DOORS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Solid-core fiberglass entry doors.
2. Hollow-core interior doors with hardboard or MDF faces.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of door.

B. Shop Drawings: Indicate location, size, and hand of each door; elevation of each kind of door; construction details not covered in Product Data; and the following:

1.3 QUALITY ASSURANCE

A. Manufacturer Qualifications: A qualified manufacturer that is acceptable to the Architect.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Manufacturers: Basis of Design Products: Subject to compliance with requirements, provide products indicated on the drawings.

2.2 WOOD DOORS, GENERAL

A. Quality Standard: In addition to requirements specified, comply with WDMA I.S.1-A, "Architectural Wood Flush Doors."

B. Low-Emitting Materials: Fabricate doors with adhesives and composite wood products that do not contain urea formaldehyde.

C. WDMA I.S.1-A Performance Grade:

1. Standard Duty

- D. Fire-Rated Wood Doors: Doors complying with NFPA 80 that are listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at positive pressure according to NFPA 252 UL 10C.
 - 1. Cores: Provide core specified or mineral core as needed to provide fire-protection rating indicated.
- E. Hollow-Core Doors:
 - 1. Construction: Standard hollow core.
 - 2. Type: Panel, as indicated on the drawings.

2.3 DOORS FOR OPAQUE FINISH

- A. Exterior Fiberglass doors:
 - 1. As indicated on the drawings.
- B. Interior Hollow-Core Doors:
 - 1. Grade: Custom.
 - 2. Faces: Hardboard or MDF, paneled.

2.4 FABRICATION

- C. Factory fit doors to suit frame-opening sizes indicated. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.
 - 1. Comply with NFPA 80 requirements for fire-rated doors.
- D. Factory machine doors for hardware that is not surface applied.
- E. Openings: Factory cut and trim openings through doors.
 - 1. Light Openings: Trim openings with moldings of material and profile indicated.
 - 2. Glazing: Factory install glazing in exterior doors as indicated

2.4 SHOP PRIMING

- A. Doors for Opaque Finish: Shop prime faces, all four edges, edges of cutouts, and mortises with one coat of wood primer or metal primer.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Hardware: For installation, see Section 087100 "Door Hardware."
- B. Installation Instructions: Install doors to comply with manufacturer's written instructions and referenced quality standard, and as indicated.
 - 1. Install fire-rated doors according to NFPA 80.
- C. Job-Fitted Doors: Align and fit doors in frames with uniform clearances and bevels as indicated below; do not trim stiles and rails in excess of limits set by manufacturer or permitted for fire-rated doors. Machine doors for hardware. Seal edges of doors, edges of cutouts, and mortises after fitting and machining.
 - 1. Clearances: Provide 1/8 inch at heads, jambs, and between pairs of doors. Provide 1/8 inch from bottom of door to top of decorative floor finish or covering unless otherwise indicated. Where threshold is shown or scheduled, provide 1/4 inch from bottom of door to top of threshold unless otherwise indicated.
 - a. Comply with NFPA 80 for fire-rated doors.

END OF SECTION 081416

SECTION 085200 – VINYL CLAD WOOD WINDOWS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes vinyl-clad wood windows.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Include plans, elevations, sections, hardware, accessories, insect screens, operational clearances, and details of installation, including anchor, flashing, and sealant installation.
- C. Samples: For each exposed product and for each color specified, 2 by 4 inches in size.
- D. Product Schedule: For wood windows. Use same designations indicated on Drawings.

1.3 INFORMATIONAL SUBMITTALS

- A. Product test reports.
- B. Sample warranties.

1.4 WARRANTY

- A. Manufacturer's Warranty: Manufacturer agrees to repair or replace wood windows that fail in materials or workmanship within specified warranty period.
 - 1. Warranty Period:
 - a. Window: 10 years from date of Substantial Completion.
 - b. Glazing Units: 20 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- 1. Vinyl-Clad Wood Windows:

2. Manufacturers: Basis of Design Product: Subject to compliance with requirements, provide products indicated on the drawings

2.2 WINDOW PERFORMANCE REQUIREMENTS

- A. Product Standard: AAMA/WDMA/CSA 101/I.S.2/A440.
 1. Minimum Performance Class: R
 2. Minimum Performance Grade: 15
 3. Provide with Coastal Storm Watch Components.
- B. Thermal Transmittance: NFRC 100 maximum whole-window U-factor of 0.30 Btu/sq. ft. x h x deg F.
- C. Solar Heat-Gain Coefficient (SHGC): NFRC 200 maximum whole-window SHGC of 0.40

2.3 WOOD WINDOWS

- A. Operating Types: Double Hung-Tilt Wash.
 1. Double Hung Tilt Wash
 2. Projected Awning
 3. Casement
- B. Frames and Sashes: Fine-grained wood lumber complying with AAMA/WDMA/CSA 101/I.S.2/A440; kiln dried to a moisture content of not more than 12 percent at time of fabrication; free of visible finger joints, blue stain, knots, pitch pockets, and surface checks larger than 1/32 inch deep by 2 inches wide; water-repellent preservative treated.
 1. Exterior Finish: Vinyl-clad wood.
 - a. Color: As selected by Architect from manufacturer's full range.
 2. Interior Finish: Unfinished.
- C. Glass: Clear annealed glass, ASTM C 1036, Type 1, Class 1, q3.
- D. Insulating-Glass Units: ASTM E 2190.
 1. Glass: ASTM C 1036, Type 1, Class 1, q3.
 - a. Tint: Clear.
 - b. Safety Glass: Provide Kind FT, fully tempered, labeled safety glass where indicated on Drawings.
 2. Lites: Two.
 3. Filling: Fill space between glass lites with argon.

4. Low-E Coating: Pyrolytic on second surface.
- E. Glazing System: Manufacturer's standard factory-glazing system that produces weathertight seal.
- F. Hardware, General: Manufacturer's standard corrosion-resistant hardware sized to accommodate sash weight and dimensions.
 1. Exposed Hardware Color and Finish: As selected by Architect from manufacturer's full range
- G. Hung Window Hardware:
 1. Counterbalancing Mechanism: AAMA 902.
 2. Locks and Latches: Operated from the inside only.
 3. Tilt Hardware: Releasing tilt latch allows sash to pivot about horizontal axis.
- H. Projected Window Hardware:
 1. Gear-Type Rotary Operators: Complying with AAMA 901 when tested according to ASTM E 405, Method A. Provide operators that function without requiring the removal of interior screens or using screen wickets.
 - a. Type and Style: As selected by Architect from manufacturer's full range of types and styles.
 2. Hinges: Manufacturer's standard type for sash weight and size indicated.
 3. Single-Handle Locking System: Operates positive-acting arms that pull sash into locked position. Provide one arm on sashes up to 29 inches tall and two arms on taller sashes.
- I. Weather Stripping: Provide full-perimeter weather stripping for each operable sash unless otherwise indicated.
- J. Fasteners: Noncorrosive and compatible with window members, trim, hardware, anchors, and other components.
 1. Exposed Fasteners: Do not use exposed fasteners to the greatest extent possible. For application of hardware, use fasteners that match finish hardware being fastened.

2.4 ACCESSORIES

- A. Dividers (False Muntins): Provide divider grilles in designs indicated for each sash lite.
 1. Quantity and Type: Two per sash, removable from exposed surfaces of interior and permanently located at exterior lite.
 2. Material: Manufacturer's standard.
 3. Pattern: As indicated on Drawings
 4. Profile: As selected by Architect from manufacturer's full range.

5. Color: As selected by Architect from manufacturer's full range.

2.5 INSECT SCREENS

- A. General: Fabricate insect screens to integrate with window frame. Provide screen for each operable exterior sash. Screen wickets are not permitted.
 1. Type and Location: Full, outside for double-hung sashes.
- B. Aluminum Frames: Complying with SMA 1004 or SMA 1201.
 1. Finish for Exterior Screens: Baked-on organic coating in color selected by Architect from manufacturer's full range.
- C. Glass-Fiber Mesh Fabric: 18-by-14 mesh complying with ASTM D 3656.
 1. Mesh Color: Manufacturer's standard.

2.6 FABRICATION

- A. Fabricate wood windows in sizes indicated. Include a complete system for installing and anchoring windows.
- B. Glaze wood windows in the factory.
- C. Weather strip each operable sash to provide weathertight installation.
- D. Provide mullions and cover plates, matching window units, complete with anchors for support to structure and installation of window units. Allow for erection tolerances and provide for movement of window units due to thermal expansion and building deflections. Provide mullions and cover plates capable of withstanding design wind loads of window units.
- E. Complete fabrication, assembly, finishing, hardware application, and other work in the factory to greatest extent possible. Disassemble components only as necessary for shipment and installation. Allow for scribing, trimming, and fitting at Project site.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Comply with manufacturer's written instructions for installing windows, hardware, accessories, and other components. For installation procedures and requirements not addressed in manufacturer's written instructions, comply with installation requirements in ASTM E 2112.

- B. Install windows level, plumb, square, true to line, without distortion, anchored securely in place to structural support, and in proper relation to wall flashing and other adjacent construction to produce weathertight construction.
- C. Adjust operating sashes and hardware for a tight fit at contact points and weather stripping for smooth operation and weathertight closure.
- D. Clean exposed surfaces immediately after installing windows. Remove excess sealants, glazing materials, dirt, and other substances.
- E. Remove and replace sashes if glass has been broken, chipped, cracked, abraded, or damaged during construction period.

END OF SECTION 085200

SECTION 087100 - DOOR HARDWARE

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes:
1. Mechanical door hardware for the following:
 - a. Swinging doors.

1.2 ACTION SUBMITTALS

- A. Other Action Submittals:
1. Door Hardware Schedule: Prepared by or under the supervision of Installer, detailing fabrication and assembly of door hardware, as well as installation procedures and diagrams. Coordinate final door hardware schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
 - a. Format: Use same scheduling sequence and format and use same door numbers as in the Contract Documents.
 - b. Content: Include the following information:
 - 1) Identification number, location, hand, fire rating, size, and material of each door and frame.
 - 2) Locations of each door hardware set, cross-referenced to Drawings on floor plans and to door and frame schedule.
 - 3) Complete designations, including name and manufacturer, type, style, function, size, quantity, function, and finish of each door hardware product.
 - 4) Description of electrified door hardware sequences of operation and interfaces with other building control systems.
 2. Keying Schedule: Prepared by or under the supervision of Installer, detailing Owner's final keying instructions for locks.

1.3 QUALITY ASSURANCE

- A. Installer Qualifications: Supplier of products and an employer of workers trained and approved by product manufacturers and an Architectural Hardware Consultant who is available during the course of the Work to consult with Contractor, Architect, and Owner about door hardware and keying.

- B. Fire-Rated Door Assemblies: Where fire-rated door assemblies are indicated, provide door hardware rated for use in assemblies complying with NFPA 80 that are listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at positive pressure according to NFPA 252 or UL 10C, unless otherwise indicated.
- C. Smoke- and Draft-Control Door Assemblies: Where smoke- and draft-control door assemblies are required, provide door hardware that meet requirements of assemblies tested according to UL 1784 and installed in compliance with NFPA 105.
 - 1. Air Leakage Rate: Maximum air leakage of 0.3 cfm/sq. ft. at the tested pressure differential of 0.3-inch wg of water.
- D. Means of Egress Doors: Latches do not require more than 15 lbf to release the latch. Locks do not require use of a key, tool, or special knowledge for operation.

1.4 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.
 - 1. Warranty Period: Three years from date of Substantial Completion, unless otherwise indicated.

PART 2 - PRODUCTS

2.1 SCHEDULED DOOR HARDWARE

- A. Provide door hardware for each door as scheduled on Drawings.
- B. Hardware shall be provided under a Contract Allowance. Refer to Section 010200 "Allowances"
 - 1. Door Hardware Sets: Provide quantity, item, size, finish or color indicated, and products complying with BHMA designations referenced.
- C. Designations: Requirements for design, grade, function, finish, size, and other distinctive qualities of each type of door hardware are indicated in Part 3 "Door Hardware Schedule" Article. Products are identified by using door hardware designations, as follows:
 - 1. References to BHMA Designations: Provide products complying with these designations and requirements for description, quality, and function.

2.2 HINGES

- A. Hinges: BHMA A156.1. Provide template-produced hinges for hinges installed on hollow-metal doors and hollow-metal frames.

2.3 MECHANICAL LOCKS AND LATCHES

- A. Strikes: Provide manufacturer's standard strike for each lock bolt or latchbolt complying with requirements indicated for applicable lock or latch and with strike box and curved lip extended to protect frame; finished to match lock or latch.
 - 1. Flat-Lip Strikes: For locks with three-piece antifriction latchbolts, as recommended by manufacturer.
 - 2. Extra-Long-Lip Strikes: For locks used on frames with applied wood casing trim.
 - 3. Aluminum-Frame Strike Box: Manufacturer's special strike box fabricated for aluminum framing.
- B. Bored Locks: BHMA A156.2; Grade 2 Series 4000.
- C. Mortise Locks: BHMA A156.13; Grade 2; stamped steel case with steel or brass parts; Series 1000.

2.4 AUXILIARY LOCKS

- A. Bored Auxiliary Locks: BHMA A156.5: Grade 2; with strike that suits frame.
- B. Mortise Auxiliary Locks: BHMA A156.5; Grade 2; with strike that suits frame.

2.5 LOCK CYLINDERS

- A. Lock Cylinders: Tumbler type, constructed from brass or bronze, stainless steel, or nickel silver.
 - 1. Manufacturer: Same manufacturer as for locking devices.
- B. Construction Cores: Provide construction cores that are replaceable by permanent cores. Provide 10 construction master keys.

2.6 KEYING

- A. Keying System: Factory registered, complying with guidelines in BHMA A156.28, Appendix
 - 1. No Master Key System: Only change keys operate cylinder.
- B. Keys:
 - 1. Quantity: In addition to one extra key blank for each lock, provide the following:
 - a. Cylinder Change Keys: Five.

2.7 OPERATING TRIM

- A. Operating Trim: BHMA A156.6; See Editing Instruction No. 1 in the Evaluations for cautions about naming manufacturers. Retain one of two subparagraphs and list of manufacturers below. See Section 016000 "Product Requirements."

2.8 MECHANICAL STOPS AND HOLDERS

- A. Wall- and Floor-Mounted Stops: BHMA A156.16.

2.9 OVERHEAD STOPS AND HOLDERS

- A. Overhead Stops and Holders: BHMA A156.8.

2.10 DOOR GASKETING

- A. Door Gasketing: BHMA A156.22; air leakage not to exceed 0.50 cfm per foot of crack length for gasketing other than for smoke control, as tested according to ASTM E 283; with resilient or flexible seal strips that are easily replaceable and readily available from stocks maintained by manufacturer.

2.11 THRESHOLDS

- A. Thresholds: BHMA A156.21; fabricated to full width of opening indicated.

2.12 AUXILIARY DOOR HARDWARE

- A. Auxiliary Hardware: BHMA A156.16.

2.13 FABRICATION

- A. Fasteners: Provide door hardware manufactured to comply with published templates prepared for machine, wood, and sheet metal screws. Provide screws that comply with commercially recognized industry standards for application intended, except aluminum fasteners are not permitted. Provide Phillips flat-head screws with finished heads to match surface of door hardware, unless otherwise indicated.

1. Concealed Fasteners: For door hardware units that are exposed when door is closed, except for units already specified with concealed fasteners. Do not use through bolts for installation where bolt head or nut on opposite face is exposed unless it is the only means of securely attaching the door hardware. Where through bolts are used on hollow door and frame construction, provide sleeves for each through bolt.
2. Fire-Rated Applications:

- a. Wood or Machine Screws: For the following:
 - 1) Hinges mortised to doors or frames; use threaded-to-the-head wood screws for wood doors and frames.
 - 2) Strike plates to frames.
 - 3) Closers to doors and frames.
- 3. Spacers or Sex Bolts: For through bolting of hollow-metal doors.
- 4. Fasteners for Wood Doors: Comply with requirements in DHI WDHS.2, "Recommended Fasteners for Wood Doors."
- 5. Gasketing Fasteners: Provide noncorrosive fasteners for exterior applications and elsewhere as indicated.

2.14 FINISHES

- A. Provide finishes complying with BHMA A156.18 as indicated in door hardware schedule.
- B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Steel Doors and Frames: For surface applied door hardware, drill and tap doors and frames according to ANSI/SDI A250.6.
- B. Wood Doors: Comply with DHI WDHS.5 "Recommended Hardware Reinforcement Locations for Mineral Core Wood Flush Doors."
- C. Mounting Heights: Mount door hardware units at heights to comply with the following unless otherwise indicated or required to comply with governing regulations.
 - 1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
 - 2. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."
- D. Install each door hardware item to comply with manufacturer's written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work. Do not install surface-mounted items until finishes have been completed on substrates involved.
 - 1. Set units level, plumb, and true to line and location. Adjust and reinforce attachment substrates as necessary for proper installation and operation.

2. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.
- E. Hinges: Install types and in quantities indicated in door hardware schedule but not fewer than the number recommended by manufacturer for application indicated or one hinge for every 30 inches of door height, whichever is more stringent, unless other equivalent means of support for door, such as spring hinges or pivots, are provided.
- F. Lock Cylinders: Install construction cores to secure building and areas during construction period.
 1. Replace construction cores with permanent cores.
- G. Thresholds: Set thresholds for exterior doors and other doors indicated in full bed of sealant complying with requirements specified in Section 079200 "Joint Sealants."
- H. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they will impede traffic.
- I. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.
- J. Meeting Stile Gasketing: Fasten to meeting stiles, forming seal when doors are closed.
- K. Door Bottoms: Apply to bottom of door, forming seal with threshold when door is closed.
- L. Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

END OF SECTION 087100

SECTION 089516 - WALL VENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes wall vents and cast in place bucks.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.

PART 2 - PRODUCTS

2.1 WALL VENTS (FLOOD VENTS)

- A. Stainless Steel Flood Vent:
 - 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Smart Vent Model # 1540-570 (with fire damper) 1540-510 (with Vinyl Buck)
 - b. An approved equal

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install vinyl buck in formwork plumb and level at locations indicated with reversible fasteners into wood nailing blocks as per manufacturer's instructions.
- B. After removing forms install flood vent in buck as per manufacturer's instructions."

END OF SECTION 089516

SECTION 092900 - GYPSUM BOARD

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Interior gypsum board.
 2. Exterior gypsum board for ceilings and soffits.
 3. Tile backing panels.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Resistance-Rated Assemblies: For fire-resistance-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 119 by an independent testing agency.
- B. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 90 and classified according to ASTM E 413 by an independent testing agency.

2.2 GYPSUM BOARD, GENERAL

- A. Size: Provide maximum lengths and widths available that will minimize joints in each area and that correspond with support system indicated.

2.3 INTERIOR GYPSUM BOARD

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Georgia-Pacific Gypsum LLC.
 2. National Gypsum Company.
 3. USG Corporation.
 4. An approved equal.

- B. Gypsum Wallboard: ASTM C 1396
 - 1. Thickness: 1/2 inch
 - 2. Long Edges: Tapered.

- C. Gypsum Board, Type X: ASTM C 1396.
 - 1. Thickness: 5/8 inch
 - 2. Long Edges: Tapered.

- D. Gypsum Ceiling Board: ASTM C 1396.
 - 1. Thickness: 1/2 inch.
 - 2. Long Edges: Tapered.

- E. Mold-Resistant Gypsum Board: ASTM C 1396 With moisture- and mold-resistant core and paper surfaces.
 - 1. Core: 1/2 inch , regular type.
 - 2. Long Edges: Tapered.
 - 3. Mold Resistance: ASTM D 3273, score of 10 as rated according to ASTM D 3274.

2.4 EXTERIOR GYPSUM BOARD FOR CEILINGS AND SOFFITS

- A. Glass-Mat Gypsum Sheathing Board: ASTM C 1177, with fiberglass mat laminated to both sides and with manufacturer's standard edges.
 - 1. Core: 5/8 inch, Type X.

2.5 TILE BACKING PANELS

- A. Glass-Mat, Water-Resistant Backing Board: ASTM C 1178, with manufacturer's standard edges.
 - 1. Core: 1/2 inch , regular type
 - 2. Mold Resistance: ASTM D 3273, score of 10 as rated according to ASTM D 3274.

2.6 TRIM ACCESSORIES

- A. Interior Trim: ASTM C 1047.
 - 1. Material: Galvanized or aluminum-coated steel sheet.
 - 2. Shapes:
 - a. Cornerbead.
 - b. LC-Bead: J-shaped; exposed long flange receives joint compound.
 - c. L-Bead: L-shaped; exposed long flange receives joint compound.
 - d. U-Bead: J-shaped; exposed short flange does not receive joint compound.
 - e. Expansion (control) joint.

B. Exterior Trim: ASTM C 1047.

1. Material: Hot-dip galvanized-steel sheet, plastic, or rolled zinc.
2. Shapes:
 - a. Cornerbead.
 - b. LC-Bead: J-shaped; exposed long flange receives joint compound.
 - c. Expansion (Control) Joint: One-piece, rolled zinc with V-shaped slot and removable strip covering slot opening.

2.7 JOINT TREATMENT MATERIALS

A. General: Comply with ASTM C 475/C 475M.

B. Joint Tape:

1. Interior Gypsum Board: Paper.
2. Exterior Gypsum Soffit Board: Paper.
3. Glass-Mat Gypsum Sheathing Board: 10-by-10 glass mesh.
4. Tile Backing Panels: As recommended by panel manufacturer.

C. Joint Compound for Interior Gypsum Board: For each coat, use formulation that is compatible with other compounds applied on previous or for successive coats.

1. Prefilling: At open joints, rounded or beveled panel edges, and damaged surface areas, use setting-type taping compound.
2. Embedding and First Coat: For embedding tape and first coat on joints, fasteners, and trim flanges, use setting-type taping compound.
 - a. Use setting-type compound for installing paper-faced metal trim accessories.
3. Fill Coat: For second coat, use setting-type, sandable topping compound.
4. Finish Coat: For third coat, use setting-type, sandable topping compound.

D. Joint Compound for Exterior Applications:

1. Exterior Gypsum Soffit Board: Use setting-type taping compound and setting-type, sandable topping compound.
2. Glass-Mat Gypsum Sheathing Board: As recommended by sheathing board manufacturer.

E. Joint Compound for Tile Backing Panels:

1. Glass-Mat, Water-Resistant Backing Panel: As recommended by backing panel manufacturer.
2. Cementitious Backer Units: As recommended by backer unit manufacturer.

2.8 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards and manufacturer's written instructions.
- B. Laminating Adhesive: Adhesive or joint compound recommended for directly adhering gypsum panels to continuous substrate.
- C. Steel Drill Screws: ASTM C 1002 unless otherwise indicated.
 - 1. Use screws complying with ASTM C 954 for fastening panels to steel members from 0.033 to 0.112 inch thick.
 - 2. For fastening cementitious backer units, use screws of type and size recommended by panel manufacturer.
- D. Sound-Attenuation Blankets: ASTM C 665, Type I (blankets without membrane facing) produced by combining thermosetting resins with mineral fibers manufactured from glass, slag wool, or rock wool.
 - 1. Fire-Resistance-Rated Assemblies: Comply with mineral-fiber requirements of assembly.
- E. Acoustical Sealant: Manufacturer's standard nonsag, paintable, nonstaining latex sealant complying with ASTM C 834. Product effectively reduces airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing representative assemblies according to ASTM E 90.
- F. Thermal Insulation: As specified in Section 072100 "Thermal Insulation."

PART 3 - EXECUTION

3.1 APPLYING AND FINISHING PANELS

- A. Examine panels before installation. Reject panels that are wet, moisture damaged, and mold damaged.
- B. Comply with ASTM C 840.
- C. Isolate perimeter of gypsum board applied to non-load-bearing partitions at structural abutments. Provide 1/4- to 1/2-inch- wide spaces at these locations and trim edges with edge trim where edges of panels are exposed. Seal joints between edges and abutting structural surfaces with acoustical sealant.
- D. For trim with back flanges intended for fasteners, attach to framing with same fasteners used for panels. Otherwise, attach trim according to manufacturer's written instructions.
- E. Prefill open joints and damaged surface areas.

- F. Apply joint tape over gypsum board joints, except for trim products specifically indicated as not intended to receive tape.

- G. Gypsum Board Finish Levels: Finish panels to levels indicated below and according to ASTM C 840:
 - 1. Level 1: Ceiling plenum areas, concealed areas, and where indicated.
 - 2. Level 2: Panels that are substrate for tile.
 - 3. Level 3: Not applicable.
 - 4. Level 4: At panel surfaces that will be exposed to view unless otherwise indicated.
 - a. Primer and its application to surfaces are specified in Section 099123 "Interior Painting."
 - 5. Level 5: Not applicable.
 - a. Primer and its application to surfaces are specified in Section 099123 "Interior Painting."

- H. Glass-Mat Gypsum Sheathing Board: Finish according to manufacturer's written instructions for use as exposed soffit board.

- I. Glass-Mat Faced Panels: Finish according to manufacturer's written instructions.

- J. Cementitious Backer Units: Finish according to manufacturer's written instructions.

3.2 PROTECTION

- A. Protect installed products from damage from weather, condensation, direct sunlight, construction, and other causes during remainder of the construction period.

- B. Remove and replace panels that are wet, moisture damaged, and mold damaged.

END OF SECTION 092900

SECTION 093000 - TILING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Ceramic tile.
 2. Stone thresholds.
 3. Waterproof membrane.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
1. Product Data for adhesives and grouts documentation including printed statement of VOC content.
 2. Product Data for tile floors, documentation from an independent testing agency indicating compliance with the FloorScore Standard.

1.3 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match and are from same production runs as products installed and that are packaged with protective covering and identified with labels describing contents.
1. Tile and Trim Units: Furnish quantity of full-size units equal to 3 percent of amount installed for each type, composition, color, pattern, and size indicated.

PART 2 - PRODUCTS

2.1 TILE PRODUCTS

- A. ANSI Ceramic Tile Standard: Provide Standard grade tile that complies with ANSI A137.1 for types, compositions, and other characteristics indicated.
- B. FloorScore Compliance: Tile for floors shall comply with requirements of FloorScore Standard.
- C. Tile shall be provided as indicated on the Drawings.

- D. Setting materials source limitations: Setting materials including thin set mix, grout, water proof membranes and crack isolation membranes shall be by the same manufacturer and approved by the manufacturer in writing as being compatible for use in a complete assembly with the tile selected.

2.2 THRESHOLDS

- A. General: Fabricate to sizes and profiles indicated or required to provide transition between adjacent floor finishes.
1. Bevel edges at 1:2 slope, with lower edge of bevel aligned with or up to 1/16 inch above adjacent floor surface. Finish bevel to match top surface of threshold. Limit height of threshold to 1/2 inch or less above adjacent floor surface.
- B. Marble Thresholds: ASTM C 503, with a minimum abrasion resistance of 10 per ASTM C 1353 or ASTM C 241 and with honed finish.
1. Description: Uniform, fine- to medium-grained white stone with gray veining.

2.3 TILE BACKING PANELS

- A. Refer to Section 092900 for tile backing panels

2.4 WATERPROOF MEMBRANE

- A. General: Manufacturer's standard product that complies with ANSI A118.10 and is recommended by the manufacturer for the application indicated.
- B. Fabric-Reinforced, Fluid-Applied Membrane: System consisting of liquid-latex rubber or elastomeric polymer and continuous fabric reinforcement.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Laticrete International, Inc.; Laticrete 9235 Waterproof Membrane.
 - b. MAPEI Corporation; Mapelastic HPG with MAPEI Fiberglass Mesh.
 - c. Approved equal.

2.5 SETTING MATERIALS

- A. Latex-Portland Cement Mortar (Thin Set): ANSI A118.4.
1. Basis-of-Design Product: Subject to compliance with requirements, provide product by one of the following:
 - a. Laticrete International, Inc.

- b. MAPEI Corporation.
- c. Approved equal.
2. For wall applications, provide nonsagging mortar.

2.6 GROUT MATERIALS

- A. Standard Cement Grout: ANSI A118.6.
 1. Basis-of-Design Product: Subject to compliance with requirements, provide product by one of the following:
 - a. Laticrete International, Inc.
 - b. MAPEI Corporation.
 - c. Approved equal
- B. Polymer-Modified Tile Grout: ANSI A118.7.
 1. Basis-of-Design Product: Subject to compliance with requirements, provide product by one of the following:
 - a. Laticrete International, Inc.
 - b. MAPEI Corporation.
 - c. Approved equal

2.7 MISCELLANEOUS MATERIALS

- A. Trowelable Underlayments and Patching Compounds: Latex-modified, portland cement-based formulation provided or approved by manufacturer of tile-setting materials for installations indicated.
- B. Metal Edge Strips: Angle or L-shape, stainless steel, ASTM A 666, 300 Series exposed-edge material.
- C. Grout Sealer: Manufacturer's standard silicone product for sealing grout joints and that does not change color or appearance of grout.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions where tile will be installed, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of installed tile.
 1. Verify that substrates for setting tile are firm, dry, clean, free of coatings that are incompatible with tile-setting materials including curing compounds and other substances that contain soap, wax, oil, or silicone; and comply with flatness tolerances required by ANSI A108.01 for installations indicated.

3.2 PREPARATION

- A. Fill cracks, holes, and depressions in concrete substrates for tile floors installed with thin-set mortar with trowelable leveling and patching compound specifically recommended by tile-setting material manufacturer.
- B. Where indicated, prepare substrates to receive waterproofing by applying a reinforced mortar bed that complies with ANSI A108.1A
- C. Blending: For tile exhibiting color variations, use factory blended tile or blend tiles at Project site before installing.
- D. Field-Applied Temporary Protective Coating: If indicated under tile type or needed to prevent grout from staining or adhering to exposed tile surfaces, precoat them with continuous film of temporary protective coating, taking care not to coat unexposed tile surfaces.

3.3 INSTALLATION

- A. Comply with TCA's "Handbook for Ceramic Tile Installation" for TCA installation methods specified in tile installation schedules. Comply with parts of the ANSI A108 Series "Specifications for Installation of Ceramic Tile" that are referenced in TCA installation methods, specified in tile installation schedules, and apply to types of setting and grouting materials used.
 - 1. For the following installations, follow procedures in the ANSI A108 Series of tile installation standards for providing 95 percent mortar coverage:
 - a. Tile floors in wet areas.
 - b. Tile floors in laundries.
 - c. Tile floors composed of tiles 8 by 8 inches or larger.
 - d. Tile floors composed of rib-backed tiles.
- B. Extend tile work into recesses and under or behind equipment and fixtures to form complete covering without interruptions unless otherwise indicated. Terminate work neatly at obstructions, edges, and corners without disrupting pattern or joint alignments.
- C. Accurately form intersections and returns. Perform cutting and drilling of tile without marring visible surfaces. Carefully grind cut edges of tile abutting trim, finish, or built-in items for straight aligned joints. Fit tile closely to electrical outlets, piping, fixtures, and other penetrations so plates, collars, or covers overlap tile.
- D. Provide manufacturer's standard trim shapes where necessary to eliminate exposed tile edges.
- E. Jointing Pattern: Lay tile in grid pattern unless otherwise indicated. Lay out tile work and center tile fields in both directions in each space or on each wall area. Lay out tile work to minimize the use of pieces that are less than half of a tile. Provide uniform joint widths unless otherwise indicated.
- F. Joint Widths: Unless otherwise indicated, install tile with the following joint widths:

1. Ceramic Mosaic Tile: 1/16 inch.
 2. Glazed Wall Tile: 1/16 inch.
 3. Decorative Thin Wall Tile: 1/16 inch.
- G. Lay out tile wainscots to dimensions indicated or to next full tile beyond dimensions indicated.
- H. Expansion Joints: Provide expansion joints and other sealant-filled joints, including control, contraction, and isolation joints, where indicated. Form joints during installation of setting materials, mortar beds, and tile. Do not saw-cut joints after installing tiles.
1. Where joints occur in concrete substrates, locate joints in tile surfaces directly above them.
 2. Prepare joints and apply sealants to comply with requirements in Section 079200 "Joint Sealants."
- I. Stone Thresholds: Install stone thresholds in same type of setting bed as adjacent floor unless otherwise indicated.
1. At locations where mortar bed (thickset) would otherwise be exposed above adjacent floor finishes, set thresholds in latex-portland cement mortar (thin set).
- J. Metal Edge Strips: Install [at locations indicated] [where exposed edge of tile flooring meets carpet, wood, or other flooring that finishes flush with top of tile] [where exposed edge of tile flooring meets carpet, wood, or other flooring that finishes flush with or below top of tile and no threshold is indicated].
- K. Install cementitious backer units and treat joints according to ANSI A108.11 and manufacturer's written instructions for type of application indicated. Use latex-portland cement mortar for bonding material unless otherwise directed in manufacturer's written instructions.]
- L. Install waterproofing to comply with ANSI A108.13 and manufacturer's written instructions to produce waterproof membrane of uniform thickness and bonded securely to substrate.
- M. Install crack isolation membrane to comply with ANSI A108.17 and manufacturer's written instructions to produce membrane of uniform thickness and bonded securely to substrate.
- 3.4 INTERIOR TILE INSTALLATION SCHEDULE
- A. Interior Floor Installations, Wood Subfloor:
1. Tile Installation F144: Thin-set mortar on cementitious backer units/fiber cement underlayment; TCA F144.
 - a. Locations used: locations other than bathrooms and laundry rooms.
 - b. Thin-Set Mortar: Latex-portland cement mortar.
 - c. Grout: Standard unsanded grout.

2. Tile Installation F144: Thin-set mortar on cementitious backer units/fiber cement underlayment; TCA F144. with waterproof membrane
 - a. Locations used: bathrooms and laundry rooms.
 - b. Thin-Set Mortar: Latex-portland cement mortar.
 - c. Grout: Standard unsanded grout.
 - d. waterproof membrane

B. Interior Wall Installations, Wood Studs or Furring:

1. Tile Installation W244: Thin-set mortar on cementitious backer units or fiber cement underlayment; TCA W244.
 - a. Thin-Set Mortar: Latex-portland cement mortar.
 - b. Grout: Standard unsanded cement grout

END OF SECTION 093000

SECTION 096400 - WOOD FLOORING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Factory-finished wood flooring.
 2. Sound control underlayment.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
1. Product Data: For wood flooring installation adhesives, documentation including printed statement of VOC content.
 2. Product Data: For field-applied finishes, documentation including printed statement of VOC content.
 3. Product Data: For wood flooring system elements, documentation from an independent testing agency indicating certification under the RFCI FloorScore program and that finishes comply with SCAQMD Rule 1113.
- B. Samples: For each exposed product and for each color and texture specified.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. FloorScore Certification: Wood floors shall be certified under the RFCI FloorScore program.
1. Floor finishes shall comply with requirements of SCAQMD Rule 1113, "Architectural Coatings."
- B. Hardwood Flooring: Comply with NWFA A500 for species, grade, and cut.
1. Certification: Provide flooring that carries NWFA grade stamp on each bundle or piece.
 2. Certification: Provide flooring that carries MFMA mark on each bundle or piece.

2.2 FACTORY-FINISHED WOOD FLOORING

- A. Solid-Wood Flooring: Kiln dried to 6 to 9 percent maximum moisture content; tongue and groove and end matched; with backs channeled.

1. Species: Red oak.
2. Grade: Clear.
3. Cut: Plain sawn
4. Thickness: 3/4 inch.
5. Face Width: 2-1/4 inches.
6. Lengths: Random-length strips complying with applicable grading rules.
7. Edge Style: Square.
8. Finish: UV urethane.
 - a. Color: As selected by Architect from manufacturer's full range.

2.3 SOUND CONTROL UNDERLAYMENT

2.4 ACCESSORY MATERIALS

- A. Wood Underlayment: As specified in Section 061600 "Sheathing."
- B. Asphalt-Saturated Felt: ASTM D 4869, Type II.
- C. Trowelable Leveling and Patching Compound: Latex-modified, hydraulic-cement-based formulation approved by wood flooring manufacturer.
- D. Fasteners: As recommended by manufacturer, but not less than that recommended in NWFA's "Installation Guidelines."
- E. Thresholds and Saddles: To match wood flooring. Tapered on each side.
- F. Reducer Strips: To match wood flooring. 2 inches wide, tapered, and in thickness required to match height of flooring.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Broom or vacuum clean substrates to be covered immediately before product installation. After cleaning, examine substrates for moisture, alkaline salts, carbonation, or dust. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Comply with flooring manufacturer's written installation instructions, but not less than applicable recommendations in NWFA's "Installation Guidelines."
- B. Subfloor: Install according to requirements in Section 061000 "Rough Carpentry" and Section 061600 "Sheathing."

- C. Provide expansion space at walls and other obstructions and terminations of flooring of not less than 3/4 inch.
- D. Vapor Retarder: Comply with the following for vapor retarder installation:
 - 1. Wood Flooring Nailed to Wood Subfloor: Install flooring over a layer of asphalt-saturated felt.
- E. Solid-Wood Flooring: Blind nail or staple flooring to substrate.

3.3 PROTECTION

- A. Protect installed wood flooring during remainder of construction period with covering of heavy kraft paper or other suitable material. Do not use plastic sheet or film that might cause condensation.
 - 1. Do not move heavy and sharp objects directly over kraft-paper-covered wood flooring. Protect flooring with plywood or hardboard panels to prevent damage from storing or moving objects over flooring.

END OF SECTION 096400

SECTION 099123 - INTERIOR PAINTING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes surface preparation and the application of paint systems on the following interior substrates:
 - 1. Wood.
 - 2. Gypsum board.

1.2 DEFINITIONS

- A. MPI Gloss Level 3: 10 to 25 units at 60 degrees and 10 to 35 units at 85 degrees, according to ASTM D 523.
- B. MPI Gloss Level 5: 35 to 70 units at 60 degrees, according to ASTM D 523.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product. Include preparation requirements and application instructions.
 - 1. Include Printout of current "MPI Approved Products List" for each product category specified, with the proposed product highlighted.
 - 2. Product Data For paints and coatings, documentation including printed statement of VOC content.
- B. Samples: For each type of paint system and in each color and gloss of topcoat.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Products: Subject to compliance with requirements, provide one of the products listed in the Interior Painting Schedule for the paint category indicated.

2.2 PAINT, GENERAL

- A. MPI Standards: Products shall comply with MPI standards indicated and shall be listed in its "MPI Approved Products Lists."
- B. Material Compatibility:
 - 1. Materials for use within each paint system shall be compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
 - 2. For each coat in a paint system, products shall be recommended in writing by topcoat manufacturers for use in paint system and on substrate indicated.
- C. VOC Content: Products shall comply with VOC limits of authorities having jurisdiction and, for interior paints and coatings applied at Project site, the following VOC limits, exclusive of colorants added to a tint base:
 - 1. Flat Paints and Coatings: 50 g/L.
 - 2. Nonflat Paints and Coatings: 150 g/L.
 - 3. Primers, Sealers, and Undercoaters: 200 g/L.
 - 4. Anticorrosive and Antirust Paints Applied to Ferrous Metals: 250 g/L.
 - 5. Pretreatment Wash Primers: 420 g/L.
 - 6. Floor Coatings: 100 g/L.
 - 7. Shellacs, Clear: 730 g/L.
 - 8. Shellacs, Pigmented: 550 g/L.
- D. Colors: As selected by Owner from manufacturer's full range.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
 - 1. Wood: 15 percent.
 - 2. Gypsum Board: 12 percent.
- C. Verify suitability of substrates, including surface conditions and compatibility with existing finishes and primers.
- D. Proceed with coating application only after unsatisfactory conditions have been corrected.
 - 1. Application of coating indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual" applicable to substrates and paint systems indicated.
- B. Remove hardware, covers, plates, and similar items already in place that are removable and are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
 - 1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.

3.3 APPLICATION

- A. Apply paints according to manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual."
- B. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.

3.4 INTERIOR PAINTING SCHEDULE

- A. Wood Substrates: Wood trim, Architectural woodwork, Doors and Windows.
 - 1. Latex over Latex Primer System MPI INT 6.3T:
 - a. Prime Coat: Primer, latex, for interior wood, MPI #39.
 - 1) Benjamin Moore.
 - 2) Sherwin Williams.
 - b. Intermediate Coat: Latex, interior, matching topcoat.
 - c. Topcoat: Latex, interior, semi-gloss (MPI Gloss Level 5), MPI #54.
 - 1) Benjamin Moore.
 - 2) Sherwin Williams.
- B. Wood Substrates: Traffic surfaces, including stairs.
 - 1. Latex Porch & Floor Enamel System MPI INT 6.5G:
 - a. Prime Coat: Primer sealer, alkyd, interior, MPI #45.

- 1) PPG Architectural.
 - 2) Sherwin Williams.
 - b. Intermediate Coat: Floor paint, latex, matching topcoat.
 - c. Topcoat: Floor paint, latex, low gloss (maximum MPI Gloss Level 3), MPI #60.
 - 1) PPG Architectural.
 - 2) Sherwin Williams.
- C. Gypsum Board Substrates:
1. Latex over Latex Sealer System MPI INT 9.2A:
 - a. Prime Coat: Primer sealer, latex, interior, MPI #50 X green.
 - 1) Benjamin Moore
 - 2) PPG Architectural
 - 3) Sherwin Williams
 - b. Intermediate Coat: Latex, interior, matching topcoat.
 - c. Topcoat: Latex, interior (MPI Gloss Level 3), MPI #52 X green.
 - 1) Benjamin Moore
 - 2) PPG Architectural
 - 3) Sherwin Williams.

END OF SECTION 099123

SECTION 102800 -BATHROOM AND LAUNDRY ACCESSORIES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Private-use bathroom accessories.

PART 2 - PRODUCTS

- 2.1 Products shall be provided under a Contract Allowance. Refer to Section 010200 "Allowances"

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install accessories according to manufacturers' written instructions, using fasteners appropriate to substrate indicated and recommended by unit manufacturer. Install units level, plumb, and firmly anchored in locations and at heights indicated.
- B. Grab Bars: Install to withstand a downward load of at least 250 lbf, when tested according to ASTM F 446.

END OF SECTION 102800

SECTION 123530 - RESIDENTIAL CASEWORK

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes kitchen and vanity cabinets.

1.2 ACTION SUBMITTALS

PART 2 - PRODUCTS

- 2.1 Products shall be provided under a Contract Allowance. Refer to Section 010200 "Allowances."

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install cabinets with no variations in flushness of adjoining surfaces; use concealed shims. Where cabinets abut other finished work, scribe and cut for accurate fit. Provide filler strips, scribe strips, and moldings in finish to match cabinet face.
- B. Install cabinets without distortion so doors and drawers fit the openings, are aligned, and are uniformly spaced. Complete installation of hardware and accessories as indicated.
- C. Install cabinets level and plumb to a tolerance of 1/8 inch in 8 feet.
- D. Fasten cabinets to adjacent units and to backing.
 - 1. Fasten wall cabinets through back, near top and bottom, and at ends not more than 16 inches o.c. with No. 10 wafer-head screws sized for not less than 1-1/2-inch penetration into wood framing, blocking, or hanging strips

3.2 ADJUSTING AND CLEANING

- A. Adjust cabinets and hardware so doors and drawers are centered in openings and operate smoothly without warp or bind. Lubricate operating hardware as recommended by manufacturer.

END OF SECTION 123530

SECTION 222326 – PLUMBING-HVAC-ELECTRICAL GENERAL REQUIREMENTS

PART 1 - GENERAL

1.1 GENERAL PLBG. HVAC. ELECT. REQUIREMENTS

- A. Refer to Division 01 for General Requirements applicable to all work.
- B. Mechanical, plumbing and electrical sub-contractors shall provide work in accordance with applicable specification sections, local and state codes and requirements, and good engineering practice.
- C. It is the intent of the specifications to call for completed work tested and ready for operation, provide all materials, equipment and labor necessary to complete the work outlined within this document. Any apparatus, appliance, material, work or any incidental accessories necessary to make the work complete and perfect in all respects as well as ready for operation as determined by good trade practice, even if not particularly specified, shall be furnished, delivered and installed without any additional expense to the Owner.
- D. The Contractor shall be responsible for arranging for inspections by the authority having jurisdiction. The Contractor shall be available and present for inspections by the authority having jurisdiction.
- E. The following definitions apply:
 - 1. Furnish: The term “furnish” is used to mean, “supply and deliver to the project site ready for unloading, unpacking, assembly, installation and similar operations”.
 - 2. Install: The term “install” is used to describe operations at a project site including the actual, “unloading, unpacking, assembly, erection, placing, anchoring, applying, working to dimension, finishing, curing, protecting, cleaning and similar operations”.
 - 3. Provide: The term “provide” is used to mean, “to furnish and install completely and ready for the intended usage”.
 - 4. Remove: The term “remove” is used to mean, “to disconnect from its present position and take away from the premises and to dispose of in a legal manner”.
 - 5. Substitutions: The term “substitutions” is used to mean, “requests for change in products, materials, equipment and methods of construction required by contract documents proposed by the contractor after award of the contract”.
- F. Provide access doors in walls, ceilings and floors at all automatic valves and other apparatus and equipment requiring periodic service and inspection. Coordinate type and location with architect for approval.
- G. Provide shut-off duty valves at each branch connection to supply mains at supply connection, to each piece of equipment and elsewhere as indicated.
- H. Provide drain valves at low points in mains, risers, branch lines and elsewhere as required for system drainage.

- I. Provide pressure-reducing valves on hot water generators and elsewhere as required to regulate system pressure.
- J. Furnish motor starters and disconnects for all mechanical equipment to electrician for installation and wiring as required.

1.2 SUBMITTALS

- A. Provide shop drawings and product data for the following:
 - 1. Gas fired attic mounted furnace.
 - 2. Registers and grilles.
 - 3. Ductwork insulation.
 - 4. Duct layout, indicating sizes, routing, and location of registers and grilles. Scale: ¼" = 1'-0"-minimum.
 - 5. Plumbing fixtures, piping, valves and accessories.
 - 6. Domestic hot water heater.
 - 7. Electrical equipment including service panels, wiring devices, light fixtures, fire alarm devices.
 - 8. Certification by the contractor that any substitution of specified equipment or materials proposed is equal to or better than in every significant respect required by the contract documents and that it will perform adequately in the application intended. Include the contractor's waiver of rights to additional payment or time that may subsequently become necessary because of failure of the substitution to perform adequately.

1.3 GUARANTEES

- A. The Contractor shall guarantee all material and workmanship under these specifications and the contract for a period of one (1) year from the date of Substantial Completion. During this guarantee period, all defects developing through faulty equipment, materials or workmanship shall be corrected or replaced immediately by the Contractor without expense to the Owner. Such repairs or replacements shall be made to the Architect's and Engineer's satisfaction.
- B. Contractor shall provide name, address and phone number of all contractors, subcontractors and associated equipment they provided.

END OF SECTION 222326

SECTION 224000 PLUMBING PERFORMANCE SPECIFICATION

1.1 DESCRIPTION OF PLUMBING SCOPE

- A. Plumbing scope of work shall include the following:
1. Provide new natural gas meter rig in a location above the flood plain. Location of gas meter shall be in accordance with utility company regulations and subject to Architect's approval. Coordinate with the gas utility company connection of gas service to new meter.
 2. Provide new domestic water meter and pit. Meter shall be located in a new water meter pit. Coordinate location of the meter pit, and installation details with water utility company and authorities having jurisdiction.
 3. Contractor shall contact local Plumbing Inspector or authority having jurisdiction before submitting bid to determine if the existing sanitary waste line from the property to the street needs to be investigated for integrity and/or replaced. Include cost in bid if required.
 4. Provide new plumbing fixtures in accordance with these specifications.
 5. Provide a new gas-fired domestic water heater. Provide new domestic hot water piping from the water heater to the new fixtures.
 6. Provide and connect gas piping from the meter to new gas furnace, domestic water heater, kitchen range and clothes dryer.
 7. Connect domestic cold water piping from the meter to the new plumbing fixtures and equipment.
 8. Provide sanitary waste piping from new plumbing fixtures to sanitary waste main. Provide vent piping from the fixtures through the roof.
 9. All exposed water and sanitary waste piping from 48 inches below grade to their penetration through the first floor shall be provided with electric heat tracing sized to prevent freezing. Provide insulation for heat traced piping in accordance with these specifications. Provide water-proofed aluminum jacket around insulated piping to prevent damage from any future flood event. Provide electric heat trace system compatible with piping to which it is attached.
 10. Provide any new piping, fittings and insulation in accordance with the requirements of this specification.

1.2 PLUMBING SYSTEM – GENERAL REQUIREMENTS

- A. Pipe Threads: ASME B1.20.1 for factory-threaded pipe and pipe fittings
- B. Comply with applicable codes for installation of backflow prevention devices.
- C. All plumbing systems shall be designed and installed in accordance with the latest editions of the International Building Code, the International Plumbing Code and all local, state and federal codes and requirements.

- D. All new domestic water supply piping shall be type L cooper with copper or brass fittings for all mains and risers. Type K copper or AWWA approved polypropylene piping shall be used where required for underground or under slab piping. PEX tubing may be substituted with Architect's approval.
- E. All new domestic water piping shall be cleaned, sterilized and leak tested in accordance with the local health department regulations and local or state codes.
- F. New insulation for all domestic hot and cold water piping shall be as follows. All domestic hot water piping shall be 1" thick fiberglass piping with jacket. Cold water piping shall be installed with 1/2" thick foam Arma-flex or equal self-sealing pipe insulation with vapor barrier jacket. Provide water proof aluminum jacket around exposed piping.
- G. Sanitary waste and vent piping shall be DWV grade PVC piping with socket welded fittings. Provide minimal insulation around heat traced sanitary waste piping to protect heat trace. Provide waterproof jacket around sanitary waste pipe insulation
- H. Install all piping systems in such a manner to avoid pipe freezing. Provide not only piping insulation, but building insulation between cold surfaces and piping.
- I. Provide heat trace on all domestic water and sanitary waste pipes installed in areas exposed to freezing temperatures, and as specified elsewhere. The heat trace to be self-regulating temperature cable system by Raychem.
- J. Natural gas piping shall be Schedule 40 black steel and sized in accordance with the requirements of the International Mechanical Code and NFPA 54. Leak test all piping in accordance with utility requirements, local and state codes. Provide gas cocks and shut- off valve at all equipment.

1.3 PLUMBING FIXTURES

- A. Provide new water closets with seats, counter top lavatories with faucets and fittings, shower and fittings, and kitchen sink with faucet and fittings under a Contract Allowance specified elsewhere. Fixtures shall be residential grade. Refer to Section 224100 "Residential Plumbing Fixtures".

1.4 PLUMBING EQUIPMENT

- A. Provide new 40 gallon storage gas-fired domestic water heater, A.O. Smith or equal.
- B. Provide exterior freeze proof hose bibs located per Owner's direction. As a minimum provide one hose bib each on the south and north sides of the building.
- C. Provide a laundry/clothes washer flush valve box at the clothes washer. The unit shall be manufactured by Simons or PPP Inc, with water hammer arrestor, Y2" NPT inlets, 3/4" hose connections and 2" drain connections.
- D. Provide a 2" high drain pan under the clothes washer and dryer. The pan shall be constructed from reinforced fiberglass or galvanized steel with welded and water tight connections. Provide a drain

connection to the clothes washer drain, prior to the trap, to prevent a dry trap condition and sewer gases entering into the room.

- E. Provide a Watts Manufactures "Intelliflow" automatic washing machine shutoff valve, with leak sensor, the washing machine.

END OF SECTION 224000

SECTION 224100 - RESIDENTIAL PLUMBING FIXTURES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Faucets.
2. Bathroom sinks
3. Showers.
4. Kitchen sinks.
5. Dishwasher air-gap fittings.
6. Water closets.
7. Toilet seats.
8. Supply fittings.
9. Waste fittings.

- B. Provide new water closets with seats, counter top lavatories with faucets and fittings, shower and fittings, and kitchen sink with faucet and fittings under a Contract Allowance. Refer to Section 010200 "Allowances".

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Include rough in diagrams.

1.3 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Counter cutout templates for mounting of counter-mounted plumbing fixtures.

1.4 CLOSEOUT SUBMITTALS

- A. Maintenance data.

PART 2 - PRODUCTS

1.5 Products listed below shall be provided as part of the Work and are not part of the Plumbing Fixture Allowance.

1.6 SUPPLY FITTINGS

- A. NSF Standard: Comply with NSF/ANSI 61 Annex G, "Drinking Water System Components - Health Effects," for faucet materials that will be in contact with potable water.
- B. Standard: ASME A112.18.1/CSA B125.1.
- C. Lavatory and Kitchen Sink Supply Fittings:
 - 1. Supply Piping: Chrome-plated-brass pipe or chrome-plated-copper tube matching water-supply piping size. Include chrome-plated wall flange.
 - 2. Stops: Chrome-plated-brass, one-quarter-turn, ball-type or compression stop with inlet connection matching water-supply piping type and size.
 - a. Operation: Wheel handle.
 - 3. Risers:
 - a. Size: NPS 3/8 for lavatories.
 - b. Size: NPS 1/2 for kitchen sinks.
 - c. Material: [Chrome-plated, soft-copper flexible tube] [ASME A112.18.6, braided-or corrugated-stainless-steel flexible hose] riser.

1.7 WASTE FITTINGS

- A. Standard: ASME A112.18.2/CSA B125.2.
- B. Drain: Pop-up type with NPS 1-1/4 straight tailpiece as part of faucet for standard lavatories.
- C. Drain: Grid type with NPS 1-1/2 straight tailpiece for standard kitchen sinks.
- D. Trap:
 - 1. Size: NPS 1-1/4 for lavatories.
 - 2. Size: NPS 1-1/2 for kitchen sinks.
 - 3. Material: Chrome-plated, [two-piece, cast-brass trap and swivel elbow with 0.032-inch-thick brass tube to wall

1.8 GROUT

- A. Standard: ASTM C 1107, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- B. Characteristics: Nonshrink; recommended for interior and exterior applications.
- C. Design Mix: 5000-psi, 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

PART 3 - EXECUTION

1.9 INSTALLATION

- A. Install plumbing fixtures level and plumb according to roughing-in drawings.
- B. Install floor-mounted water closets on closet flange attachments to drainage piping.
- C. Install counter-mounting fixtures in and attached to casework.
- D. Install pedestal lavatories on pedestals and secured to wood blocking in wall.
- E. Install water-supply piping with stop on each supply to each fixture to be connected to water distribution piping. Attach supplies to supports or substrate within pipe spaces behind fixtures. Install stops in locations where they can be easily reached for operation.
 - 1. Exception: Use ball or gate valves if supply stops are not specified with fixture.
- F. Install tanks for accessible, tank-type water closets with lever handle mounted on wide side of compartment.
- G. Install toilet seats on water closets.
- H. Install faucet flow-control fittings with specified flow rates and patterns in faucet spouts if faucets are not available with required rates and patterns. Include adapters if required.
- I. Install shower flow-control fittings with specified maximum flow rates in shower arms.
- J. Install traps on fixture outlets.
 - 1. Exception: Omit trap on fixtures with integral traps.
 - 2. Exception: Omit trap on indirect wastes unless otherwise indicated.
- K. Install dishwasher air-gap fitting at each sink indicated to have air-gap fitting. Install in sink deck. Connect inlet hose to dishwasher and outlet hose to disposer.

- L. Set bathtubs and shower receptors in leveling bed of cement grout.
- M. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings.
- N. Seal joints between plumbing fixtures, counters, floors, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

1.10 CONNECTIONS

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.

1.11 ADJUSTING

- A. Operate and adjust plumbing fixtures and controls. Replace damaged and malfunctioning fixtures, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.

1.12 CLEANING AND PROTECTION

- A. After completing installation of plumbing fixtures, inspect and repair damaged finishes.
- B. Clean plumbing fixtures, faucets, and other fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed plumbing fixtures and fittings.
- D. Do not allow use of plumbing fixtures for temporary facilities unless approved in writing by the Architect.

END OF SECTION 224100

SECTION 23000 HVAC PERFORMANCE SPECIFICATION

1.1 DESCRIPTION OF HVAC SCOPE

- A. HVAC scope of work shall include the following:
 - 1. Provide new gas fired furnace with controls.
 - 2. Provide new ductwork with registers and diffusers.
 - 3. Provide new toilet exhaust fans for the bathrooms.
 - 4. Provide new ductwork, wall caps and accessories for kitchen and clothes dryer exhausts.

1.2 GAS FURNACES AND ACCESSORIES

- A. Provide a new gas fired condensing horizontal mounted furnace. Furnace shall be located in the attic above the second floor. Furnace shall have a minimum input capacity of 50 MBH, and shall be a minimum of 92% efficient. Fan shall have the capability of providing a minimum of 1100 cfm. Fan shall be sized to provide this volume at an external static pressure of 0.5", anticipating the installation of a d/x cooling coil in the future.
- B. Provide direct vent piping, and sealed combustion air.
- C. Provide automatic temperature control system for multiple zones. Provide one zone per floor.
- C. Furnace shall be Payne or approved equal by Trane or Lennox

1.3 TOILET EXHAUST FAN

- A. Toilet exhaust fans shall be recessed ceiling mounted with integral grille, minimum of 75 cfm, as manufactured by Broan, Panasonic or equal. Control shall be a separate switch located adjacent to the light switch.

1.4 DUCTWORK, GRILLES AND ACCESSORIES

- A. Ductwork distribution system and accessories: For all ductwork, provide galvanized steel supply and return air ductwork with vapor barrier, exterior blanket insulation for the furnace unit. The contractor shall size all ductwork. Ductwork mains shall be designed for a maximum velocity of 750 feet per minute and a maximum static pressure of 0.08 in. wc. per 100 feet of duct. Branch ducts shall be sized for a maximum velocity of 500 feet per minute. The return air system shall be ducted with internal noise attenuation lining for the first 10 feet of the ductwork minimum from unit.
- B. Provide Young Regulators manual balancing dampers, and Bowden Cable remote control systems, for each main and branch duct for system balancing. Provide air balancing for the entire system and adjustments so as to maintain the minimum CFM requirements. Total supply air rates shall be calculated to meet the heating loads for the building. Dampers shall be placed

no closer than 6 feet from an air terminal outlet for ducts equal to and smaller than 10" in diameter and 8 times the duct diameter for ductwork larger than 12" or larger.

- C. Flexible duct shall be limited to 5' length with a minimum number of bends. Flexible duct shall not be used as an elbow.
- D. Wall mounted and ceiling mounted supply and return registers shall be square or rectangular, constructed of extruded aluminum, with adjustable deflection, model type TB for supply and TC for return as manufactured by Tuttle & Bailey. NC ratings shall not exceed 22 at the diffuser.

1.5 DUCTWORK INSULATION SYSTEM

- A. Insulation thickness shall be in accordance with latest edition of ASHRAE 90.2: except ductwork insulation shall not be less than 1 1/2" thick fiberglass with vapor barrier. All insulation materials, adhesives, coatings, and other accessories shall have flame spread ratings of 25 or less, and smoke developed ratings of 50 or less as tested by ASTM E84 (NFP A 255) method. All insulation materials shall be installed in accordance with the manufacturer's recommendations and in accordance with the latest edition of SMACNA and ASHRAE standards.

END OF SECTION 230000

SECTION 260000 ELECTRICAL PERFORMANCE SPECIFICATION

1.1 ELECTRICAL SYSTEM – GENERAL REQUIREMENTS

- A. Systems shall include, but are not limited to; raceways for all utility service requirements, secondary terminations, all trenching, main distribution and meter socket, load centers, fire alarm devices, telecommunications service, cable-TV service.
- B. Provide all electrical connections to all mechanical and plumbing equipment including but not limited to; HVAC equipment, exhaust fans, water heater control circuit, laundry equipment and kitchen appliances.
- C. Comply with all applicable codes for installation of electrical components.
- D. Exact locations of all power receptacles, switches, telecommunications and CATV outlets shall be reviewed with the Architect and Homeowner prior to roughing in. relocations of outlets up to ten feet from their original plan locations shall be performed by the Contractor at no additional cost.

1.2 MAIN ELECTRICAL SERVICE

- A. The electrical service shall be located overhead from utility pole located at street. Coordinate with utility company having jurisdiction.
- B. The service shall be routed from the utility pole to exterior revenue meter located on the building per utility company requirements.
- C. The electrical service shall consist of a 240/120 volt, 200amp, 1 phase, 3 wire to utility meter. Service will be routed to the new panel board located in the new building.
- D. Coordinate with utility companies having jurisdiction and local cable company for exact requirements.

1.3 ELECTRICAL DISTRIBUTION SYSTEM

- A. Provide a 200amp 240V 1 phase, 3 wire, 42 pole panel board with 200amp main circuit breaker and 42 20A,1P C/B.
- B. Arc fault type circuit breakers shall be installed in all bedroom branch circuits.
- C. Provide surge suppression system for the electrical service, telephone service and CATV service.

1.4 WIRING

- A. Wiring for power distribution and general lighting throughout the interior shall be in non-metallic (Type NM) cable.
- B. All exterior wiring shall be in rigid galvanized steel conduit or PVC.

1.5 LIGHTING AND CONTROLS

- A. Lighting fixtures shall be provided under a Contract Allowance which shall be coordinated with the Architect and Owner.
- B. Lighting controls shall be a combination of wall rocker switches and dimmer switches. Dimmer switches and light switches shall be Lutron “Decora” style.

1.6 RECEPTACLES

- A. Provide power receptacles with cover-plates according to National Electrical Code “NEC 2011” sections 210.52, including but not limited to; bed rooms, living room, dining room, kitchen, bathroom, mechanical area, laundry area, Telecommunication and CATV demarcation points and at each exterior door and Lower Level.
- B. All receptacles in bathrooms and kitchen shall be GFCI protected.
- C. All receptacles located on the exterior of the residence shall be weather proof listed “While-In Use” and GFCI protected.
- D. Receptacles shall be Lutron “Decora” style.

1.7 FIRE ALARM SYSTEM

- A. The fire alarm system shall consist of 120V smoke detectors with battery back-up.
- B. Combination 120V smoke and CO detectors with battery backup outside of each bedroom.
- C. Heat detectors in all mechanical spaces, attic and crawl spaces and Lower Level.
- D. All of the smoke and heat detectors shall be interconnected, such that all devices will go into notification mode when activated.

1.8 TELECOMMUNICATION SYSTEM

- A. The telecommunications system shall include a new overhead service from a utility pole to exterior wall area of the house for telephone and data service, and internal wiring.

- B. Provide 6 wired outlet locations with faceplates. The exact location and specific ports and cables shall be coordinated with the Owner and Architect.
- C. For cabling infrastructure, provide CAT 5E cabling .

1.9 CATV SERVICE

- A. The CATV system shall include a new overhead service from a utility pole to exterior wall area of the house for CATV service and internal wiring.
- B. Provide 4 wired outlet locations with faceplates. The exact location and specific ports and cables shall be coordinated with the Owner and Architect.
- C. For cabling infrastructure provide RG-6 coaxial cabling for lengths up to 150 feet and RG-11 for lengths 151 to 250 feet.
- D. Outlets and faceplates and the quantity of specific ports and cables shall be coordinated with the Owner and Architect.

END OF SECTION 260000

SECTION 265100 - LIGHT FIXTURES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Interior and exterior lighting fixtures, lamps, and ballasts, transformers and drivers.
 - 2. Photo cell controls for exterior lighting.
- B. Provide new light fixtures under a Contract Allowance. Refer to Section 010200 "Allowances".

1.2 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NFPA 70.

PART 2 - PRODUCTS

2.1 GENERAL REQUIREMENTS FOR LIGHTING FIXTURES AND COMPONENTS

- A. Recessed Fixtures: Comply with NEMA LE 4 for ceiling compatibility for recessed fixtures.
- B. Incandescent Fixtures: Comply with UL 1598.
- C. Fluorescent Fixtures: Comply with UL 1598.
- D. Metal Parts: Free of burrs and sharp corners and edges.
- E. Sheet Metal Components: Steel unless otherwise indicated. Form and support to prevent warping and sagging.
- F. Doors, Frames, and Other Internal Access: Smooth operating, free of light leakage under operating conditions, and designed to permit relamping without use of tools. Designed to prevent doors, frames, lenses, diffusers, and other components from falling accidentally during relamping and when secured in operating position.

G. Diffusers and Globes:

1. Acrylic Lighting Diffusers: 100 percent virgin acrylic plastic. High resistance to yellowing and other changes due to aging, exposure to heat, and UV radiation.
2. Glass: Annealed crystal glass unless otherwise indicated.

2.2 BALLASTS FOR LINEAR FLUORESCENT LAMPS

A. General Requirements for Electronic Ballasts:

1. Comply with UL 935 and with ANSI C82.11.
2. Ballasts shall be designed for full light output unless another BF, dimmer, or bi-level control is indicated.

B. Ballasts for Low-Temperature Environments: Electronic or electromagnetic type rated for 0 deg F starting and operating temperature with indicated lamp types.

C. Ballasts for Residential Applications: Fixtures designated as "Residential" may use low-power-factor electronic ballasts having a Class B sound rating and total harmonic distortion of approximately 30 percent.

D. Ballasts for Dimmer-Controlled Lighting Fixtures: Electronic type.

1. Dimming Range: 100 to 5 percent of rated lamp lumens.

2.3 BALLASTS FOR COMPACT FLUORESCENT LAMPS

A. Description: Electronic-programmed rapid-start type, complying with UL 935 and with ANSI C 82.11, designed for type and quantity of lamps indicated. Ballast shall be designed for full light output unless dimmer or bi-level control is indicated:

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Lighting fixtures: Set level, plumb, and square with ceilings and walls. Install lamps in each fixture.
- B. Comply with NFPA 70 for minimum fixture supports.
- C. Adjust aimable lighting fixtures to provide required light intensities.

END OF SECTION 265100

SECTION 311000 - SITE CLEARING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Protecting existing vegetation to remain.
2. Removing existing vegetation.
3. Clearing and grubbing.
4. Stripping and stockpiling topsoil.
5. Removing above- and below-grade site improvements not removed by others
6. Disconnecting, capping, or sealing site utilities not performed by others.
7. Temporary erosion and sedimentation control.

1.2 MATERIAL OWNERSHIP

- A. Except for materials indicated to be stockpiled or otherwise remain Owner's property, cleared materials shall become Contractor's property and shall be removed from Project site.

1.3 FIELD CONDITIONS

- A. The existing residence, its foundations and utility connections, and hazardous materials abatement shall be removed by the Owner. The area shall be rough graded and all demolition debris removed from the site by the Owner prior to commencement of construction.
- B. Traffic: Minimize interference with adjoining roads, streets, walks, and other adjacent occupied or used facilities during site-clearing operations.
1. Do not close or obstruct streets, walks, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction.
 2. Provide alternate routes around closed or obstructed traffic ways if required by Owner or authorities having jurisdiction.
- C. Salvageable Improvements: Carefully remove items indicated to be salvaged and store on Owner's premises.
- D. Utility Locator Service: Notify utility locator service for area where Project is located before site clearing.
- E. Do not commence site clearing operations until temporary erosion- and sedimentation-control and plant-protection measures are in place.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Satisfactory Soil Material: Requirements for satisfactory soil material are specified in Section 312000 "Earth Moving."
 - 1. Obtain approved borrow soil material off-site when satisfactory soil material is not available on-site.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Protect and maintain benchmarks and survey control points from disturbance during construction.
- B. Verify that trees, shrubs, and other vegetation to remain or to be relocated have been flagged and that protection zones have been identified.
- C. Protect existing site improvements to remain from damage during construction.
 - 1. Restore damaged improvements to their original condition, as acceptable to Owner.

3.2 TEMPORARY EROSION AND SEDIMENTATION CONTROL

- A. Provide temporary erosion- and sedimentation-control measures to prevent soil erosion and discharge of soil-bearing water runoff or airborne dust to adjacent properties and walkways, according to erosion- and sedimentation-control Drawings and requirements of authorities having jurisdiction.
- B. Verify that flows of water redirected from construction areas or generated by construction activity do not enter or cross protection zones.
- C. Inspect, maintain, and repair erosion- and sedimentation-control measures during construction until permanent vegetation has been established.
- D. Remove erosion and sedimentation controls, and restore and stabilize areas disturbed during removal.

3.3 TREE AND PLANT PROTECTION

- A. Protect trees and plants remaining on-site to avoid damage during construction.

- B. Repair or replace trees, shrubs, and other vegetation indicated to remain or be relocated that are damaged by construction operations.

3.4 EXISTING UTILITIES

- A. Locate, identify, disconnect, and seal or cap utilities indicated to be removed or abandoned in place by the Contractor.
 - 1. Arrange with utility companies to shut off indicated utilities.
- B. Interrupting Existing Utilities: Do not interrupt utilities serving facilities occupied by Owner or others, unless permitted under the following conditions and then only after arranging to provide temporary utility services according to requirements indicated:
 - 1. Notify Architect not less than two days in advance of proposed utility interruptions.
 - 2. Do not proceed with utility interruptions without Architect's written permission.

3.5 CLEARING AND GRUBBING

- A. Remove obstructions, trees, shrubs, and other vegetation to permit installation of new construction.
 - 1. Grind down stumps and remove roots larger than 3 inches in diameter, obstructions, and debris to a depth of 18 inches below exposed subgrade.
 - 2. Use only hand methods or air spade for grubbing within protection zones.
- B. Fill depressions caused by clearing and grubbing operations with satisfactory soil material unless further excavation or earthwork is indicated.
 - 1. Place fill material in horizontal layers not exceeding a loose depth of 8 inches , and compact each layer to a density equal to adjacent original ground.

3.6 TOPSOIL STRIPPING

- A. Remove sod and grass before stripping topsoil.
- B. Strip topsoil to depth of 6 inches in a manner to prevent intermingling with underlying subsoil or other waste materials.
- C. Stockpile topsoil away from edge of excavations without intermixing with subsoil or other materials. Grade and shape stockpiles to drain surface water. Cover to prevent windblown dust and erosion by water.

3.7 SITE IMPROVEMENTS

- A. Remove existing above- and below-grade improvements as indicated and necessary to facilitate new construction.

3.8 DISPOSAL OF SURPLUS AND WASTE MATERIALS

- A. Remove surplus soil material, unsuitable topsoil, obstructions, demolished materials, and waste materials including trash and debris, and legally dispose of them off Owner's property.
- B. Separate recyclable materials produced during site clearing from other nonrecyclable materials. Store or stockpile without intermixing with other materials, and transport them to recycling facilities. Do not interfere with other Project work.

END OF SECTION 311000

SECTION 312000- EARTH MOVING

PART 1 - GENERAL

1.1 SUMMARY

- A. Furnish all labor, materials, tools, equipment, transportation and services to complete all foundation earthwork, compaction and backfilling.

1.2 SITE CONDITIONS

- A. Soil test borings: data on indicated subsurface conditions are not intended as representations or warranties of accuracy or continuity between soil bearings. It is expressly understood that the Architect and Owner will not be responsible for interpretations or conclusions drawn there from by Contractor. Data is made available for the convenience of Contractor.
- B. Existing Utilities: Locate existing underground utilities and fuel storage tanks in areas of work. If utilities are to remain in place, provide adequate means of support and protection during earthwork operations. Contact "Call Before You Dig" prior to any excavation.

PART 2 – PRODUCTS

2.1 SOIL MATERIALS

- A. Satisfactory soil materials are defined as those complying with ASTM D2487 soil classification Groups GW, GP, GM, SM, SW and SP.
- B. Unsatisfactory soil materials are defined as those complying with ASTM D2487 soil classification groups GC, SC, ML, MH, CL, CH, OL, OH and PT.
- C. Bank-run gravel: well graded granular soil free of organic material and complying with the following gradation:

3 1/2" sieve	90% to 100% passing
1 1/2" sieve	55% to 95% passing
1/4" sieve	25% to 60% passing
#10 sieve	15% to 45% passing
#40 sieve	5% to 25% passing
#100 sieve	0% to 10% passing
#200 sieve	0% to 5% passing
- D. Crushed stone: crushed durable stone screened to a uniform size.
- E. Processed stone: crusher run stone consisting of a blend of crushed stone and stone dust with not more than 5% passing the #200 sieve.

- F. Recycled aggregate: crushed concrete, brick, or bituminous pavement, free of organic material, with not more than 5% passing the #200 sieve.

2.2 MATERIALS

- A. Filter fabric: Mirafi 140N non-woven fabric or equivalent.

PART 3 - EXECUTION

3.1 EXCAVATION

- A. Slope sides of excavations to produce a safe and stable embankment. Shore and brace where sloping is not possible because of space restrictions or stability of material excavated. The Contractor shall be responsible for the structural adequacy of all shoring and bracing.
- B. Dewatering: Prevent surface water and subsurface or ground water from flowing into excavation. Do not allow water to accumulate in excavations. Remove water to prevent disturbance of footing sub-grade. Provide and maintain pumps, well points, sumps, suction and discharge lines, and other dewatering system components necessary to convey water away from excavations, in accordance with Section 312319 "Dewatering".
- C. Excavation for grade beams: conform to elevations and dimensions shown within a tolerance of plus or minus 0.10', and extending a sufficient distance from grade beams to permit placing and removal of concrete formwork and installation of footing drains.
- D. Remove all topsoil, uncompacted fill, organic soil, or other unsuitable material from under building.
- E. The Contractor shall comply with all OSHA regulations.
- F. Underpin adjacent structures which may be damaged by excavation work.

3.2 GRADE BEAM SUB-GRADE PREPARATION

- A. Soil adjacent to and below grade beams shall be protected from freezing at all times.
- B. Where grade beams are below the groundwater elevation, place 6 inches of crushed stone under grade beams.
- C. Exterior grade beams shall be not less than 3'-6" below finish grade unless otherwise protected from frost.

3.3 BACKFILLING OF FOUNDATIONS

- A. Backfill for foundation walls and retaining walls shall be compacted granular soil with not more than 10% passing the #200 sieve. If on-site soil does not meet these requirements, the Contractor all furnish soil from off-site at his own expense.
- B. Backfill shall be placed and compacted in 8 inch lifts. Compact to 95% of the maximum density except backfill under landscaped areas need not exceed 90% of the maximum density.
- C. Where foundation walls retain soil, do not backfill walls until floor construction which provides lateral bracing to the walls is in place.
- D. Where foundation walls do not retain soil, place backfill evenly on both sides of the wall.
- E. Recycled aggregate may be used as a backfill material.

3.4 GRADING

- A. Grading Outside Building Lines: Grade areas adjacent to building lines to drain away from structures and to prevent ponding.

3.5 SLAB SUB-BASE

- A. Where the slab is within a heated space, the sub-base shall be 6 inches of bank-run gravel with a maximum size of 2 inches.
- B. Where the slab is exposed to frost, the sub-base shall be 6 inches of 3/4 inch crushed stone.

END OF SECTION 312000

SECTION 312319 – DEWATERING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes construction dewatering.

1.2 FIELD CONDITIONS

- A. Survey Work: Engage a qualified land surveyor or professional engineer to survey adjacent existing buildings, structures, and site improvements; establish exact elevations at fixed points to act as benchmarks. Clearly identify benchmarks and record existing elevations.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Dewatering Performance: Design, furnish, install, test, operate, monitor, and maintain dewatering system of sufficient scope, size, and capacity to control hydrostatic pressures and to lower, control, remove, and dispose of ground water and permit excavation and construction to proceed on dry, stable subgrades.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Provide temporary grading to facilitate dewatering and control of surface water.
- B. Protect and maintain temporary erosion and sedimentation controls, which are specified in Section 311000 "Site Clearing," during dewatering operations.

3.2 INSTALLATION

- A. Install dewatering system utilizing wells, well points, or similar methods complete with pump equipment, standby power and pumps, filter material gradation, valves, appurtenances, water disposal, and surface-water controls.
 - 1. Space well points or wells at intervals required to provide sufficient dewatering.
 - 2. Use filters or other means to prevent pumping of fine sands or silts from the subsurface.

- B. Place dewatering system into operation to lower water to specified levels before excavating below ground-water level.
- C. Provide standby equipment on-site, installed and available for immediate operation, to maintain dewatering on continuous basis if any part of system becomes inadequate or fails.

3.3 OPERATION

- A. Operate system continuously until drains, sewers, and structures have been constructed and fill materials have been placed or until dewatering is no longer required.
- B. Operate system to lower and control ground water to permit excavation, construction of structures, and placement of fill materials on dry subgrades. Drain water-bearing strata above and below bottom of foundations, drains, sewers, and other excavations.
 - 1. Do not permit open-sump pumping that leads to loss of fines, soil piping, subgrade softening, and slope instability.
 - 2. Reduce hydrostatic head in water-bearing strata below subgrade elevations of foundations, drains, sewers, and other excavations.
 - 3. Maintain piezometric water level a minimum of 24 inches below bottom of excavation.
- C. Remove dewatering system from Project site on completion of dewatering. Plug or fill well holes with sand or cut off and cap wells a minimum of 36 inches below overlying construction.

3.4 FIELD QUALITY CONTROL

- A. Survey-Work Benchmarks: Resurvey benchmarks regularly during dewatering and maintain an accurate log of surveyed elevations for comparison with original elevations. Promptly notify Architect if changes in elevations occur or if cracks, sags, or other damage is evident in adjacent construction.

END OF SECTION 312319