

PURCHASING DEPARTMENT

The bid listed below has had addenda issued. Documents are available over the Internet at <http://www.norwalkct.org> Adobe Acrobat reader is required to view this document. If you do not have this software you may download it free from Adobe. The document number to request will be the same as the project number indicated below.

Project #	Addendum #	# of pages	Original Issue Date
3700	2	1	July 20, 2016

Date	August 5, 2016		
Project Number	3700		
Addenda Number	2		
Deadline	2:00 PM	August 10, 2016	
Project Title	Façade Repairs at Norwalk Public Library		

This Addendum is a contract document modifying previously issued documents, which remain in full force except as specifically modified below.

Quotations appearing on the Proposal are to reflect the provisions of this Addendum. Failure to acknowledge receipt of this Addendum in the space provided on the response sheet may subject candidate to disqualification.

NEW INFORMATION:

1. **Question:** Is the contractor responsible for the cost of building or providing a decontamination area for the lead removal?

Response: Contractor is responsible for all aspects lead removal.

2. **Question:** Is the new wood trim to be installed pine or something else?

Response: AWI premium grade. Kiln dried 6-8%, No. 1 pine is acceptable.

3. **Question:** During the walk around it was mentioned to not to worry about bricks that were worn out but in the specs there are some listed to be replaced. Did this change?

Response: Contractor shall bid on only those bricks designated to be replaced (refer to legend). Unit prices will apply if additional work is necessary.