

1

2


3

4

5

6

7



DCF HIGH MEADOWS

BUILDINGS:

- BUILDING 1 - BOYS' UNIT
- BUILDING 2 - GIRLS' UNIT
- BUILDING 3 - SENN BUILDING,  
ADMINISTRATION AND SCHOOL
- BUILDING 4 - GYMNASIUM
- BUILDING 5 - DINING, STOREROOM
- BUILDING 6 - ACTIVITY, SKILL CENTER
- BUILDING 7 - YALE CHILD STUDY
- BUILDING 8 - MAINTENANCE, GAS,  
GROUNDS EQUIPMENT
- BUILDING 9 - MAINTENANCE, HEATING,  
AIR CONDITIONING REPAIR

A

B

C

D

E


A

B

C

D

E



Saw cut and permanently repair road and sidewalk

Install shutoffs with curb boxes

New 1 inch Service to Bldg. 8

Existing 4 inch Domestic Service


Existing 4 inch Fire Service

Tap existing 4 inch ductile service. Provide shut off and curb box



Existing Sanitary Manhole

New 6 inch PVC SBR sanitary line



Lights not to be replaced (Typ. of 7)

825 HARTFORD TURNPIKE

1

2

3

4

5

6

7