

Bloomfield High School Exterior Door Replacement

ADDENDUM #2 Issued November 16, 2016

RESPONSE TO REQUEST FOR INFORMATION

1. What is the specified gauge of steel?

A: Doors are to be 16 gauge metal doors non rated.

2. Are thresholds to be included?

A: All openings shall have new 5" width, 1/2" height aluminum saddle threshold.

3. Are all doors indicated in the column 3'0" x 7'0" true to that size?

A: That column heading is only to indicate that it is a single leaf door. All opening and door sizes are to be field verified.

4. Please confirm window size and height along with exit device mounting?

A: The top of the window shall be 12" from the top of the door and the bottom 42" from the bottom of the door. Window shall be 8" wide. Glass thickness shall be 1/2" and clear laminated glass. Exit device shall be installed at 39" on center.

5. Are all leaves to receive handles for openings requiring pull exterior handles?

A: All doors at opening #9 shall have exterior pull handles. All other opening only requires one pull handle on the door with the lock installed. Lock and handle shall be installed on the right hand leaf.

6. Please clarify how to address missing stops on doors where there are aluminum frames?

A: Doors 13, 14 and 17 require the installation of a minimum 1" thick aluminum bar on entire length of the latch side and along the top.

7. What will be the hours of work?

A: The work schedule will be coordinated with the school schedule. As all of the openings are exterior work will be able to be done during the day. All openings where existing doors have been removed shall be completed and secured before departure that day.