

**Gallup Hill Elementary School  
Expansion & Renovate as New  
Ledyard, Connecticut  
State Project No. 072-0091 E/A/RR/RN  
POST-BID ADDENDUM NO. 8  
October 10, 2017**

For attachments to this Addendum, refer to the following link:

<https://secure.smartbidnet.com/External/PublicPlanRoom.aspx?Id=329588>

**I. REVISIONS TO SPECIFICATIONS**

1. Specification Section 00 11 16 – Invitation to Bid

**The Bid Due date for Bid Package No. 1.18 - Security  
has been extended to October 24, 2017 @ 2:00 p.m.**

**PLEASE SUBMIT ONE ORIGINAL AND ONE COPY OF YOUR BID. THE FOLLOWING DOCUMENTS MUST BE INCLUDED IN YOUR BID, OR YOUR PROPOSAL WILL BE DEEMED NON-RESPONSIVE:**

1. FORM OF PROPOSAL
2. BID SECURITY (BID BOND OR CERTIFIED CHECK)
3. CTDAS UPDATE STATEMENT (if bid exceeds \$500,000.00)

- a. BP 1.18 Re-Bid Pre-Bid Meeting Minutes dated October 6, 2017 are attached to this Post-Bid Addendum No. 8.

2. Specification Section 00 24 13 - Bid Packages

**II. SPECIAL INSTRUCTIONS**

Add the following Special Instructions:

86. The BP 1.18 Security contractor shall coordinate with the elevator contractor for installation of the cabling to the elevator security camera, and for integration of the card readers for the elevator call buttons. The BP 1.18 Security contractor shall include the additional programming required for integrating specific access requirements and the Owner's requirements for schedule and or limited access cards for the elevator call button card readers.

3. Specification Section 00 42 00 - Form of Proposal

- a. Replace this section with revised, attached to this Post-Bid Addendum No. 8.

4. Specification Section 00 63 13 - Bidders' Prebid Requests for Information (Prebid RFI's)

- a. Attached to this Post-Bid Addendum No. 8 are CM Prebid RFI Nos. 1 through 152. All information contained in these responses is to be used by all contractors in the preparation of their bids and will form part of their scope of work.

**III. REVISIONS TO DRAWINGS/SKETCHES**

- a. Sketch SKT-001 - Add card readers and cabling to each elevator on each level, add duress button to Office #102
- b. Sketch SKT-002 - Add card readers and cabling to each elevator on each level, refer to T301/Detail 2/TR #140 Wiring

**IV. ATTACHMENTS TO ADDENDUM**

<u>Description</u>	<u>Pages</u>
Specification Section 00 11 16 - Invitation to Bid – Prebid Meeting Minutes	2
Specification Section 00 42 00 - Form of Proposal, Revised	17
Specification Section 00 63 13 - Bidders' Prebid Requests for Information (Prebid RFI's)	36
Specification Section 00 73 43 - Wage and Hour Rates	40
<u>Sketches</u>	
SKT-001	
SKT-002	