

ADDENDUM #2



**HVAC Upgrades:
Lordship Fire Station**

21 Prospect Drive
Stratford, CT 06615

TOWN PROJECT NUMBER: 2020-30

ISSUED: 3/2/2020

PROJECT TEAM

Architect / Project Manager

Mechanical Engineer



Architecture . Planning . Construction Management

Trumbull, CT 203-243-3346
info@snyderarchitects.com



The work shall be carried out in accordance with the following supplemental instructions and in accordance with the Contract Documents.

CHANGES / CLARIFICATIONS

1. Requests For Information (RFI) Log

- See attached RFI Log.

***** END OF ADDENDUM #2 *****

RFI LOG					
HVAC Upgrades:					
Lordship Fire Station					
3/2/2020					
	Question	Date Received	Directed To	Response	Response Date
1	Please confirm size and type of oil tank to be removed, and remaining volume contents of oil in gallons.	2/16/2020	Town	2000 gallon fiberglass reinforced plastic, double-walled tank. Assume tank will have 1000 gallons of oil at time of removal.	2/20/2020
2	Can you also provide a scope regarding the removal of the tank such as if we are to restore the asphalt / concrete if any?	2/29/2020	Snyder	Area above and around tank to be restored to existing as-found condition.	3/2/2020
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					