

PROJECT #20MIL21201

August 20, 2020

ADDENDUM #2

PROJECT NAME: AASF Access Rd Aircraft Apron Repairs Phase 1 Bradley Army National Guard Base, Windsor Locks, CT

SUBJECT: RFI

Original Bid Due Date / Time: Aug 25, 2020 2:00 pm

The bid dates are not changed by this addendum

To: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this project referenced above. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do so may subject Bid Proposers to disqualification.

Addendum Item 1:

RESPONSES TO QUESTIONS (answers in bold)

1. Is there a separate Test strip for each of the Bids ? (Base Bid and Supplemental Bid) **Yes, each bid will require its own test strip**
2. Will the use of an MTV be used for both the Base Bid and the Supplemental Bid? **No, The MTV is not required for the base bid**
3. Is the JMF for the Bituminous Concrete the same for the Base Bid as it is for the Supplemental Bid ? **The same JMF can be used however needs to be submitted separately for each Bid.**
4. Is the Base Material P-403 and the Surface Material P-401 ? **The material will need to comply with Sections 32 12 15.13 Asphalt paving for Airfields & Section 32 12 17 Hot Mix Bituminous Pavement. All mixes will require the submission of a JMF for approval.**

ATTACHMENTS

NONE

**CONTRACTOR SHALL ACKNOWLEDGE RECEIPT OF THIS
ADDENDUM ON THE BID FORM**

END OF ADDENDUM NO. 1

Sincerely yours,

Ronna Cannata
Purchasing Supervisor
CT Military Department