

CENTRAL CONNECTICUT STATE UNIVERSITY
NEW PUBLIC SAFETY BUILDING
NEW BRITAIN, CT
PROJECT: BI- RC - 311

BID OPENING	1:00 P.M.	SEPTEMBER 14, 2011
ADDENDUM NUMBER 1	DATE OF ADDENDUM	SEPTEMBER 8, 2011

The following clarifications are applicable to drawings and specifications for the project referenced above.

- Item 1 In Specification section 261200: Delete paragraph 1.7.A1 thru A10.
- Item 2 In Specification 220533 Heat Tracing for Plumbing Piping: Heat trace is provided by plumbing contractor and wired for electrical contractor.
- Item 3 Refer to note drawing P2.4, Roof Plan, for heat tracing.
- Item 4 In Specification Section 232419 Motor control Centers: Eliminate this section. Utilize section 232913 Enclosed Controllers. Mechanical contractor shall provide starters. Electrical contractor to provide power wiring.
- Item 5 Drawing E2.2. Revise part number in General Note 1 to "Wire mold AF1 with all plates and trim for devices installed".
- Item 6 Drawing E4.8: Revised scale to 1" = 120'.
- Item 7 Drawing E4.8 and E4.9: E4.9 is the correct routing for new fire alarm system not as indicated on E4.8.
- Item 8 Drawing P4.1: Solenoid valve called out on Detail#1A should be wired by electrical contractor.
- Item 9 Delete reference to unit pricing as listed on section 012000. The Bid Proposal form Section 004100, Item 7.7, correctly states that Contractor Provided Unit Prices are not needed for this project.
- Item #10 In specification Section #054000, Omit reference to change proposal cost summary from Millennium builders Inc, pages 1 and 2. in its entirety from the project.

Item # 11 Aluminum doors # 101A, 101B, 104A, 107A 113A 114A and 200 A shall be aluminum doors in aluminum frames. Delete reference to hollow metal frames in these locations.

Response to Bidder questions:

1. Contractor shall utilize existing Campus site conduit for fire alarm for new work shown.
2. All cabling for the project shall be provided by the contractor with the exception of the supplemental bids for security and fiber , if the supplemental bids are not awarded.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Architect/Engineer (Id3A- Kathyann Cowles 860-657-0757) with copies sent to the DPW Project Manager (Scott Dunnack 860-713-7264) and Construction Manager (Arcadis, Norman Benjamin 860-704-6120)

End of Addendum Number One


Mellanee Walton
Associate Fiscal Administrative Officer
Department of Administrative Services for the
Department of Construction Services