

**DESIGN OF FIRE SPRINKLER SYSTEM
FOR THE TECHNICAL EDUCATION SHOPS AT
OLIVER WOLCOTT REGIONAL VOCATIONAL TECHNICAL
HIGH SCHOOL
TORRINGTON, CONNECTICUT
PROJECT: BI- RT- 853**

BID OPENING

1:00 P.M.

January 10, 2012

ADDENDUM NUMBER 2

January 4, 2012

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

The bid opening will be changed from Tuesday January 10, 2012 at 1:00PM to **Tuesday January 17, 2012 at 1:00 PM**

The Contractor is responsible for providing protection of school property. The Contractor shall provide a minimum of one week prior notice to the Agency for scheduling of any work activity in designated areas. The Agency will remove loose furnishings and materials such as computers, desk chairs, loose tools,... etc in the designated areas. The Contractor will protect all remaining fixed furnishings, heavy equipment and stored materials. The DCS will have sole discretion in determining the extent of the removal of property by the Agency.

Item 2

Drawing FP-5 FIRE PROTECTION SCHEDULES AND DETAILS, dated June 23, 2010, **ADD to SPRINKLER SYSTEM NOTES:** 9. The drawings are diagrammatic and indicate the general arrangement of the fire suppression system included in this contract. The Contractor shall provide piping, valves, fittings, appurtenances, and all other accessories as required for a proper, fully functioning, and professional systems installation.

Item 3 - LIST OF BIDDING REQUESTS FOR INFORMATION AND RESPONSES

1. Q. As discussed at the walk thru, please confirm that painting of the new fire protection system piping is not included.

A. Painting of the new fire protection sprinkler system piping is not part of the scope of work. The Contractor will provide piping and fittings in new and clean condition. Any piping and related accessories exhibiting extensive surface rusting or deterioration will not be acceptable at the sole determination by DCS.

2. Q. As discussed at the walk-thru, please clarify the extensive De-Watering specification (Section 31 23 19) and its relationship to this specific project. Are there existing boring logs which clearly identifies the elevation of the existing water table?

A. De-Watering Specification Section 31 23 19 has been provided in the event that the Contractor discovers ground water during the excavation and installation of the new buried fire mains.

3. Q. As discussed at the walk thru, please confirm that Phase I site work can be undertaken during normal school hours, with the proper protection techniques.

A. Phase I site work can be performed while school is in session provided the Contractor coordinates this work with the Agency and furnishes all required safety measures during excavation and installation of piping.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Architect/Engineer Joe Gargiulo Fax 860-632-1768 with copies sent to the DCS Project Manager, Natalina Raimondi Fax 860-713-7261.

End of Addendum Number Two



Gail Blythe
Associate Fiscal Administrative Officer
Department of Construction Services