



ADDENDUM NO.: FOUR

DATE OF ADDENDUM: June 27, 2012

**Simulation Center
Camp Niantic
BI – Q – 661**

Original Bid Due Date / Time:	June 22, 2012	1:00 PM
Revised Bid Due Date / Time:	June 29, 2012	1:00 PM

Previous Addendums: ONE, TWO, THREE

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated April 25, 2012. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1**Questions and Answers:**

The following questions have been received from potential bidders. These questions and their answers are listed below. The answers may clarify and/or modify the bid documents and shall be made a part thereof as applicable

Q1. Who provides the LP gas tank and regulator?

A1. The contractor will provide the LP gas tank, regulator and piping. The tank is a 1,000 gallon underground steel tank and the installation will include a concrete slab and tie-downs to prevent upward movement when the tank is empty. The Camp Niantic LP gas supplier is Amerigas. The tank, regulator and associate piping will conform to state code and Amerigas' installation requirements. The contractor will pay the cost of the underground tank, piping system and associated installation.

Q2. Does the entire building have to meet ATEP requirements or just the exterior openings?

A2. The entire Simulator facility must comply with ATEP requirements.

Q3. Part 2 – Attachment A, Project Specific General Requirements, page 3, paragraph 15 number 2c indicates: Electronic simulation equipment, including computers, projectors, etc. Does this statement stand for the following rooms: Simman Training Room, Ten Lane Room and Classroom?


A3. This statement applies to each of these rooms. Contractor to provide conduit, wiring, junction boxes, covers and supports as necessary for power, data and telecommunications systems to extend to the equipment locations. The owner will furnish and install the equipment.

Q4. Is it acceptable to use second tier subcontractors to fulfill the SBE and minority hiring requirements of the RFP?

A4. Yes. Second-tier subcontractors hired by a non-SBE general contractor can be used to meet the RFP's SBE and minority requirements.

All questions must be in writing (not phone or e-mail) and must be forwarded to the CT DCS Mike Rice, Project Manager at (860) 713-7261 or 7270.

End of Addendum Four



 David Busanet, Bidding & Contracts Manager
 Department of Administrative Services
 On Behalf of the Department of Construction Services