



ADDENDUM NO.: 3

DATE OF ADDENDUM: February 5, 2013

**Roof Overlay- CT Regional Market
Hartford, CT
BI – HH – 51**

Original Bid Due Date / Time:

February 13, 2013

1:00 pm

Previous Addendums: 1, 2

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated January 4, 2013. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do so subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Clarification: The State of Connecticut – Department of Construction Services is NOT requiring a warranty on this roof. The successful bidder will be required to comply with the manufacturer's material and labor installation guidelines so as to qualify for a 10 year warranty. CT – DCS intends to hire a consultant to periodically inspect the installation to ensure the above.

Item 2


Question: Will DCS entertain a mechanically fastened .045 Reinforced EPDM over ½" HD cover board?

Response: No, DCS is unsure of the ability of the existing decking to adequately hold mechanical fasteners.

Item 3

Clarification: Attached is a sketch referenced in Item 17 of Addendum #2, but was not included.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Architect (Bruce Bockstael FAX: 860 713 7273) with copies sent to the CT DCS Project Manager (Wayne E. Thorpe FAX: 860 713 7261).


David Busanet, Bidding & Contracts Supervisor
Department of Administrative Services
On Behalf of the Department of Construction Services

TRUCK GRAVEL STOP DETAIL
(REVISED) 1/30/2013

