



ADDENDUM NO.: 4

DATE OF ADDENDUM: February 7, 2013

**Roof Overlay- CT Regional Market**  
**Hartford, CT**  
**BI – HH – 51**

Original Bid Due Date / Time:

February 13, 2013

1:00 pm

Previous Addendums: 1, 2, 3

**TO: Prospective Bid Proposers:**

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated January 4, 2013. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

**Item 1**

**Question:** Specification Section 07 53 23 2.2.C calls for water based adhesive. Can usual adhesive be used?

**Response:** Yes, DCS will accept a non-water based adhesive.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Architect (Bruce Bockstael FAX: 860 713 7273) with copies sent to the CT DCS Project Manager (Wayne E. Thorpe FAX: 860 713 7261).

End of Addendum #4

David Busanet, Bidding & Contracts Supervisor  
Department of Administrative Services  
On Behalf of the Department of Construction Services