

ADDENDUM NO: 05

DATE OF ADDENDUM: 12/04/2014

Hammonasset Beach State Park
West Beach Improvements
Madison, CT
BI – T – 603

Original Bid Due Date / Time: 11/19/2014 1:00 pm

REVISED BID DATE/TIME 12/10/2014 1:00 PM

Previous Addendums: Addendum No. 04- November 25, 2014, Addendum No. 03- November 17, 2014: Addendum No. 2- November 14, 2014: Addendum No. 01- November 12, 2014

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated August 25, 2014. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Specification Section 32 92 19- Lawns

Article 2.3 Seed, Subparagraph A1. **Change** Title to Seed Mixture Composition Seed Mix #1

Add the following. Subparagraph A2:

Seed Mixture Composition Seed Mix #2

- Virginia Wild Rye
- Creeping Red Fescue
- Little Bluestem
- Big Bluestem
- Switch Grass
- Blue Vervain
- Rough Bentgrass/Ticklegrass
- New England Aster
- Spotted Joe Pye Weed
- Boneset
- Soft Rush
- Wool Grass

Mix Type #2 to be applied at 6 lbs. per 1000 SF.

ADDENDUM NO: 05

DATE OF ADDENDUM: 12/04/2014

Item 2

Section 329000 Planting

Clarification: Article 3.1, Paragraph J. Mulch. : Mulch is only required for detail 9 on Sheet L008

Item 3

**DRAWING C001- SITE PREPARATION
DRAWING C104- ENLARGEMENT DETAILS AND NOTES**

C001- Note on Drawing Stating: "Contractor to relocate high-voltage electrical line in this area before excavation, coordinate with park staff"

C104; Note states "Do not disturb high-voltage electric within tidal wetland."

Clarification of Design Intent:

The high-voltage cable may require lowering to accommodate grading of the swale in the vicinity. The requirement will depend on the depth of the cable, which is unknown. If cable relocation (lowering) is required, it cannot include disturbance within tidal wetlands, shown hatched on detail 1/C.104.

Scope: Assume the cable will be lowered to a depth of 2 feet below the swale grading; not including the section within the tidal wetlands.

It is the Owner's understanding that the it is a single, direct burial cable that is not in conduit.

Item 4

**C101- Site Grading and Utilities
SE.101 – Electrical Site Plan**

C101- Clarification: The empty conduits that run from the general area of the building and transformer to the "BURT" path, and extend east and west the length of the B.U.R.T. path included in this Project: Refer to Sheet C111 for number and location of conduits.

SE.101 Clarification: All conduits indicated are part of the Project Scope.

Buried conduits shall be PVC; where they extend above ground, the conduit shall be rigid, galvanized steel.

End of Addendum 05



**Mellanee Walton, Associate Fiscal Administrative Officer
Department of Administrative Services
On Behalf of the Division of Construction Services**