

ADDENDUM NO.: 2

DATE OF ADDENDUM: December 9, 2014

**North Campus Residence Hall Bathroom Renovations at
Southern Connecticut State University
BI – RS – 308**

Original Bid Due Date / Time:

December 17, 2014

1:00pm

Previous Addendums: Bid Addendum # 1 Date: December 5, 2014

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 10/2/13. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Written Question Deadline was December 9, 2014 at 12:00pm

Item 2

Question: The mechanical drawings indicate (New) Louver and Bird Screen by G.C. The architectural plans and specifications do not address this. Please provide detail and specification for subject louver and bird screen.

Response: Hooded wall vent is to have a spring loaded damper with gasket, removable ¼" screen (bird screen), 6" inlet & outlet. Wall vent to be constructed from 28 gauge steel with factory primed & painted hood, color to be brown to match existing brick vents. Details can be found on sheet A3.1

All questions must be in writing (by fax or email, not by phone) and must be forwarded to Quisenberry Arcari Architects, Attn: Andrew Tarpill, andrew@qa-architects.com, 860-677-8534 fax with copies sent to the CT DCS Project Manager Thomas Surprenant, Thomas.surprenant@ct.gov, 860-713-7270 fax and Construction Manager Doug Goulet, dgoulet@go-sbs.com, 203-779-5661 fax

End of Addendum #2



Philip St. Amand, Purchasing Assistant
Department of Administrative Services
On Behalf of the Division of Construction Services