

ADDENDUM NO.: 6

DATE OF ADDENDUM: April 21, 2015

**Roof Replacement & Exterior Stair
Willard-Cybulski Correctional Institution
391 Shaker Road
Enfield, CT
BI-JA-463**

Original Bid Due Date/Time:

April 22, 2015

1:00pm

Previous Addenda:

Addenda Nos. 1 & 2, March 25, 2015; Addendum No. 3, April 10, 2015,
Addendum No. 4, April 15, 2015, Addendum No. 5, April 15, 2015

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated January 20, 2015. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

If not required by the manufacturer for a 20 yr warrantee is the "Asphalt Glass Felt used in roofing and waterproofing" on page 1 of 5 Section 07 21 20 still wanted as a base layer?

Please eliminate the "Asphalt Glass Felt" unless required by specific manufacturer for the warranty.


Item 2

There are approximately 8 areas noted M.G. which corresponds to the guard rail to remain. The questions we have are, on the noted spots where the rails are to remain, is it spanning the length of the entire wall that the detail (M.G.) is placed or is it just meant to be in front of the immediate area, and is the rail face mounted to the wall or mounted on top of the parapet wall? If you could get back to me at your earliest convenience it would be greatly appreciated.

Some of the metal guard rails span the entire of the wall area where noted as well as some indicate the specific small areas location. All of the existing guard rails are face mounted to the existing parapet walls.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Architect/Engineer (David Wenchell, dwenchell@silverpetrucelli.com) with copies sent to the CT DCS Project Manager (Glenn Washburn, glenn.washburn@ct.gov).

End of Addendum 6



Mellanee Walton, Associate Fiscal Administrative Officer
Department of Administrative Services
On Behalf of the Division of Construction Services