

ADDENDUM NO.: 4

DATE OF ADDENDUM: September 22, 2015

**DESPP
STATE POLICE TRAINING ACADEMY
RE-ROOFING AND CHIMNEY REPAIR
285 PRESTON AVENUE
MERIDEN, CT
BI- N-335**

Original Bid Due Date / Time:

September 30, 2015

1:00 PM

Previous Addendums:

Addendum #3 dated 9/21/2015, Addendum #2 dated 9/2/2015, Addendum #1 dated 9/2/2015

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated **April 14, 2015**. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Question:

At all the limestone panels around the building, please confirm that we are only cutting and repointing the vertical joints between the panels as noted and that the existing top and bottom joints are to remain.

Answer:

Yes, only cutting and repointing the vertical joints between the panels.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting firm (Hoffmann Architects attn.: Erin Kesegi, AIA and Fax Number 203.239.6340) with copies sent to the CT DCS Project Manager (Ward Ponticelli, RA and Fax Number 860.713.7261).

End of Addendum 4



Mellanee Walton, Associate Fiscal Administrative Officer
Department of Administrative Services
On Behalf of the Division of Construction Services