

ADDENDUM NO.: 3

DATE OF ADDENDUM: February 23, 2016

**REHABILITATION OF WALKWAY & CANOPIES**  
**200 Folly Brook Boulevard**  
**Wethersfield, CT**  
**BI-2B-359**

Original Bid Due Date / Time:

March 2, 2016

1:00 PM

Previous Addendums: Addendum #2, February 16, 2016, Addendum #1, January 28, 2016

**TO: Prospective Bid Proposers:**

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated September 30, 2015. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

**Item 1**

Section 01 14 00 item G: Add:

The demolition can occur during working hours, except for any excessive noise producing activities – e.g. jack hammering. That should be contained between the hours of 1PM and 7PM. The Agency is to be advised of when this type of work is scheduled, so as to inform the staff about the disturbance. Verify city noise ordinance allowances for construction work during this time.

**Item 2**

*Question:*

*We would propose using Sherwin Williams Loxon Xp in lieu of using A100 for all Concrete and EFIS surfaces. This system will help waterproof the surface as well help with color retention will not having any price difference.*

*Answer:*

The use of Sherwin Williams Loxon XP is an acceptable optional substitution for Sherwin Williams A100 listed in specification 09 91 13, paragraph 2.5.A, 2.5.C & 2.5.C.

**Item 3**

The exposed vertical surfaces and underside of the cantilevered concrete North and South Canopies as shown on drawings S-1.2, S-1.4, S-1.5, A-100, A-101 & A-302 shall be painted per specification section 09 91 13.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting firm GM2 Associates, Inc attn.: Scott Anderson, PE and Fax Number 860.657.2926) with copies sent to the CT DCS Project Manager (Ward Ponticelli, RA and Fax Number 860.713.7261).

End of Addendum 3



Philip St. Amand, Purchasing Assistant  
Department of Administrative Services  
On Behalf of the Division of Construction Services